

April 1, 1987

Docket Nos.: 50-413  
and 50-414

Mr. H. B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Amendment No. 25 to Facility Operating License NPF-35  
and Amendment No. 15 to Facility Operating License NPF-52 - Catawba  
Nuclear Station, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 25 to Facility Operating License NPF-35 and Amendment No.15 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications in response to your application dated December 13, 1985.

The amendments change the Technical Specifications related to reporting requirements for primary coolant iodine spikes and delete existing shutdown requirements if coolant iodine activity limits are exceeded for 800 hours in a 12 month period. The amendments are effective as of the date of issuance.

A copy of the related safety evaluation supporting Amendment No.25 to Facility Operating License NPF-35 and Amendment No.15 to Facility Operating License NPF-52 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

*151*

Kahtan Jabbour, Project Manager  
PWR Project Directorate No. 4  
Division of PWR Licensing-A

Enclosures:

1. Amendment No.25 to NPF-35
2. Amendment No.15 to NPF-52
3. Safety Evaluation

cc w/encl:  
See next page

DISTRIBUTION:  
See attached page

*mac*  
PWR#4/DPWR-A  
MDuncan:mac  
03/19/87

*KNS*  
PWR#4/DPWR-A  
KJabbour  
03/18/87

*BJ*  
PWR#4/DPWR-A  
BJYoungblood  
03/31/87

8704080266 870401  
PDR ADOCK 05000413  
P PDR

April 1, 1987

AMENDMENT NO. 25 TO FACILITY OPERATING LICENSE NPF-35 -  
CATAWBA NUCLEAR POWER STATION, UNIT 1  
AMENDMENT NO. 15 TO FACILITY OPERATING LICENSE NPF-52 -  
CATAWBA NUCLEAR POWER STATION, UNIT 2

DISTRIBUTION: w/enclosures:

Docket Nos. 50-413/414

NRC PDR

Local PDR

NSIC

PRC System

PWR#4 R/F

B. J. Youngblood

K. Jabbour

M. Duncan

OGC-Bethesda

T. Barnhart (8)

E. L. Jordan

L. J. Harmon

B. Grimes

J. Partlow

ACRS (10)

E. Butcher

W. Jones

FOB

OPA

LFMB

N. Thompson

J. Lazevnick

Mr. H. B. Tucker  
Duke Power Company

Catawba Nuclear Station

cc:  
A.V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

North Carolina Electric Membership  
Corp.  
3400 Summer Boulevard  
P.O. Box 27306  
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esq.  
Bishop, Liberman, Cook, Purcell  
and Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D. C. 20036

Saluda River Electric Cooperative,  
Inc.  
P.O. Box 929  
Laurens, South Carolina 29360

North Carolina MPA-1  
Suite 600  
3100 Smoketree Ct.  
P.O. Box 29513  
Raleigh, North Carolina 27626-0513

Senior Resident Inspector  
Route 2, Box 179N  
York, South Carolina 29745

L.L. Williams  
Area Manager, Mid-South Area  
ESSD Projects  
Westinghouse Electric Corp.  
MNC West Tower - Bay 239  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

County Manager of York County  
York County Courthouse  
York South Carolina 29745

Mr. Heyward G. Shealy, Chief  
Bureau of Radiological Health  
South Carolina Department of Health  
and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Richard P. Wilson, Esq.  
Assistant Attorney General  
S.C. Attorney General's Office  
P.O. Box 11549  
Columbia, South Carolina 29211

Karen E. Long  
Assistant Attorney General  
N.C. Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Piedmont Municipal Power Agency  
100 Memorial Drive  
Greer, South Carolina 29651

Spence Perry, Esquire  
General Counsel  
Federal Emergency Management Agency  
Room 840  
500 C Street  
Washington, D. C. 20472

Mr. Michael Hirsch  
Federal Emergency Management Agency  
Office of the General Counsel  
Room 840  
500 C Street, S.W.  
Washington, D. C. 20472

Brian P. Cassidy, Regional Counsel  
Federal Emergency Management Agency,  
Region I  
J. W. McCormach POCH  
Boston, Massachusetts 02109



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 25  
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc., (licensees) dated December 13, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 25, and the Environmental Protection Plan

contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan Jabbour, Project Manager  
PWR Project Directorate No. 4  
Division of PWR Licensing-A

Attachment:  
Technical Specification Changes

Date of Issuance: April 1, 1987

PWR#4/DPWR-A  
MDuncan:mac  
03/19/87

*KJS*  
PWR#4/DPWR-A  
KJabbour  
03/18/87

OGC-Bethesda  
*G.S. Myer*  
03/20/87

*BJ*  
PWR#4/DPWR-A  
BJYoungblood  
03/31/87



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 15  
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency, (licensees) dated December 13, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 15, and the Environmental Protection Plan

contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

151

Kahtan Jabbour, Project Manager  
PWR Project Directorate No. 4  
Division of PWR Licensing-A

Attachment:  
Technical Specification Changes

Date of Issuance: April 1, 1987

PWR#4/DPWR-A  
MDuncan:mac  
03/19/87

*KNT*  
PWR#4/DPWR-A  
KJabbour  
03/18/87

OGC-Bethesda  
03/31/87

*G.S. Miguna reviewed package on 3/20/87 + concurred for Unit 1. KNT called him on this on 3/31/87 + obtained his concurrence by telephone*  
PWR#4/DPWR-A  
BJWongblood  
03/31/87

ATTACHMENT TO LICENSE AMENDMENT NO. 25

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 15

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Amended  
Page

3/4 4-27  
3/4 4-28  
B 3/4 4-5  
B 3/4 4-6

6-16  
6-17  
6-18  
6-19

## REACTOR COOLANT SYSTEM

### 3/4.4.8 SPECIFIC ACTIVITY

#### LIMITING CONDITION FOR OPERATION

---

3.4.8 The specific activity of the reactor coolant shall be limited to:

- a. Less than or equal to 1 microCurie per gram DOSE EQUIVALENT I-131, and
- b. Less than or equal to  $100/\bar{E}$  microCuries per gram of gross specific activity.

APPLICABILITY: MODES 1, 2, 3, 4, and 5.

ACTION:

MODES 1, 2 and 3\*:

- a. With the specific activity of the reactor coolant greater than 1 microCurie per gram DOSE EQUIVALENT I-131 for more than 48 hours during one continuous time interval or exceeding the limit line shown on Figure 3.4-1, be in at least HOT STANDBY with  $T_{avg}$  less than 500°F within 6 hours;
- b. With the gross specific activity of the reactor coolant greater than  $100/\bar{E}$  microCuries per gram of gross radioactivity, be in at least HOT STANDBY with  $T_{avg}$  less than 500°F within 6 hours; and
- c. The provisions of Specification 3.0.4 are not applicable.

\*With  $T_{avg}$  greater than or equal to 500°F.

## REACTOR COOLANT SYSTEM

### LIMITING CONDITION FOR OPERATION

---

#### ACTION (Continued)

MODES 1, 2, 3, 4, and 5:

With the specific activity of the reactor coolant greater than 1 microCurie per gram DOSE EQUIVALENT I-131 or greater than 100/E micro-curies per gram, perform the sampling and analysis requirements of Item 4.a) of Table 4.4-4 until the specific activity of the reactor coolant is restored to within its limits.

#### SURVEILLANCE REQUIREMENTS

---

4.4.8 The specific activity of the reactor coolant shall be determined to be within the limits by performance of the sampling and analysis program of Table 4.4-4.

## REACTOR COOLANT SYSTEM

### BASES

---

---

#### 3/4.4.7 CHEMISTRY

The limitations on Reactor Coolant System chemistry, ensure that corrosion of the Reactor Coolant System is minimized and reduces the potential for Reactor Coolant System leakage or failure due to stress corrosion. Maintaining the chemistry within the Steady-State Limits provides adequate corrosion protection to ensure the structural integrity of the Reactor Coolant System over the life of the plant. The associated effects of exceeding the oxygen, chloride, and fluoride limits are time and temperature dependent. Corrosion studies show that operation may be continued with contaminant concentration levels in excess of the Steady-State Limits, up to the Transient Limits, for the specified limited time intervals without having a significant effect on the structural integrity of the Reactor Coolant System. The time interval permitting continued operation within the restrictions of the Transient Limits provides time for taking corrective actions to restore the contaminant concentrations to within the Steady-State Limits.

The Surveillance Requirements provide adequate assurance that concentrations in excess of the limits will be detected in sufficient time to take corrective action.

#### 3/4.4.8 SPECIFIC ACTIVITY

The limitations on the specific activity of the reactor coolant ensure that the resulting 2-hour doses at the SITE BOUNDARY will not exceed an appropriately small fraction of Part 100 dose guideline values following a steam generator tube rupture accident in conjunction with an assumed steady-state primary-to-secondary steam generator leakage rate of 1.0 gpm. The values for the limits on specific activity represent limits based upon a parametric evaluation by the NRC of typical site locations. These values are conservative in that specific site parameters of the Catawba site, such as SITE BOUNDARY location and meteorological conditions, were not considered in this evaluation.

The ACTION statement permitting POWER OPERATION to continue for limited time periods with the reactor coolant's specific activity greater than 1.0 microCurie/gram DOSE EQUIVALENT I-131, but within the allowable limit shown on Figure 3.4-1, accommodates possible iodine spiking phenomenon which may occur following changes in THERMAL POWER.

## REACTOR COOLANT SYSTEM

### BASES

---

#### SPECIFIC ACTIVITY (Continued)

The sample analysis for determining the gross specific activity and  $\bar{E}$  can exclude the radioiodines because of the low reactor coolant limit of 1 microCurie/gram DOSE EQUIVALENT I-131, and because, if the limit is exceeded, the radioiodine level is to be determined every 4 hours. If the gross specific activity level and radioiodine level in the reactor coolant were at their limits, the radioiodine contribution would be approximately 1%. In a release of reactor coolant with a typical mixture of radioactivity, the actual radioiodine contribution would probably be about 20%. The exclusion of radionuclides with half-lives less than 10 minutes from these determinations has been made for several reasons. The first consideration is the difficulty to identify short-lived radionuclides in a sample that requires a significant time to collect, transport, and analyze. The second consideration is the predictable delay time between the postulated release of radioactivity from the reactor coolant to its release to the environment and transport to the SITE BOUNDARY, which is relatable to at least 30 minutes decay time. The choice of 10 minutes for the half-life cutoff was made because of the nuclear characteristics of the typical reactor coolant radioactivity. The radionuclides in the typical reactor coolant have half-lives of less than 4 minutes or half-lives of greater than 14 minutes, which allows a distinction between the radionuclides above and below a half-life of 10 minutes. For these reasons the radionuclides that are excluded from consideration are expected to decay to very low levels before they could be transported from the reactor coolant to the SITE BOUNDARY under any accident condition.

Based upon the above considerations for excluding certain radionuclides from the sample analysis, the allowable time of 2 hours between sample taking and completing the initial analysis is based upon a typical time necessary to perform the sampling, transport the sample, and perform the analysis of about 90 minutes. After 90 minutes, the gross count should be made in a reproducible geometry of sample and counter having reproducible beta or gamma self-shielding properties. The counter should be reset to a reproducible efficiency versus energy. It is not necessary to identify specific nuclides. The radiochemical determination of nuclides should be based on multiple counting of the sample with typical counting basis following sampling of less than 1 hour, about 2 hours, about 1 day, about 1 week, and about 1 month.

## ADMINISTRATIVE CONTROLS

### ANNUAL REPORTS <sup>1/</sup>

6.9.1.4 Annual Reports covering the activities of the unit as described below for the previous calendar year shall be submitted prior to March 1 of each year. The initial report shall be submitted prior to March 1 of the year following initial criticality.

6.9.1.5 Annual Reports shall include the activities of the unit as described below:

a. Personnel Exposures

Reports required on an annual basis shall include a tabulation on an annual basis of the number of station, utility, and other personnel (including contractors) receiving exposures greater than 100 mrem/yr and their associated man-rem exposure according to work and job functions <sup>2/</sup>, e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling. The dose assignments to various duty functions may be estimated based on pocket dosimeter, TLD, or film badge measurements. Small exposures totalling less than 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole-body dose received from external sources should be assigned to specific major work functions.

b. Primary Coolant Specific Activity

Reports required on an annual basis shall include the results of specific activity analysis in which the primary coolant exceeded the limits of Specification 3.4.8. The following information shall be included: 1) Reactor power history starting 48 hours prior to the first sample in which the limit was exceeded; 2) Results of the last isotopic analysis for radioiodine performed prior to exceeding the limit, results of analysis while limit was exceeded and results of one analysis after the radioiodine activity was reduced to less than limit. Each result should include date and time of sampling and the radioiodine concentrations; 3) Clean-up system flow history starting 48 hours prior to the first sample in which the limit was exceeded; 4) Graph of the I-131 concentration and one other radioiodine isotope concentration in microcuries per gram as a function of time for the duration of the specific activity above the steady-state level; and 5) The time duration when the specific activity of the primary coolant exceeded the radioiodine limit.

### ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT\*\*\*

6.9.1.6 Routine Annual Radiological Environmental Operating Reports covering the operation of the unit during the previous calendar year shall be submitted prior to May 1 of each year. The initial report shall be submitted prior to May 1 of the year following initial criticality.

<sup>1/</sup> A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station.  
<sup>2/</sup> This tabulation supplements the requirements of § 20.407 of 10 CFR Part 20.  
\*\*\*A single submittal may be made for a multiple unit station.

## ADMINISTRATIVE CONTROLS

### ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT (Continued)

The Annual Radiological Environmental Operating Reports shall include summaries, interpretations, and an analysis of trends of the results of the radiological environmental surveillance activities for the report period, including a comparison with preoperational studies, with operational controls as appropriate, and with previous environmental surveillance reports, and an assessment of the observed impacts of the plant operation on the environment. The reports shall also include the results of the land use census required by Specification 3.12.2.

The Annual Radiological Environmental Operating Reports shall include the results of analysis of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the Table and Figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted as soon as possible in a supplementary report.

The reports shall also include the following: a summary description of the Radiological Environmental Monitoring Program; at least two legible maps\* covering all sampling locations keyed to a table giving distances and directions from the centerline of one reactor; the results of licensee participation in the Interlaboratory Comparison Program, required by Specification 3.12.3; discussion of all deviations from the sampling schedule of Table 3.12-1; and discussion of all analyses in which the LLD required by Table 4.12-1 was not achievable.

### SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT\*\*

6.9.1.7 Routine Radioactive Effluent Release Reports covering the operation of the unit during the previous 6 months of operation shall be submitted within 60 days after January 1 and July 1 of each year. The period of the first report shall begin with the date of initial criticality. The Radioactive Effluent Release Reports shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit as outlined in Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," Revision 1, June 1974, with data summarized on a quarterly basis following the format of Appendix B thereof.

\*One map shall cover stations near the SITE BOUNDARY; a second shall include the more distant stations.

\*\*A single submittal may be made for a multiple unit station. The submittal should combine those sections that are common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

## ADMINISTRATIVE CONTROLS

### SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The Radioactive Effluent Release Report to be submitted within 60 days after January 1 of each year shall include an annual summary of hourly meteorological data collected over the previous year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distributions of wind speed, wind direction, and atmospheric stability.\* This same report shall include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit or station during the previous calendar year. This same report shall also include an assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY (Figures 5.1-3 and 5.1.4) during the report period. All assumptions used in making these assessments, i.e., specific activity, exposure time and location, shall be included in these reports. The meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents, as determined by sampling frequency and measurement, shall be used for determining the gaseous pathway doses. The assessment of radiation doses shall be performed in accordance with the methodology and parameters in the OFFSITE DOSE CALCULATION MANUAL (ODCM).

The Radioactive Effluent Release Report to be submitted 60 days after January 1 of each year shall also include an assessment of radiation doses to the likely most exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operation." Acceptable methods for calculating the dose contribution from liquid and gaseous effluents are given in Regulatory Guide 1.109, Rev. 1, October 1977.

The Radioactive Effluent Release Reports shall include the following information for each type of solid waste shipped offsite during the report period:

- a. Total Container volume, in cubic meters,
- b. Total Curie quantity (determined by measurement or estimate),
- c. Principal radionuclides (determined by measurement or estimate),
- d. Type of waste (e.g., dewatered spent resin, compacted dry waste, evaporator bottoms),
- e. Number of shipments, and
- f. Solidification agent or absorbent [e.g., cement or other approved agents (media)].

\*In lieu of submission with the first half year Radioactive Effluent Release Report, the licensee has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

## ADMINISTRATIVE CONTROLS

### SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (Continued)

The Radioactive Effluent Release Reports shall include a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Radioactive Effluent Release Reports shall include any changes made during the reporting period to the PROCESS CONTROL PROGRAM (PCP) and to the OFFSITE DOSE CALCULATION MANUAL (ODCM), as well as a listing of new locations for dose calculations and/or environmental monitoring identified by the land use census pursuant to Specification 3.12.2.

### MONTHLY OPERATING REPORTS

6.9.1.8 Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the PORVs or safety valves, shall be submitted on a monthly basis to the Director, Office of Resource Management, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, with a copy to the NRC Regional Office, no later than the 15th of each month following the calendar month covered by the report.

### RADIAL PEAKING FACTOR LIMIT REPORT

6.9.1.9 The  $W(z)$  functions for RAOC and Base Load operation and the value for  $APL^{ND}$  (as required) shall be provided to the Director, Nuclear Reactor Regulation, Attention: Chief, Core Performance Branch, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555 at least 60 days prior to cycle initial criticality. In the event that these values would be submitted at some other time during core life, it will be submitted 60 days prior to the date the values would become effective unless otherwise exempted by the Commission.

Any information needed to support  $W(z)$ ,  $W(z)_{BL}$  and  $APL^{ND}$  will be by request from the NRC and need not be included in this report.



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 25 TO FACILITY OPERATING LICENSE NPF-35  
AND AMENDMENT NO. 15 TO FACILITY OPERATING LICENSE NPF-52

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DUKE POWER COMPANY, ET AL.

INTRODUCTION

By letter dated December 13, 1985, Duke Power Company, et al., (the licensee) proposed changes to the Technical Specifications (TS) for Catawba Nuclear Station, Units 1 and 2 that would involve: (1) a revision to the reporting requirements related to primary coolant iodine spikes, and (2) the deletion of existing TS requirements to shutdown the facility if coolant iodine activity limits are exceeded for 800 hours in a 12-month period. The proposed changes are in accordance with NRC Generic Letter No. 85-19 dated September 27, 1985.

EVALUATION

Generic Letter 85-19, Reporting Requirements on Primary Coolant Iodine Spikes, is part of an ongoing effort to delete unnecessary reporting requirements. It has been determined that reporting requirements related to primary coolant specific activity levels, specifically iodine spikes, can be reduced from a short term report to an item to be included in the Annual Report.

It has also been determined that existing shutdown requirements based on exceeding the primary coolant iodine activity limits for an accumulated period of over 800 hours are no longer necessary. This is based on an improvement in the quality of nuclear fuel over the past 10 years and the fact that appropriate actions would be initiated long before approaching the limit as currently specified.

Generic Letter 85-19 reports these findings and presents model TS in Standard Technical Specification format which reflect these findings. The licensee has proposed amending the Catawba Units 1 and 2 TS to match the model TS presented. We find the revisions to the reporting requirements and the deletion of requirements to shutdown the facility if coolant iodine activity limits are exceeded for 800 hours in a 12 month period to be consistent with the Generic Letter and model TS and, therefore, to be acceptable.

ENVIRONMENTAL CONSIDERATION

The amendments involve a change in use of facility components located within the restricted area as defined in 10 CFR Part 20 and changes in requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that

may be released offsite and that there is no significant increase in individual or cumulative occupational exposures. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there have been no public comments on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR Section 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (51 FR 30565) on August 27, 1986, and consulted with the state of South Carolina. No public comments were received, and the state of South Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Kahtan Jabbour, PWR#4/DPWR-A  
Howard Gilpin, PSB/DPWR-A

Dated: April 1, 1987