

January 10, 1989

Docket Nos.: 50-413
and 50-414

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: ISSUANCE OF AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 52 TO FACILITY OPERATING LICENSE NPF-52 - CATAWBA
NUCLEAR STATION, UNITS 1 AND 2 (TACS 71029/71030)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 59 to Facility Operating License NPF-35 and Amendment No. 52 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TS) in response to your application dated October 6, 1988.

The amendments revise the TS to reflect a modification to the pumphouse pit level instrumentation of the Nuclear Service Water System.

A copy of the related safety evaluation supporting Amendment No. 59 to Facility Operating License NPF-35 and Amendment No. 52 to Facility Operating License NPF-52 is enclosed.

Notice of issuance of amendments will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Original Signed By:

Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 59 to NPF-35
2. Amendment No. 52 to NPF-52
3. Safety Evaluation

cc w/enclosures:
See next page

OFFICIAL RECORD COPY

LA:PDII-3 PM:PDII-3 PDII-3/DRPI/II
 MRood KJabbour:sw for DMatthews
 12/14/88 12/15/88 1/19/89

8901230432 890110
 PDR ADOCK 05000413
 F PDC

DFB
1/11
CP

Mr. H. B. Tucker
Duke Power Company

Catawba Nuclear Station

cc:
A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

North Carolina MPA-1
Suite 600
3100 Smoketree Ct.
P.O. Box 29513
Raleigh, North Carolina 27626-0513

S. S. Kilborn
Area Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corp.
MNC West Tower - Bay 239
P.O. Box 355
Pittsburgh, Pennsylvania 15230

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
100 Memorial Drive
Greer, South Carolina 29651

Mr. Michael Hirsch
Federal Emergency Management Agency
Office of the General Counsel
Room 840
500 C Street, S.W.
Washington, D. C. 20472

North Carolina Electric Membership
Corp.
3400 Sumner Boulevard
P.O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,
Inc.
P.O. Box 929
Laurens, South Carolina 29360

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Karen E. Long
Assistant Attorney General
N.C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Mr. Peter G. LeRoy
Nuclear Production Department
Duke Power Company
P.O. Box 33189
Charlotte, North Carolina 28241

DATED: January 10, 1989

AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NPF-35 - Catawba Nuclear Station, Unit 1
AMENDMENT NO. 52 TO FACILITY OPERATING LICENSE NPF-52 - Catawba Nuclear Station, Unit 2

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PD#II-3 R/F

Catawba R/F

S. Varga	14-E-4
G. Lainas	14-H-3
D. Matthews	14-H-25
M. Rood	14-H-25
K. Jabbour	14-H-25
OGC-WF	15-B-18
B. Grimes	9-A-2
E. Jordan	MNBB-3302
W. Jones	P-130A
T. Meek (8)	P1-137
ACRS (10)	
GPA/PA	17-F-2
ARM/LFMB	AR-2015
E. Butcher	11-F-23
D. Hagan	MNBB-3302
J. Craig	8-D-1
S. Newberry	7-E-12



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 59
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc., (licensees) dated October 6, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 59, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Lawrence P. Crocker signed for:

David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification Changes

Date of Issuance: January 10, 1989

OFFICIAL RECORD COPY

LA:PDII-3
MRood
12/14/88

PM:PDII-3
KJabbour:sw
12/15/88

PSB/DEST
JCraig
12/19/88

PSB/DEST
SNewberry
12/23/88

OGC
1/03/89
+188

D:PDII-3
DMatthews
1/19/88 89

[Handwritten signatures and initials: KNS, JCraig, SNewberry, APH, DMatthews]



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency, (licensees) dated October 6, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 52, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Lawrence P. Crocker signed for:

David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification Changes

Date of Issuance: January 10, 1989

OFFICIAL RECORD COPY

LA:PDII-3
MRood
12/14/88

PM:PDII-3
KJabbour:sw
12/15/88

FSB/DEST
Craig
12/19/88

FSB/DEST
Stewberry
12/27/88

OGC
1/03/89
1/1/88

D:PDII-3
DMatthews
1/9/88

APH *my*

ATTACHMENT TO LICENSE AMENDMENT NO. 59

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 52

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Amended Page

3/4 3-23

3/4 3-25

3/4 3-26a (new page)

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
14. Nuclear Service Water Operation (Continued)					
c. Loss-of-Offsite Power	3	2	2	1,2,3	15
d. Containment Spray	See Item 2. above for all Containment Spray initiating functions and requirements.				
e. Phase "B" Isolation	See Item 3.b. above for all Phase "B" Isolation initiating functions and requirements.				
f. Safety Injection	See Item 1. above for all Safety Injection initiating functions and requirements.				
g. Suction Transfer-Low Pit Level (Units 1 and 2)					
1) 1 Out of 2 Logic	2/pit	1(either pit)	1/pit	1,2,3,4	28*
2) 2 Out of 3 Logic**	3/pit	2/pit (either pit)	2/pit	1,2,3,4	29
15. Emergency Diesel Generator Operation (Diesel Building Ventilation Operation, Nuclear Service Water Operation)					
a. Manual Initiation	2	1	2	1,2,3,4	18
b. Automatic Actuation Logic and Actuation Relays	2	1	2	1,2,3,4	21
c. Loss-of-Offsite Power	3	2	2	1,2,3,4	15
d. Safety Injection	See Item 1. above for all Safety Injection initiating functions and requirements.				
16. Auxiliary Building Filtered Exhaust Operation					
a. Manual Initiation	2	1	2	1,2,3,4	18
b. Automatic Actuation Logic and Actuation Relays	2	1	2	1,2,3,4	21

CATAMBA - UNITS 1 & 2

3/4 3-23

Amendment No. 59 (Unit 1)
Amendment No. 52 (Unit 2)

TABLE 3.3-3 (Continued)

TABLE NOTATIONS

#Trip function may be blocked in this MODE below the P-11 (Pressurizer Pressure Interlock) setpoint.

##Trip function automatically blocked above P-11 and may be blocked below P-11 when Safety Injection on low steam line pressure is not blocked.

*The provisions of this Action Statement may be waived for up to 48 hours per pit to allow for the implementation of the modification to change the Nuclear Service Water swapover logic to a 2 out of 3 logic system.

**Applicable after implementation of the modification to install the 2 out of 3 logic system.

ACTION STATEMENTS

- ACTION 14 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1, provided the other channel is OPERABLE.
- ACTION 15 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed until performance of the next required ANALOG CHANNEL OPERATIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 16 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is met. One additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.
- ACTION 17 - With less than the Minimum Channels OPERABLE requirement, operation may continue provided the containment purge supply and exhaust valves are maintained closed.
- ACTION 18 - With the number of OPERABLE channels one less than the Minimum Channels OPERABLE requirement, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- ACTION 19 - With the number of OPERABLE channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour, and
 - b. The Minimum Channels OPERABLE requirement is met; however, one additional channel may be bypassed for up to 2 hours for surveillance testing of other channels per Specification 4.3.2.1.

TABLE 3.3-3 (Continued)

TABLE NOTATIONS

ACTION 29 - With the number of OPERABLE channels less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided one of the following applicable conditions is satisfied:

- a. With one channel inoperable, place the inoperable channel in the tripped condition within 4 hours and ensure the Minimum Channels OPERABLE requirement is met. One additional channel may be bypassed for up to 2 hours for surveillance testing of other channels per Specification 4.3.2.1; or
- b. With less than the Minimum Number of Channels OPERABLE align the Nuclear Service Water System for Standby Nuclear Service Water Pond recirculation within 4 hours, or be in at least HOT STANDBY within the next 6 hours, at least HOT SHUTDOWN within the following 6 hours, and at least COLD SHUTDOWN within the subsequent 24 hours.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 59 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 52 TO FACILITY OPERATING LICENSE NPF-52
DUKE POWER COMPANY, ET AL.
CATAWBA NUCLEAR STATION, UNITS 1 AND 2
DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated October 6, 1988, Duke Power Company, et al., (the licensee) proposed changes to the Catawba Units 1 and 2 nuclear service water (RN) system Technical Specification (TS) Table 3.3-3, Item 14.g., to reflect a proposed modification to the pumphouse pit level instrumentation of the RN System. The system is designed to supply cooling water to various heat loads in both the safety and non-safety portions of each unit. This modification would change the swapover logic of the RN system.

2.0 EVALUATION

There are currently four level transmitters per pit at the RN pumphouse. Two are safety-related and two are not safety-related. The modification will upgrade 1 out of the 2 non-safety level transmitters per pit to safety grade. This would accommodate a 2 out of 3 logic instead of the present 1 out of 2 logic. Past experience has shown that a single spurious failure to the "low" position of one level transmitter can initiate a swapover when there is an adequate water level in the RN pits. Inadvertently challenging the system with numerous valves changing position and starting all RN pumps is unnecessary and reduces the reliability of the system.

The failure mode of all the safety grade level transmitters is the same. They fail low on loss of power. This is desirable in order to realign suction from Lake Wylie to the Standby Nuclear Service Water Pond (SNSWP) which is the ultimate heat sink.

The amendments would also temporarily waive the requirements of the Action Statement for Item 14.g. in Table 3.3-3, for 48 hours per pit, on a one time basis in order to allow orderly implementation of this modification. During this time at least one RN pit will be available. The 48 hours is needed for implementation of the modification on each pit separately. During this period, the pit will be inoperable only from the standpoint of automatic realignment to the SNSWP from its normal supply if low level is sensed in the affected pit.

8901230443 890110
PDR ADOCK 05000413
F PDC

All necessary automatic functions would still occur in the opposite pit. The only automatic valve actuation which is activated by train specific pit level instrumentation is the loop cross-over isolation valves. Closure of these valves is only required in the event of design basis accident accompanied by a failure of a pit supply valve to open when an emergency diesel generator or nuclear service water pump is out-of-service for extended maintenance. All four diesel generators and nuclear service water pumps will be maintained in an operable status for the duration of the requested 48 hour period. Therefore, the RN system would be capable of performing its design function during any design basis event, including any concurrent postulated single failure, throughout the requested 48 hour period.

In a letter to Duke Power Company dated September 30, 1987, the NRC staff noted that this proposed modification would improve the overall reliability of the RN System.

Based on its review of the licensee's proposed TS changes, the staff concludes that they adequately address the staff's concerns regarding overall reliability improvement of the RN System. The modification has no adverse impact on safety and would not pose an undue risk to public health and safety. Therefore, it is acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

These amendments involve changes to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20 and changes in surveillance requirements. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational exposure. The NRC staff has made a determination that the amendments involve no significant hazards consideration, and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (53 FR 46143) on November 16, 1988. The Commission consulted with the state of South Carolina. No public comments were received, and the state of South Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will

not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: K. Jabbour, PDII-3/DRP-I/II

Dated: January 10, 1989