

June 24, 1988

Docket Nos. 50-413
50-414

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: ISSUANCE OF ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT
IMPACT - CATAWBA NUCLEAR STATION UNITS 1 AND 2 (TACs 67347/67348)

Enclosed for your information is a copy of an "Environmental Assessment and Finding of No Significant Impact" related to your April 1, 1988, request for amendments to the operating licenses for Catawba Nuclear Station, Units 1 and 2. The amendments would change Technical Specification 5.3.1 "Fuel Assemblies." The assessment has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

Enclosure:
As Stated

cc w/encl:
See next page

DISTRIBUTION:

Docket File
NRC PDR

Local PDR
PDII-3 Reading

S. Varga 14E-4

G. Lainas 14H-3

D. Matthews

M. Rood

E. Jordan MNBB 3302

B. Grimes 9A-2

ACRS (10) H-1016

GPA/PA 17F-2

CATAWBA PLANT FILE

OGC-WF 15B-18

K. Jabbour

PDII-3

MRood

06/16/88

PDII-3 *KNT*

KJabbour:sw

06/17/88

PDII-3

DMatthews

06/24/88

8807110538 880624
PDR ADDCK 05000413
P PDR

Mr. H. B. Tucker
Duke Power Company

Catawba Nuclear Station

cc:

A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

North Carolina Electric Membership
Corp.
3400 Sumner Boulevard
P.O. Box 27306
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Saluda River Electric Cooperative,
Inc.
P.O. Box 929
Laurens, South Carolina 29360

North Carolina MPA-1
Suite 600
3100 Smoketree Ct.
P.O. Box 29513
Raleigh, North Carolina 27626-0513

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

S. S. Kilborn
Area Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corp.
MNC West Tower - Bay 239
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

County Manager of York County
York County Courthouse
York South Carolina 29745

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

Karen E. Long
Assistant Attorney General
N.C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Piedmont Municipal Power Agency
100 Memorial Drive
Greer, South Carolina 29651

Spence Perry, Esquire
General Counsel
Federal Emergency Management Agency
Room 840
500 C Street
Washington, D. C. 20472

Mr. Michael Hirsch
Federal Emergency Management Agency
Office of the General Counsel
Room 840
500 C Street, S.W.
Washington, D. C. 20472

Brian P. Cassidy, Regional Counsel
Federal Emergency Management Agency,
Region I
J. W. McCormack POCH
Boston, Massachusetts 02109

DISTRIBUTION:
Docket File
PD II-3 Reading
MRood
KJabbour

June 29, 1988

DOCKET NOS. 50-413
50-414

MEMORANDUM FOR: Rules and Procedures Branch
Division of Rules and Records
Office of Administration

FROM: Office of Nuclear Reactor Regulation

SUBJECT: Catawba Nuclear Station, Units 1 and 2 (Duke Power Company, et al.)

One signed original of the *Federal Register* Notice identified below is enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies (5) of the Notice are enclosed for your use.

- Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s); Time for Submission of Views on Antitrust Matters.
- Notice of Consideration of Issuance of Amendment to Facility Operating License.
- Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- Notice of Availability of NRC Draft/Final Environmental Statement.
- Notice of Limited Work Authorization.
- Notice of Availability of Safety Evaluation Report.
- Notice of Issuance of Construction Permit(s).
- Notice of Issuance of Facility Operating License(s) or Amendment(s).
- Order.
- Exemption.
- Notice of Granting Exemption.
- Environmental Assessment.
- Notice of Preparation of Environmental Assessment.
- Other: _____

Office of Nuclear Reactor Regulation

Enclosure:
As stated

Contact: Marilee Rood
Phone: 21487

OFFICE	NRR:PDII-3						
SURNAME	MRood						
DATE	6/29/88						

UNITED STATES NUCLEAR REGULATORY COMMISSIONDUKE POWER COMPANY, ET AL.DOCKET NOS. 50-413 AND 50-414ENVIRONMENTAL ASSESSMENT AND FINDING OFNO SIGNIFICANT IMPACT

The United States Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License Nos. NPF-35 and NPF-52 issued to Duke Power Company, et al., (the licensee), for operation of the Catawba Nuclear Station, Units 1 and 2, located in York County, South Carolina.

ENVIRONMENTAL ASSESSMENTIdentification of Proposed Action:

The amendments would change Technical Specification (TS) 5.3.1 "Fuel Assemblies" to provide increased flexibility in the substitution of solid stainless steel rods and open water channels (i.e., vacancies) for fuel rods in reconstitutable fuel assemblies to be reinserted in the reactor core during a refueling outage. Presently, TS 5.3.1 requires that each fuel assembly contain 264 fuel rods clad with Zircaloy-4, except that limited substitutions of fuel rods with filler rods consisting of Zircaloy-4 or stainless steel, or by vacancies, may be made in peripheral fuel assemblies if justified by cycle-specific reload analyses. The revised TS 5.3.1 would require that each fuel assembly nominally contain 264 fuel rods clad with Zircaloy-4, except that substitutions of fuel rods by filler rods consisting of Zircaloy-4 or stainless steel, or by vacancies, may be made in fuel assemblies if justified by cycle-specific reload analyses using NRC-approved methodology. The proposed

8807110541 880624
PDR ADOCK 05000413
P PDR

revision would also state that should more than 30 rods in the core, or 10 rods in any assembly, be replaced per refueling, a special report describing the number of rods replaced would be submitted to the Commission pursuant to Specification 6.9.2 within 30 days after cycle startup.

The Need for the Proposed Action:

The proposed TS change which removes TS requirements concerning "limited substitutions" and "peripheral fuel assemblies" is needed to provide increased operational flexibility. Under the proposed change, limitations on fuel rod substitutions or omissions and limitations regarding core locations are those implicit in the justifying analyses required to be performed by the licensee for each fuel cycle using NRC-approved methodology to demonstrate that existing design limits and safety analyses criteria continue to be met. The proposed flexibility is intended to provide for improved fuel performance by permitting the timely removal of individual fuel rods which are found to be leaking during a refueling outage. The requirement for special reporting is proposed in response to the NRC's request to be informed in the event a significant deviation from past fuel performances should be observed during a refueling outage.

Environmental Impacts of the Proposed Action:

The purpose of the change is to provide for reductions in future occupational radiation exposure and plant radiological releases through improvements in the licensee's fuel performance program. The licensee's goal for fuel reliability improvement is that the cycle average steady-state Iodine-131 activity, corrected for tramp contribution and normalized to a

common purification rate, remain below 0.02 microcuries per gram. This corresponds to about 12 leaking fuel rods. The licensee's goal is to achieve one-half the present goal, or 0.01 microcuries per gram, by 1990 and beyond. This will be achieved, in part, by an action plan of outage inspections and reconstitution; if the I-131 activity exceeds 0.05 microcuries per gram anytime during the cycle, then all of the reconstitutable assemblies to be reinserted will be examined by special ultrasonic testing (UT) equipment for defects in individual failed rods and results used for reconstitution decisions. Fuel handling, UT, and reconstitution of failed assemblies of a reconstitutable top-nozzle design would be conducted in parallel during refueling outages. The licensee estimates the fuel improvement program will reduce the total station occupational dose by at least 5 to 10 percent. Radiological releases from the station during normal operation would also be significantly reduced because of improved fuel performance.

The Commission has completed its review of the proposed amendments to revise the TS. The revision does not result in any significant adverse change in the process for determining the adequacy for reload designs and plant operation. The licensee will continue to justify each cycle-specific reload by analyses using NRC-approved methodology in order to demonstrate that existing design and operating limits are met in advance of operation. Therefore, the proposed change does not increase the probability or consequences of accidents. As discussed above, no adverse changes are being made in the types or amounts of effluents that may be released offsite, and there is no significant increase in the allowable individual or cumulative occupational radiation exposure.

Accordingly, the Commission concludes that this proposed action would result in no significant adverse radiological environmental impact.

With regard to potential non-radiological impacts, the proposed change to the TS involves systems located within the restricted area as defined in 10 CFR Part 20. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, the Commission concludes that there are no significant non-radiological environmental impacts associated with the proposed amendment.

Alternative to the Proposed Action:

Since the Commission concluded that there are no significant environmental effects that would result from the proposed action, any alternatives with equal or greater environmental impacts need not be evaluated.

The principal alternative would be to deny the requested amendments. This would not reduce environmental impacts of plant operation and would result in reduced operational flexibility.

Alternative Use of Resources:

This action does not involve the use of resources not previously considered in the "Final Environmental Statement Related to the Operation of the Catawba Nuclear Station, Units 1 and 2," dated January 1983.

Agencies and Persons Consulted:

The NRC staff has reviewed the licensee's request and did not consult other agencies or persons.

FINDING OF NO SIGNIFICANT IMPACT

The Commission has determined not to prepare an environmental impact statement for the proposed license amendment.

Based upon the foregoing environmental assessment, we conclude that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the application for amendments dated April 1, 1988 and a previous application of February 5, 1988 which it replaced. Also see D. Hood's memorandum dated April 1, 1988, entitled "Summary of March 28, 1988 Meeting on TS Changes Regarding Use of Steel Rods and Open Water Channels in Reconstitutable Fuel Assemblies." These documents are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D.C., and at the York County Library, 138 East Black Street, Rock Hill, South Carolina 29730.

Dated at Rockville, Maryland, this 29th day of June 1988.

FOR THE NUCLEAR REGULATORY COMMISSION

David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

LA:PDII-3
MRood
6/16/88

KNJ
PM:PDII-3
KJabbour:sw
6/17/88

OGC/*W*
W
6/20/88

DM
D:PDII-3
DMatthews
6/24/88