Entergy

Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
Entergy Nuclear Indian Point 2, LLC
P. O. Box 249
Buchanan, NY 10511

October 23, 2001

NYSDEC - Division of Water
SPDES Compliance Information Section
Bureau of Watershed Compliance Programs
50 Wolf Road - Room 340
Albany, New York 12233-3506

Re: Monthly Discharge Monitoring Report
Permit #NY0234826
Entergy Buchanan Gas Turbine Site

Gentlemen:

Enclosed is the Discharge Monitoring Report (DMR) for the month of September 2001.

If you have any questions regarding this submission, please contact Mr. Thomas Teague of Entergy (914)734-5791.

Very truly yours,

Roger Keppel
Environmental Health & Safety Manager
Indian Point Station
Entergy Units 1 & 2

Enc.

/paa

IE25

PERMITTEE NAME/ADDRESS *(Include Facility Name/ Location (if Different)*
NAME CONSOLIDATED EDISON CO OF NY
ADDRESS BUCHANAN GAS TURBINE SITE
BROADWAY & BLEAKLEY AVE
BUCHANAN NY 10511
FACILITY
LOCATION BUCHANAN GAS TURBINE SITE
BUCHANAN NY 10511
ATTN: RAYMOND BURNS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

NY0234826 — PERMIT NUMBER
001 M — DISCHARGE NUMBER

MONITORING PERIOD

	YEAR	MO	DAY		YEAR	MO	DAY
FROM	01	09	01	TO	01	09	30

MINOR
(SUBR 03)
F - FINAL
STORMWATER RUNOFF TO G.W.

*** NO DISCHARGE [ ] ***
NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	QUANTITY OR LOADING UNITS	Quality or Concentration MINIMUM	Quality or Concentration AVERAGE	Quality or Concentration MAXIMUM	Quality or Concentration UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
FLOW RATE	SAMPLE MEASUREMENT	******	E 288000	(07)	******	******	******		0	1/30	ESTIMA
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	REPORT DAILY MX	GPD	******	******	******	**** ****		ONCE/ MONTH	INSTAN
OIL & GREASE	SAMPLE MEASUREMENT	******	******		******	******	1.0	(19)	0	1/30	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	15 DAILY MX	MG/L		ONCE/ MONTH	GRAB
TOLUENE	SAMPLE MEASUREMENT	******	******		******	******	<0.005	(19)	0	1/30	GRAB
34010 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.005 DAILY MX	MG/L		ONCE/ MONTH	GRAB
BENZENE	SAMPLE MEASUREMENT	******	******		******	******	~~<0.005~~ JJ <0.7	(28)	0	1/30	GRAB
34030 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.7 DAILY MX	UG/L		ONCE/ MONTH	GRAB
XYLENE	SAMPLE MEASUREMENT	******	******		******	******	<0.005	(19)	0	1/30	GRAB
81551 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.005 DAILY MX	MG/L		ONCE/ MONTH	GRAB
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
ROGER KEPPEL
E, H+S MANAGER
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Roger Keppel
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: AREA CODE 914 NUMBER 271-7353

DATE: YEAR 01 MO 10 DAY 23

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*
FLOW RATE IS ESTIMATED BASED ON MAXIMUM DISCHARGE FLOW DURING ANY 24 HOUR PERIOD.