

November 30, 1990

Docket Nos. 50-413
and 50-414

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: ISSUANCE OF AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NPF-52 - CATAWBA
NUCLEAR STATION, UNITS 1 AND 2 (TACS 76451/76452)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 82 to Facility Operating License NPF-35 and Amendment No. 76 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 13, 1990.

The amendments modify TSs 3.1.2.5a., 3.1.2.5b. and 3.1.2.6a. and their associated Bases to revise the required volumes for the Boric Acid Tank and the Refueling Water Storage Tank.

A copy of the related Safety Evaluation supporting the amendments is also enclosed. Notice of issuance of the amendments will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

Kahtan N. Jabbour, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 82 to NPF-35
- 2. Amendment No. 76 to NPF-52
- 3. Safety Evaluation

cc w/enclosures:
See next page

OFFICIAL RECORD COPY
Document Name: CATAWBA AMEND BAT RWST

| | | | |
|---------------------------------|-----------------------------------|----------------------|--|
| LA:PDII-3 RIngram 10/9/90 | PM:PDII-3 KJabbour: 10/9/90 | OGC Eh 11/8/90 | PDII-3/DRPI/II DMatthews 11/9/90 |
|---------------------------------|-----------------------------------|----------------------|--|

9012110167 901130
PDR ADOCK 05000413
PDC

[Handwritten signatures and initials]
 QF01
 111
 e/p-1
 [Signature]

Mr. H. B. Tucker
Duke Power Company

cc:

A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Bishop, Cook, Purcell and Reynolds
1400 L Street, N.W.
Washington, D. C. 20005

North Carolina MPA-1
Suite 600
3100 Smoketree Ct.
P.O. Box 29513
Raleigh, North Carolina 27626-0513

Ms. S. S. Kilborn
Area Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corp.
MNC West Tower - Bay 239
P.O. Box 355
Pittsburgh, Pennsylvania 15230

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Catawba Nuclear Station

North Carolina Electric Membership
Corp.
3400 Sumner Boulevard
P.O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,
Inc.
P.O. Box 929
Laurens, South Carolina 29360

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Ms. Karen E. Long
Assistant Attorney General
N.C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Mr. Robert G. Morgan
Nuclear Production Department
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY
NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION
SALUDA RIVER ELECTRIC COOPERATIVE, INC.
DOCKET NO. 50-413
CATAWBA NUCLEAR STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 82
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees) dated March 13, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9012110169 901130
PDR ADOCK 05000413
P PIC

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 82 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification Changes

Date of Issuance: November 30, 1990



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY
NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1
PIEDMONT MUNICIPAL POWER AGENCY
DOCKET NO. 50-414
CATAWBA NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 76
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees) dated March 13, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 76, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification Changes

Date of Issuance: November 30, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 82

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 76

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

3/4 1-11
3/4 1-12
B 3/4 1-3
-
-

Insert Pages

3/4 1-11
3/4 1-12
B 3/4 1-3
B 3/4 1-3a
B 3/4 1-3b

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCE - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A Boric Acid Storage System with:
 - 1) A minimum contained borated water volume of 12,000 gallons,
 - 2) A minimum boron concentration of 7000 ppm, and
 - 3) A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1) A minimum contained borated water volume of 45,000 gallons,
 - 2) A minimum boron concentration of 2000 ppm, and
 - 3) A minimum solution temperature of 70°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.

SURVEILLANCE REQUIREMENTS

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1) Verifying the boron concentration of the water,
 - 2) Verifying the contained borated water volume, and
 - 3) Verifying the boric acid storage tank solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the refueling water storage tank temperature when it is the source of borated water and the outside air temperature is less than 70°F.

REACTIVITY CONTROL SYSTEMS

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2:

- a. A Boric Acid Storage System with:
 - 1) A minimum contained borated water volume of 22,000 gallons,
 - 2) A minimum boron concentration of 7000 ppm, and
 - 3) A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1) A contained borated water volume of at least 363,513 gallons,
 - 2) A minimum boron concentration of 2000 ppm,
 - 3) A minimum solution temperature of 70°F, and
 - 4) A maximum solution temperature of 100°F.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With the Boric Acid Storage System inoperable and being used as one of the above required borated water sources, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least 1% $\Delta k/k$ at 200°F; restore the Boric Acid Storage System to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

REACTIVITY CONTROL SYSTEMS

BASES

BORATION SYSTEMS (Continued)

MARGIN from expected operating conditions of 1.3% $\Delta k/k$ after xenon decay and cooldown to 200°F. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires 9,851 gallons of 7000 ppm borated water from the boric acid storage tanks or 57,107 gallons of 2000 ppm borated water from the refueling water storage tank.

The Technical Specification requires 22,000 gallons of 7000 ppm borated water from the boric acid tanks to be available in Modes 1-4. This volume is based on the required volume for maintaining shutdown margin, unusable volume (to allow for a full suction pipe), instrument error, and additional margin to account for different cores and conservatism as follows:

Modes 1-4 Boric Acid Tank

| | |
|--|-----------------------|
| Required volume for maintaining SDM | 9,851 gallons |
| 5% Additional Margin | 496 gallons |
| Unusable Volume (to maintain full suction pipe) | 7,230 gallons |
| 14" of water equivalent | |
| Vortexing (4" of water above top of suction pipe) | 2,066 gallons |
| Instrumentation Error (Based on Total Loop Acc. for 1&2 NV5740 loops) - 2" of water equivalent | 1,550 gallons |
| | <u>21,193 gallons</u> |

This value is increased to 22,000 gallons for additional margin.

A similar approach is taken for calculating the required Refueling Water Storage Tank volume:

When the temperature of one or more cold legs drops below 285°F in Mode 4, the potential for low temperature overpressurization of the reactor vessel makes it necessary to render one charging pump INOPERABLE and at least one safety injection pump INOPERABLE. The limitation for a maximum of one centrifugal charging pump to be OPERABLE and the Surveillance Requirement to verify all charging pumps except the required OPERABLE pump to be inoperable below 285°F provides assurance that a mass addition pressure transient can be relieved by the operation of a single PORV.

Refueling Water Storage Tank Requirements For Maintaining SDM - Modes 1-4

| | |
|-------------------------------------|-----------------------|
| Required Volume for Maintaining SDM | 57,107 gallons |
| Unusable Volume (below nozzle) | 13,442 gallons |
| Instrument Inaccuracy | 11,307 gallons |
| Vortexing | <u>13,247 gallons</u> |
| | 95,103 gallons |

The Technical Specification Volume 363,513 gallons was determined by correcting the tank's low level setpoint (level at which makeup is added to

REACTIVITY CONTROL SYSTEMS

BASES

BORATION SYSTEMS (Continued)

tank) for instrument inaccuracy. This level provides the maximum available volume to account for shutdown margin, worst case single failure, adequate containment sump volume for transfer to recirculation, and sufficient volume above the switchover initiation level such that no operator action is required prior to ten minutes after the initiation of the accident.

With the coolant temperature below 200°F, one Boron Injection flow path is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity changes in the event the single Boron Injection flow path becomes inoperable.

The boron capability required below 200°F is sufficient to provide a SHUTDOWN MARGIN of 1% $\Delta k/k$ after xenon decay and cooldown from 200°F to 140°F. This condition requires either 585 gallons of 7000 ppm borated water from the boric acid storage tanks or 3500 gallons of 2000 ppm borated water from the refueling water storage tank.

The Boric Acid Tank and Refueling Water Storage Tank volumes required in Modes 5-6 to provide necessary SDM are based on the following inputs as discussed previously:

Boric Acid Tank

| | |
|---|-------------------|
| Required Volume for maintaining SDM | 585 gallons |
| Unusable Volume, Vortexing, Inst. Error | 10,846 gallons |
| 5% additional margin | <u>33 gallons</u> |
| | 11,464 gallons |

This value is increased to the Technical Specification value of 12,000 gallons for additional margin.

Refueling Water Storage Tank

| | |
|-------------------------------------|-----------------------|
| Required Volume for Maintaining SDM | 3,500 gallons |
| Water Below the Nozzle | 13,442 gallons |
| Instrument Inaccuracy | 11,307 gallons |
| Vortexing | <u>13,247 gallons</u> |
| | 41,496 gallons |

This value is increased to the Technical Specification value of 45,000 gallons for additional margin.

The contained water volume limits include allowance for water not available because of discharge line location and other physical characteristics.

REACTIVITY CONTROL SYSTEMS

BASES

BORATION SYSTEMS (Continued)

The limits on contained water volume and boron concentration of the refueling water storage tank also ensure a pH value of between 8 and 9 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

The OPERABILITY of one Boron Injection System during REFUELING ensures that this system is available for reactivity control while in MODE 6.

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

The specifications of this section ensure that: (1) acceptable power distribution limits are maintained, (2) the minimum SHUTDOWN MARGIN is maintained, and (3) the potential effects of rod misalignment on associated accident analyses are limited. OPERABILITY of the control rod position indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits. Verification that the Digital Rod Position Indicator agrees with the demanded position within ± 12 steps at 24, 48, and 120 steps and fully withdrawn (≥ 225 steps) for the Control Banks and 18 and 210 steps and fully withdrawn for the Shutdown Banks provides assurances that the Digital Rod Position Indicator is operating correctly over the full range of indication. Since the Digital Rod Position System does not indicate the actual shutdown rod position between 18 steps and 210 steps, only points in the indicated ranges are picked for verification of agreement with demanded position.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NPF-52
DUKE POWER COMPANY, ET AL.
CATAWBA NUCLEAR STATION, UNITS 1 AND 2
DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated March 13, 1990, Duke Power Company, et al. (the licensee) proposed changes to the Catawba Nuclear Station, Units 1 and 2, Technical Specifications (TSs) 3.1.2.5 and 3.1.2.6 and associated Bases to revise the required volumes for the Boric Acid Tank (BAT) and Refueling Water Storage Tank (RWST). In the current TSs, the unusable tank volumes are not taken into account as is assumed in their associated Bases 3/4.1.2, "Boration Systems." Hence, the current TS calculations do not accurately reflect the volumes necessary for the tanks to perform their required safety function.

The inaccuracy of the current TSs was discovered during the review of a plant modification for necessary procedure changes. Following the discovery, a Duke Power Problem Investigation Report was initiated and a calculation was done to determine the necessary required volumes to meet the TS Bases for the BAT and RWST.

As part of the problem resolution, the design bases requirements for the BAT and RWST volume levels were researched and reconstructed based on the required safety function of the tanks.

2.0 EVALUATION

The licensee proposed to change the current volumes required of the BAT in Modes 1 to 6 (power operation, startup, hot standby, hot shutdown, cold shutdown and refueling) and the RWST in Modes 5 and 6 in order to account for the unusable volume due to discharge line location and other physical characteristics associated with the tanks. The volume required for RWST in Modes 1 to 4 will not change as the existing level provides the maximum available volume to account for shutdown margin, worst case single failure, adequate containment sump volume for transfer to sump recirculation, and sufficient volume above the switchover initiation level such that no operator action is required prior to ten minutes after the initiation of the accident.

The design bases requirements for BAT and RWST were researched and reconstructed based on the required safety function of the tanks. The BAT is designed to store sufficient boric acid for a cold shutdown from full power operation immediately following refueling with the most reactive control rod not inserted, plus operating margins (Final Safety Analysis Report (FSAR) Section 9.3.4).

9012110170 901130
PDR ADOCK 05000413
PDC

Additionally, conditions at cold shutdown require the reactor to be shutdown by at least 1.0 percent delta k/k (FSAR Section 15.4). The RWST is required to provide a source of borated water at refueling water boron concentration for use during refueling or a postulated loss-of-coolant accident (LOCA). The RWST must contain enough inventory to bring the reactor to safe shutdown through all six modes of operation (FSAR Section 9.2.7). The design bases volumes for these tanks account for tank specific characteristics.

The existing tank volumes required by the TSs for the BAT and RWST do not meet the design bases and are not conservative because they do not account for unusable tank volumes. The proposed changes to the TSs will meet the design bases requirements and correct the volumes required for BAT and RWST to account for unusable tank volumes. The changes require that the BAT and the RWST be maintained at levels which will allow them to perform their required safety function. The proposed changes also make the specifications consistent with the supporting analyses and Bases.

Based on its review, the NRC staff concludes that the proposed TS revision for Catawba Units 1 and 2 has no adverse impact on safety and does not pose an undue risk to public health and safety and is, therefore, acceptable.

3.0 ENVIRONMENTAL CONSIDERATION

These amendments involve changes to the requirements with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

4.0 CONCLUSION

The Commission's proposed determination that the amendments involve no significant hazards consideration was published in the Federal Register (55 FR 34366) on August 22, 1990. The Commission has consulted with the State of South Carolina. No public comments were received, and the State of South Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will

be conducted in compliance with the Commission's regulations, and issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: K. Jabbour, PDII-3/DRP-I/II
A. Massey, SRXB/DST

Dated: November 30, 1990

DATED: November 30, 1990

AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NPF-35 - Catawba Nuclear Station, Unit 1
AMENDMENT NO. 76 TO FACILITY OPERATING LICENSE NPF-52 - Catawba Nuclear Station, Unit 2

DISTRIBUTION:

Docket File

| | |
|-------------|-----------|
| NRC PDR | |
| Local PDR | |
| PD II-3 R/F | |
| Catawba R/F | |
| S. Varga | 14-E-4 |
| G. Lainas | 14-H-3 |
| D. Matthews | 9-H-3 |
| R. Ingram | 9-H-3 |
| K. Jabbour | 9-H-3 |
| OGC-WF | 15-B-18 |
| D. Hagan | MNBB 4702 |
| E. Jordan | MNBB-3701 |
| G. Hill (8) | P1-37 |
| W. Jones | MNBB 7103 |
| J. Calvo | 11-F-22 |
| ACRS (10) | P-135 |
| GPA/PA | 17-F-2 |
| OC/LFMB | MNBB 4702 |