

MEMORANDUM FOR: Sholly Coordinator

DISTRIBUTION

FROM: Robert E. Martin, Senior Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II

Docket File OGC  
NRC/LOCAL PDRs Sholly Coord  
LBerry  
RMartin  
DMatthews

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE  
OF ISSUANCE OF AMENDMENTS TO FACILITY OPERATING LICENSES  
(TACS M81287 AND M81288)

Duke Power Company, et al., Docket Nos. 50-413 and 50-414, Catawba Nuclear  
Station, Units 1 and 2, York County, South Carolina

Date of application for amendments: August 6, 1991

Brief description of amendments: The amendments revise the maximum allowable  
combined flowrates for both reactor makeup water pumps for MODES 3-5 with one  
or both trains of the Boron Dilution Mitigation System inoperable. A restriction  
is also added for MODE 6 and certain administrative changes are also made.

Date of issuance: March 3, 1992

Effective date: March 3, 1992

Amendment Nos.: 94 and 88

Facility Operating License Nos. NPF-35 and NPF-52: Amendments revised the  
Technical Specifications.

Date of initial notice in FEDERAL REGISTER: December 26, 1991 (56 FR 66919)

The Commission's related evaluation of the amendments is contained in a Safety  
Evaluation dated March 3, 1992.

No significant hazards consideration comments received: No.

Local Public Document Room location: York County Library, 138 East Black  
Street, Rock Hill, South Carolina 29730

ORIGINAL SIGNED BY:

Robert E. Martin, Senior Project Manager  
Project Directorate II-3  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

CP-1

9203100248 920303  
PDR ADDCK 05000413  
P PDR

OFC	: PDII-3/LA	: PDII-3/PM	: PDII-3/D	:
NAME	: LBerry	: RMartin	: DMatthews	:
DATE	: 02/ 3 192	: 02/ 4 192	: 02/ 3 192	:

OFFICIAL RECORD COPY  
090032

Document Name: CATAWBA SHOLLY AMD

DF01 1/0