

January 12, 1993

Docket Nos. 50-413
and 50-414

Distribution
See next page

Mr. M. S. Tuckman
Vice President, Catawba Site
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Dear Mr. Tuckman:

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2
(TAC NOS. M84329 AND M84330)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 105 to Facility Operating License NPF-35 and Amendment No. 99 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated July 27, 1992.

The amendments revise the minimum channels operable requirement of TS Table 3.3-10, Item 17, Steam Relief Valve Exhaust Radiation Monitor from "1" to "1/Steam Line."

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/s/

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 105 to NPF-35
2. Amendment No. 99 to NPF-52
3. Safety Evaluation

cc w/enclosures:
See next page

OFC : PDII-3/LA : PDII-3/PM : OGC : BC:ICSB : PDII-3/D
NAME : LBERRY : RMARTIN : cw: : SNEWBERRY : DMATTHEWS :
DATE : 12/10/92 : 12/10/92 : 1/9/93 : 12/20/92 : 1/12/93 :
RBachmann

OFFICIAL RECORD COPY

Document Name: G:\CATAWBA\84329.AMD

9302010050 930112
PDR ADDCK 05000413
P PDR

Defol
CP-1
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 12, 1993

Docket Nos. 50-413
and 50-414

Mr. M. S. Tuckman
Vice President, Catawba Site
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Dear Mr. Tuckman:

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2
(TAC NOS. M84329 AND M84330)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 105 to Facility Operating License NPF-35 and Amendment No. 99 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated July 27, 1992.

The amendments revise the minimum channels operable requirement of TS Table 3.3-10, Item 17, Steam Relief Valve Exhaust Radiation Monitor from "1" to "1/Steam Line."

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "Robert E. Martin".

Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 105 to NPF-35
2. Amendment No. 99 to NPF-52
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. M. S. Tuckman
Duke Power Company

Catawba Nuclear Station

cc:

Mr. R. C. Futrell
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Mr. Alan R. Herdt, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Mr. A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Senior Resident Inspector
Route 2, Box 179 N
York, South Carolina 29745

North Carolina MPA-1
Suite 600
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Mr. T. Richard Puryear
Nuclear Technical Services
Manager
Carolinas District
Westinghouse Electric Corporation
P. O. Box 32817
Charlotte, North Carolina 28232

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 27602

County Manager of York County
York County Courthouse
York, South Carolina 29745

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P. O. Box 1006
Charlotte, North Carolina 28201-1006

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 11549
Columbia, South Carolina 29211

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

DATED: January 12, 1993

AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NPF-35 - Catawba Nuclear Station, Unit 1

AMENDMENT NO. 99 TO FACILITY OPERATING LICENSE NPF-52 - Catawba Nuclear Station, Unit 2

DISTRIBUTION:

~~Docket File~~

NRC & Local PDRs

PD II-3 R/F

Catawba R/F

S. Varga 14-E-4

G. Lainas 14-H-3

D. Matthews 14-H-25

L. Berry 14-H-25

R. Martin 14-H-25

OGC-WF 15-B-18

D. Hagan MNBB 4702

G. Hill (8) P1-22

W. Jones MNBB 7103

C. Grimes 11-F-23

ACRS (10) P-135

PA 2-G-5

OC/LFMB MNBB 4702

E. Merschoff RII

S. Newberry 8H7

270107



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 105
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees) dated July 27, 1992 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 105, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: January 12, 1993



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY
NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1
PIEDMONT MUNICIPAL POWER AGENCY
DOCKET NO. 50-414
CATAWBA NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 99
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees) dated July 27, 1992 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 99 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: January 12, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 105

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 99

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove Page

3/4 3-67

Insert Page

3/4 3-67

TABLE 3.3-10 (Continued)
ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>
15. In Core Thermocouples	4/core quadrant	2/core quadrant
16. Unit Vent - High-High Range Area Monitor (EMF-54)	N.A.	1
17. Steam Relief Valve Exhaust Radiation Monitor (1EMF-26, 27, 28 and 29 and 2EMF-10, 11, 12 and 13)	N.A.	1/Steam Line
18. Containment Area - High Range Radiation Monitor (EMF-53 A or B)	N.A.	1
19. Reactor Vessel Water Level	2	1
20. Reactor Coolant Radiation Level (EMF-48)	N.A.	1

TABLE NOTATIONS

* Not applicable if the associated block valve is in the closed position.

** Not applicable if the associated block valve is in the closed position and power is removed.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 105 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 99 TO FACILITY OPERATING LICENSE NPF-52

DUKE POWER COMPANY, ET AL.

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated July 27, 1992, the Duke Power Company, et al. (the licensee), submitted a request for changes to the Catawba Nuclear Station, Units 1 and 2, Technical Specifications (TS). The requested changes revise the minimum channels operable requirement of TS Table 3.3-10, Item 17, Steam Relief Valve Exhaust Radiation Monitors, from one to one per each of the four steam lines.

2.0 EVALUATION

As noted in the application, an area radiation monitor is located adjacent to each of the four main steam lines (MSL) upstream of the main steam isolation valves, to detect secondary radiation releases. The previously existing TS required that a minimum of one channel of these monitors must be operable. The licensee has previously relied on the steam generator water sample monitor (EMF-34) as a backup for the MSL monitors. However, due to continuous operability problems cited by the licensee with EMF-34, its design basis is being changed. This also results in removal of the backup function provided by EMF-34 to the MSL monitors.

In response, the licensee proposes to change the TS such that all four MSL monitors are subject to the minimum operable channels requirement. This change is (1) more conservative than the previous TS requirement, (2) consistent with the licensee's commitment made in response to Regulatory Guide 1.97 in Table 1-11 of the Final Safety Analysis Report, and (3) consistent with the standard technical specifications for Westinghouse reactors. Based on the above, the staff finds the change from requiring one MSL monitor to be operable to requiring one for each of the four steam lines to be operable is acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the South Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (57 FR 58245, dated December 9, 1992). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Robert E. Martin

Date: January 12, 1993