



50-413

UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0801

August 31, 1995

Mr. William R. McCollum
Vice President, Catawba Site
Duke Power Company
4800 Concord Road
York, SC 29745

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2
FUEL POOL ENRICHMENT AND BORON CONCENTRATION LIMITS
(TAC NOS. M90447 AND M90448)

Dear Mr. McCollum:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 134 to Facility Operating License NPF-35 and Amendment No. 128 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated September 19, 1994, as supplemented April 26 and June 19, 1995. The June 19, 1995, letter provided clarifying information that did not change the scope of the September 19, 1994, application and initial proposed no significant hazards consideration determination.

The amendments revise the Technical Specifications to increase the enrichment limits for fuel stored in the fuel pools and establish restricted loading patterns and associated burnup criteria for qualifying fuel in the spent fuel pools. In addition, several administrative changes have been included in order to provide clarity to the TS and bring them more in line with the Standard Technical Specifications format. These changes are as follows: (1) The TS index is changed to add TS 3/4.9.12 and 3/4.9.13, Tables 3.9-1 and 3.9-2 and Figure 3.9-1; (2) TS 3/4.9.12, Spent Fuel Pool (SFP) Boron Concentration is added to establish a boron concentration limit and to establish a Limiting Condition for Operation (LCO) for all modes of operation and to allow the numerical value of the limit to be specified in the Core Operating Limits Report (COLR); (3) TS 3/4.9.13, Tables 3.9-1 and 3.9-2 and Figure 3.9-1 are being added to establish restricted loading patterns for spent fuel storage and associated burnup criteria; (4) Corresponding BASES for TS 3/4.9.12 and 3/4.9.13 are added to explain the basis for each LCO, Action Statement and Surveillance Requirement covered by the subject TS; (5) TS 5.6, Fuel Storage, is changed to reflect limits for criticality analysis for fuel storage; and (6) TS 6.9, Reporting Requirements, is changed to reflect the inclusion of the SFP boron concentration limit values in the COLR as established by TS 3/4.9.12.

9509110097 950831
PDR ADOCK 05000413
P PDR

NRC FILE CENTER COPY

DFC
9/1

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

Robert E. Martin, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 134 to NPF-35
2. Amendment No. 128 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

Distribution

Docket File	L.Kopp, 0-8 E23
PUBLIC	G.Hill(4) T-5 C3
PDII-2 Reading	C.Grimes 0-11 F23
S.Varga	ACRS(4) T-2 E26
PA 0-17 F2	R.Crlenjak, RII
OG/LFDCB T-9 E10	OGC, 0-15 B18
E.Merschhoff, RII	

DOCUMENT NAME: G:\CATAWBA\CAT90447.AMD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD22:DRPE	E	PM:PD22:DRPE	E	OGC	D:PD22:DRPE	
NAME	LBerry		RMartin:dt			HBerkow	
DATE	8/8/95		8/15/95		8/15/95	8/22/95	

OFFICIAL RECORD COPY

000000

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Robert E. Martin

Robert E. Martin, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 134 to NPF-35
2. Amendment No. 128 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

Mr. W. R. McCollum
Duke Power Company

cc:

Mr. Z. L. Taylor
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Dayne H. Brown, Director
Division of Radiation Protection
N.C. Department of Environment,
Health and Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Catawba Nuclear Station

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
4830 Concord Road
York, South Carolina 29745

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 134
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation, and Saluda River Electric Cooperative, Inc. (licensees), dated September 19, 1994, as supplemented April 26 and June 19, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 134 , and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: August 31, 1995



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 128
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees), dated September 19, 1994, as supplemented April 26 and June 19, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 128, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: August 31, 1995

ATTACHMENT TO LICENSE AMENDMENT NO.134

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 128

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

XI

-

-

-

-

-

-

-

5-7

6-19

6-19a

Insert Pages

XI

3/4 9-17

3/4 9-18

3/4 9-19

3/4 9-20

3/4 9-21

B 3/4 9-4

B 3/4 9-5

5-7

6-19

6-19a

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
3/4.9.8	RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION
	High Water Level..... 3/4 9-10
	Low Water Level..... 3/4 9-11
3/4.9.9	WATER LEVEL - REACTOR VESSEL..... 3/4 9-12
3/4.9.10	WATER LEVEL - STORAGE POOL 3/4 9-13
3/4.9.11	FUEL HANDLING VENTILATION EXHAUST SYSTEM..... 3/4 9-14
3/4.9.12	SPENT FUEL POOL BORON CONCENTRATION..... 3/4 9-17
3/4.9.13	SPENT FUEL ASSEMBLY STORAGE..... 3/4 9-18
Table 3.9-1	MINIMUM QUALIFYING BURNUP Vs. INITIAL ENRICHMENT FOR UNRESTRICTED STORAGE..... 3/4 9-19
Table 3.9-2	MINIMUM QUALIFYING BURNUP Vs. INITIAL ENRICHMENT FOR FILLER ASSEMBLIES..... 3/4 9-20
Figure 3.9-1	REQUIRED 3 OUT OF 4 LOADING PATTERN FOR RESTRICTED STORAGE..... 3/4 9-21

3/4.10 SPECIAL TEST EXCEPTIONS

3/4.10.1	SHUTDOWN MARGIN..... 3/4 10-1
3/4.10.2	GROUP HEIGHT, INSERTION, AND POWER DISTRIBUTION LIMITS..... 3/4 10-2
3/4.10.3	PHYSICS TESTS..... 3/4 10-3
3/4.10.4	REACTOR COOLANT LOOPS..... 3/4 10-4
3/4.10.5	POSITION INDICATION SYSTEM - SHUTDOWN..... 3/4 10-5

3/4.11 RADIOACTIVE EFFLUENTS

3/4.11.1	LIQUID EFFLUENTS
	Liquid Holdup Tanks..... 3/4 11-1
3/4.11.2	GASEOUS EFFLUENTS
	Explosive Gas Mixture..... 3/4 11-2
	Gas Storage Tanks..... 3/4 11-3

REFUELING OPERATIONS

3/4.9.12 SPENT FUEL POOL BORON CONCENTRATION

LIMITING CONDITION FOR OPERATION

3.9.12 The boron concentration in the spent fuel pool shall be within the limit specified in the COLR.

APPLICABILITY:

During storage of fuel in the spent fuel pool.

ACTION:

- a. Immediately suspend movement of fuel assemblies in the spent fuel pool and initiate action to restore the spent fuel pool boron concentration to within its limit.
- b. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.12 Verify at least once per 7 days that the spent fuel pool boron concentration is within its limit.

REFUELING OPERATIONS

3/4.9.13 SPENT FUEL ASSEMBLY STORAGE

LIMITING CONDITION FOR OPERATION

3.9.13 New or irradiated fuel may be stored in the Spent Fuel Pool in accordance with these limits:

- a. Unrestricted storage of fuel meeting the criteria of Table 3.9-1; or
- b. Restricted storage in accordance with Figure 3.9-1, of fuel which does not meet the criteria of Table 3.9-1.

APPLICABILITY:

During storage of fuel in the spent fuel pool.

ACTION:

- a. Immediately initiate action to move the noncomplying fuel assembly to the correct location.
- b. The provisions of Specification 3.0.3 are not applicable.


SURVEILLANCE REQUIREMENTS

4.9.13 Prior to storing a fuel assembly in the spent fuel storage pool, verify by administrative means the initial enrichment and burnup of the fuel assembly are in accordance with Specification 3.9.13.

Table 3.9-1

Minimum Qualifying Burnup Versus Initial Enrichment
for Unrestricted Storage

<u>Initial Nominal Enrichment</u> <u>(Weight% U-235)</u>	<u>Assembly Burnup</u> <u>(GWD/MTU)</u>
4.05 (or less)	0
4.50	2.73
5.00	5.67




Fuel which differs from those designs used to determine the requirements of Table 3.9-1 may be qualified for Unrestricted storage by means of an analysis using NRC approved methodology to assure that k_{eff} is less than or equal to 0.95.

Likewise, previously unanalyzed fuel up to 5.0 weight% U-235 may be qualified for Restricted storage by means of an analysis using NRC approved methodology to assure that k_{eff} is less than or equal to 0.95.

Table 3.9-2


Minimum Qualifying Burnup Versus Initial Enrichment
for Filler Assemblies

<u>Initial Nominal Enrichment (Weight% U-235)</u>	<u>Assembly Burnup (GWD/MTU)</u>
1.90 (or less)	0
2.00	16.83
2.50	26.05
3.00	35.11
3.50	43.48
4.00	51.99
4.48	60.00



Fuel which differs from those designs used to determine the requirements of Table 3.9-2 may be qualified for use as a Filler Assembly by means of an analysis using NRC approved methodology to assure that k_{eff} is less than or equal to 0.95.

Figure 3.9-1
Required 3 out of 4 Loading Pattern
for Restricted Storage



Restricted Fuel: Fuel defined for Restricted Storage in Table 3.9-1. (Fuel defined for Unrestricted Storage in Table 3.9-1, or non-fuel components, or an empty location may be placed in restricted fuel locations as needed)

Filler Location: Either fuel which meets the minimum burnup requirements of Table 3.9-2, or an empty cell.

Boundary Condition: Any row bounded by an Unrestricted Storage Area shall contain a combination of restricted fuel assemblies and filler locations arranged such that no restricted fuel assemblies are adjacent to each other.
Example: In the figure above, row 1 or column 1 can not be adjacent to an Unrestricted Storage Area, but row 4 or column 4 can be.

REFUELING OPERATIONS

BASES

3/4.9.12 AND 3/4.9.13 SPENT FUEL POOL BORON CONCENTRATION AND SPENT FUEL ASSEMBLY STORAGE

The requirements for spent fuel pool boron concentration specified in Specification 3.9.12 ensure that a minimum boron concentration is maintained in the pool. The requirements for spent fuel assembly storage specified in Specification 3.9.13 ensure that the pool remains subcritical. The water in the spent fuel storage pool normally contains soluble boron, which results in large subcriticality margins under actual operating conditions. However, the NRC guidelines based upon the accident condition in which all soluble poison is assumed to have been lost, specify that the limiting k_{eff} of 0.95 be evaluated in the absence of soluble boron. Hence the design of the spent fuel storage racks is based on the use of unborated water, which maintains the spent fuel pool in a subcritical condition during normal operation with the pool fully loaded. The double contingency principle discussed in ANSI N-16.1-1975 and the April 1978 NRC letter (Ref. 4) allows credit for soluble boron under other abnormal or accident conditions, since only a single accident need be considered at one time. For example, the most severe accident scenario is associated with the accidental misloading of a fuel assembly. This could increase the reactivity of the spent fuel pool. To mitigate this postulated criticality related accident, boron is dissolved in the pool water.

Tables 3.9-1 and 3.9-2 allow for specific criticality analyses for fuel which does not meet the requirements for storage defined in these tables. These analyses would require using NRC approved methodology to ensure that $k_{eff} \leq 0.95$ with a 95 percent probability at a 95 percent confidence level as described in Section 9.1 of the FSAR. This option is intended to be used for fuel not included in previous criticality analyses. Fuel storage is still limited to the configurations defined in TS 3.9.13. The use of specific analyses for qualification of previously unanalyzed fuel includes, but is not limited to, fuel assembly designs not previously analyzed which may be as a result of new fuel designs or fuel shipments from another facility. Currently analyzed fuel designs include the Babcock and Wilcox Mkbw design, and the Westinghouse Standard and Optimized fuel designs. Another more likely, and expected use of this specific analysis provision would be to analyze movement and storage of individual fuel pins as a result of reconstitution activities.

In verifying the design criteria of $k_{eff} \leq 0.95$, the criticality analysis assumed the most conservative conditions, i.e. fuel of the maximum permissible reactivity for a given configuration. Since the data presented in Specification 3.9.13.a and 3.9.13.b represents the maximum reactivity requirements for acceptable storage, substitutions of less reactive components would also meet the $k_{eff} \leq 0.95$ criteria. Hence an empty cell, or a non-fuel component may be substituted for any designated fuel assembly location. These, or other substitutions which will decrease the reactivity of a particular storage cell will only decrease the overall reactivity of the spent fuel storage pool.

REFUELING OPERATIONS

BASES

3/4.9.12 AND 3/4.9.13 SPENT FUEL POOL BORON CONCENTRATION AND SPENT FUEL ASSEMBLY STORAGE (Continued)

If both restricted and unrestricted storage is used, an additional criteria has been imposed to ensure that the boundary row between these two configurations would not locally increase the reactivity above the required limit.

The action statement applicable to fuel storage in the spent fuel pool requires that action must be taken to preclude the occurrence of an accident or to mitigate the consequences of an accident in progress. This is most efficiently achieved by immediately suspending the movement of fuel assemblies. Prior to the resumption of fuel movement, the requirements of the LCOs must be met. This requires restoring the soluble boron concentration and the correct fuel storage configuration to within the corresponding limits. This does not preclude movement of a fuel assembly to a safe position.

The surveillance requirements ensure that the requirements of the two LCOs are satisfied, namely boron concentration and fuel placement. The boron concentration in the spent fuel pool is verified to be greater than or equal to the minimum limit. The fuel assemblies are verified to meet the subcriticality requirement by meeting either the initial enrichment and burnup requirements of Table 3.9-1 and 3.9-2, or by using NRC approved methodology to ensure that $k_{eff} \leq 0.95$. By meeting either of these requirements, the analyzed accidents are fully addressed.

The fuel storage requirements and restrictions discussed here and applied in specification 3.9.13 are based on a maximum allowable fuel enrichment of 5.0 weight% U-235. The enrichments listed in Tables 3.9-1 and 3.9-2 are nominal enrichments and include uncertainties to account for the tolerance on the as built enrichment. Hence the as built enrichments may exceed the enrichments listed in the tables by up to 0.05 weight % U-235. Qualifying burnups for enrichments not listed in the tables may be linearly interpolated between the enrichments provided. This is because the reactivity of an assembly varies linearly for small ranges of enrichment.

REFERENCES

1. "Regulatory Guide 1.13: Spent Fuel Storage Facility Design Basis", U.S. Nuclear Regulatory Commission, Office of Standards Development, Revision 1, December 1976.
2. "Design Objectives for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Stations", American Nuclear Society, ANSI N210-1976/ANS-57.2, April 1976.
3. FSAR, Section 9.1.
4. Double contingency principle of ANSI N16.1-1975, as specified in the April 14, 1978 NRC letter (Section 1.2) and implied in the proposed revision to Regulatory Guide 1.13 (Section 1.4, Appendix A).

DESIGN FEATURES

5.6 FUEL STORAGE

CRITICALITY

- 5.6.1 a. The spent fuel storage racks are designed and shall be maintained with:
- 1) $k_{eff} \leq 0.95$ if fully flooded with unborated water as described in Section 9.1 of the FSAR; and
 - 2) A nominal 13.5" center to center distance between fuel assemblies placed in the spent fuel storage racks.
- b. The new fuel storage racks are designed and shall be maintained with:
- 1) $k_{eff} \leq 0.95$ if fully flooded with unborated water as described in Section 9.1 of the FSAR; and
 - 2) $k_{eff} \leq 0.98$ if moderated by aqueous foam as described in Section 9.1 of the FSAR; and
 - 3) A nominal 21" center to center distance between fuel assemblies placed in the new fuel storage racks.

DRAINAGE

- 5.6.2 The spent fuel storage pool is designed and shall be maintained to prevent inadvertent draining of the pool below elevation 596 feet.

CAPACITY

- 5.6.3 The spent fuel storage pool is designed and shall be maintained with a storage capacity limited to no more than 1418 fuel assemblies.

5.7 COMPONENT CYCLIC OR TRANSIENT LIMIT

- 5.7.1 The components identified in Table 5.7-1 are designed and shall be maintained within the cyclic or transient limits of Table 5.7-1.

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

10. Accumulator and Refueling Water Storage Tank boron concentration limits for Specifications 3/4.5.1 and 3/4.5.4.
11. Reactor Coolant System and refueling canal boron concentration limits for Specification 3/4.9.1.
12. Standby Makeup Pump water supply boron concentration limit of Specification 4.7.13.3.
13. Spent Fuel Pool boron concentration limit of Specification 3/4.9.12.

The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by NRC in:

1. WCAP-9272-P-A, "WESTINGHOUSE RELOAD SAFETY EVALUATION METHODOLOGY," July 1985 (W Proprietary).
(Methodology for Specifications 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Bank Insertion Limit, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)
2. WCAP-10216-P-A, "RELAXATION OF CONSTANT AXIAL OFFSET CONTROL FQ SURVEILLANCE TECHNICAL SPECIFICATION," June 1983 (W Proprietary).
(Methodology for Specifications 3.2.1 - Axial Flux Difference (Relaxed Axial Offset Control) and 3.2.2 - Heat Flux Hot Channel Factor (W(Z) surveillance requirements for F_q Methodology.)
3. WCAP-10266-P-A Rev. 2, "THE 1981 VERSION OF WESTINGHOUSE EVALUATION MODEL USING BASH CODE," March 1987, (W Proprietary).
(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)
4. BAW-10168PA, Rev. 1, "B&W Loss-of-Coolant Accident Evaluation Model for Recirculating Steam Generator Plants," January 1991 (B&W Proprietary).
(Methodology for Specification 3.2.2 - Heat Flux Hot Channel Factor.)

ADMINISTRATIVE CONTROLS

CORE OPERATING LIMITS REPORT (Continued)

5. DPC-NE-2011P-A, "Duke Power Company Nuclear Design Methodology for Core Operating Limits of Westinghouse Reactors," March, 1990 (DPC Proprietary).

(Methodology for Specifications 2.2.1 - Reactor Trip System Instrumentation Setpoints, 3.1.3.5 - Shutdown Rod Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)

6. DPC-NE-3001P-A, "Multidimensional Reactor Transients and Safety Analysis Physics Parameter Methodology," November 1991 (DPC Proprietary).

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, 3.1.3.5 - Shutdown Rod Insertion Limits, 3.1.3.6 - Control Bank Insertion Limits, 3.2.1 - Axial Flux Difference, 3.2.2 - Heat Flux Hot Channel Factor, and 3.2.3 - Nuclear Enthalpy Rise Hot Channel Factor.)

7. DPC-NF-2010P-A, "Duke Power Company McGuire Nuclear Station Catawba Nuclear Station Nuclear Physics Methodology for Reload Design," June 1985 (DPC Proprietary).

(Methodology for Specification 3.1.1.3 - Moderator Temperature Coefficient, Specification 4.7.13.3 - Standby Makeup Pump Water Supply Boron Concentration, and Specification 3.9.1 - RCS and Refueling Canal Boron Concentration, and Specification 3.9.12 - Spent Fuel Pool Boron Concentration.)

8. DPC-NE-3002A, "FSAR Chapter 15 System Transient Analysis Methodology," November 1991.

(Methodology used in the system thermal-hydraulic analyses which determine the core operating limits)

9. DPC-NE-3000P-A, Rev. 1, "Thermal-Hydraulic Transient Analysis Methodology," November 1991.

(Modeling used in the system thermal-hydraulic analyses)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 134 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 128 TO FACILITY OPERATING LICENSE NPF-52
DUKE POWER COMPANY, ET AL.
CATAWBA NUCLEAR STATION, UNITS 1 AND 2
DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated September 19, 1994, as supplemented April 26 and June 19, 1995, Duke Power Company, et al. (the licensee), submitted a request for changes to the Catawba Nuclear Station, Units 1 and 2, Technical Specifications (TS). The requested changes would allow an increased limit for fuel enrichment. The current new (fresh) and spent fuel storage rack maximum nominal enrichment is 4.00 weight percent (w/o) U-235. As-built manufacturing variations of up to 0.05 w/o U-235 are accounted for in the nominal enrichment value. The proposed changes would allow for the storage of fuel with an enrichment not to exceed a nominal 5.00 w/o U-235 in the Catawba new and spent fuel storage racks. The June 19, 1995, letter provided clarifying information that did not change the scope of the September 19, 1994, application and initial proposed no significant hazards consideration determination.

2.0 EVALUATION - CRITICALITY ASPECTS

The fresh fuel storage racks are used for temporary storage of unirradiated reload fuel and are built on 21-inch centers. Both of the two independent spent fuel pools are designed for storage of both fresh and irradiated fuel. The stainless steel cells for each Unit are spaced on a 13.5-inch center-to-center distance and each has a storage capacity of 1418 fuel assemblies. The analysis of the reactivity effects of fuel storage in the new and spent fuel storage racks was performed with the SCALE system of computer codes with the three-dimensional multi-group Monte Carlo computer code, KENO Va. Neutron cross sections were generated by the NITAWL and BONAMI codes using the 123 Group GMTH library. Since the KENO Va code package does not have depletion capability, burnup analyses were performed with the CASMO-3/SIMULATE-3 methodology. CASMO-3 is an integral transport theory code and SIMULATE-3 is a nodal diffusion theory code. These codes are widely used for the analysis of fuel rack reactivity and have been benchmarked against results from numerous critical experiments. These experiments simulate the Catawba fuel storage racks as realistically as possible with respect to parameters important to reactivity such as enrichment and assembly spacing. The intercomparison between two independent methods of analysis (KENO Va and CASMO-3/SIMULATE-3) also provides an acceptable technique for validating calculational methods for nuclear criticality safety. To minimize the statistical uncertainty of the KENO Va reactivity calculations, a minimum of 90,000 neutron histories were accumulated in each calculation. Experience has shown that this number of histories is quite sufficient to assure convergence

of KENO Va reactivity calculations. The staff concludes that the analysis methods used are acceptable and capable of predicting the reactivity of the Catawba storage racks with a high degree of confidence.

The fresh fuel storage racks are normally maintained in a dry condition, i.e., the new fuel is stored in air. However, the NRC criteria for new fuel storage require that the effective multiplication factor, k_{eff} , of the storage rack be no greater than 0.95 if accidentally flooded by pure water and no greater than 0.98 if accidentally moderated by low density hydrogenous material (optimum moderation). The new fuel storage racks were analyzed for 5.00 w/o U-235 nominally enriched fuel for the full density flooding scenario and for the optimum moderation scenario. The calculated worst-case k_{eff} for a full rack of the Westinghouse Optimized Fuel Assembly (OFA) design, which is the most reactive fresh fuel of all fuel types which exist at Catawba, was 0.9302 for full density flooding and 0.9586 for optimum moderation conditions. Appropriate biases and uncertainties due to the calculational method and material tolerances were included at the 95/95 probability/confidence level. This meets the staff acceptance criteria of 0.95 for full density water flooding and 0.98 for optimum moderation conditions and is, therefore, acceptable.

Fuel assemblies with nominal enrichments up to 4.00 w/o U-235 can be stored in every cell of the Catawba spent fuel storage racks. To enable the storage of depleted fuel assemblies initially enriched to greater than 4.00 w/o U-235, the concept of burnup credit reactivity equivalencing was used. This is predicated upon the reactivity decrease associated with fuel depletion and has been previously accepted by the staff for spent fuel storage analysis. For burnup credit, a series of reactivity calculations are performed to generate a set of initial enrichment-fuel assembly discharge burnup ordered pairs which all yield an equivalent k_{eff} less than 0.95 when stored in the spent fuel storage racks. This is shown in Table 3.9-1 in which a fresh 4.05 w/o enriched fuel assembly yields the same rack reactivity as an initially enriched 5.00 w/o assembly depleted to 5.67 GWD/MTU. The curve shown in the Table includes biases due to methodology, a 95/95 methodology uncertainty, and a mechanical uncertainty due to manufacturing tolerances. In addition, a bias and uncertainty associated with fuel burnup was also included. The staff has reviewed the assumptions made in determining these biases and uncertainties and concludes that they are appropriately conservative.

New or irradiated assemblies with initial enrichments up to 5.00 w/o U-235 which do not meet the requirements for unrestricted storage must be placed in a restricted loading pattern. Reactivity analyses for these assemblies, arranged in a three-out-of-four storage configuration, were performed using the previously discussed methods. Acceptable fuel assemblies which qualify for storage in the fourth storage location of each three-out-of-four pattern are shown in Table 3.9-2 and are referred to as filler assemblies. These filler assemblies were also determined from minimum burnup versus initial enrichment calculations as described above. These special configurations have been analyzed using the acceptable reactivity methods described previously and meet the NRC acceptance criterion of k_{eff} no greater than 0.95, including all appropriate uncertainties at the 95/95 probability/confidence level. The results are, therefore, acceptable.

Tables 3.9-1 and 3.9-2 contain a footnote which would allow for specific criticality analyses for fuel which differs from those designs used to determine the requirements for storage defined in these tables. This would allow storage of fuel from the licensee's other facilities, pursuant to provision 2.B(7) of the Catawba Facility Operating Licenses, or storage of individual fuel rods as a result of fuel assembly reconstitution. These analyses would require using the NRC approved methodology described above to ensure that k_{eff} does not exceed 0.95 at a 95/95 probability/confidence level. At the staff's request, the Bases for TS 3.9-13 was revised to include additional discussion which reflects the intended use of this provision.

Most abnormal storage conditions will not result in an increase in the k_{eff} of the spent fuel racks. However, it is possible to postulate events, such as the misloading of an assembly with a burnup and enrichment combination outside of the acceptable requirement, which could lead to an increase in reactivity. However, for such events credit may be taken for the presence of boron in the pool water required during storage of fuel by TS 3.9.12 since the staff does not require the assumption of two unlikely, independent, concurrent events to ensure protection against a criticality accident (Double Contingency Principle). The reduction in k_{eff} caused by the boron more than offsets the reactivity addition caused by credible accidents. Therefore, the staff criterion of k_{eff} no greater than 0.95 for any postulated accident is met.

The following Technical Specification changes have been proposed as a result of the requested enrichment increase. The staff finds these changes, and the associated Bases changes, acceptable.

(1) TS 3/4.9.12 is being added to establish a required minimum spent fuel pool boron concentration in the Core Operating Limits Report (COLR). The relocation of the minimum spent fuel pool boron concentration to the COLR has previously been approved by the NRC in other licensing actions. Based on the NRC staff's recommendation, the licensee has also reduced the soluble boron surveillance interval from 31 days to 7 days.

(2) TS 3/4.9.13 is being added to specify the new fuel storage requirements given in Tables 3.9-1 and 3.9-2 and Figure 3.9-1 based on the reactivity analyses evaluated and approved above.

In response to the NRC staff's concern, the licensee has added a statement to Tables 3.9-1 and 3.9-2 indicating that specific analyses may be performed to qualify fuel assemblies for storage using NRC-approved methodology and has added additional discussion in the Bases to allow for specific criticality analyses for special situations without requiring additional TS changes, as discussed above.

(3) TS 5.6.1 is being changed to reflect the NRC criticality acceptance criteria for both the new fuel storage racks and the spent fuel storage racks.

Based on the review described above, the staff finds the criticality aspects of the proposed enrichment increase to the Catawba new and spent fuel pool storage racks are acceptable and meet the requirements of General Design Criterion 62 for the prevention of criticality in fuel storage and handling.

Although the Catawba TS have been modified to specify the above-mentioned fuel as acceptable for storage in the fresh or spent fuel racks, evaluations of reload core designs (using any enrichment) will, of course, be performed on a cycle-by-cycle basis as part of the reload safety evaluation process. Each reload design is evaluated to confirm that the cycle core design adheres to the limits that exist in the accident analyses and TS to ensure that reactor operation is acceptable.

3.0 EVALUATION - SPENT FUEL POOL COOLING & HEAT TRANSFER ASPECTS

In addition to the initial submittal dated September 19, 1994, the licensee provided a response, dated June 19, 1995, to a series of questions raised by the staff, relating to cooling and heat transfer in the spent fuel pool (SFP). The spent fuel pool cooling system (SFPCS) consists of two incompletely separated trains. Each train consists of a pump, a heat exchanger (HX) and associated piping and valves. The trains are separated from the pump suction line in the SFP to some distance downstream of the HX in each train, at which point they combine into a pipeline common to both trains, for discharge into the SFP.

The cleanup portion of the SFPCS consists of a pre-filter (used to remove particulates suspended in the coolant), a deionizer (to remove soluble material), and a post-filter (to remove particulate material).

The staff has reviewed both the licensee's initial submittal and response to the questions raised and found the licensee's proposal to be acceptable as discussed below.

3.1 New Fuel Storage

The staff found no new issues involved in storage of new fuel with increased initial enrichment. Therefore, storage of new fuel is found to be acceptable.

3.2 Spent Fuel Storage

3.2.1 Decay Heat Generation

The licensee used a computer code, "Panther," to calculate the decay heat generated for two cases. One is for the "normal" case (normal reload); the other "maximum" case (full core offload). It is assumed, in the normal case, that the spent fuel pool (SFP) is filled with 1216 assemblies, leaving room for slightly more than one full core to be offloaded, while for the maximum case the SFP is filled with 1409 spent fuel assemblies. The values of decay heat the licensee calculated for these cases are: 18.5E6 BTU/HR for the normal case, 47.0E6 BTU/HR in the maximum case. For the normal case, the licensee could have added one more normal offload since the allowed number of fuel assemblies licensed for the SFP is 1418 in number, 202 more than that accounted for in the analysis and in excess of that contained in the core. Nevertheless, the addition would change the calculated decay heat generation only slightly. Furthermore, the licensee noted that, when the decay heat generation was used to calculate the SFP coolant temperatures (see Section 2.2.3, below) the licensee calculated the decay heat assuming all of the cells

were filled with fuel assemblies. Therefore, the licensee's calculation of decay heat generation for both the normal and maximum cases is found to be acceptable.

3.2.2 SFP Heat Exchanger (HX)

The SFP HX's were tested under conditions of high (maximum) and low (normal) heat load with the following results: UAF (heat transfer coefficient x heat transfer area x correction factor) equal to $1.36E6$ BTU/HR °F in the maximum case, $1.17E6$ in the normal case. The higher value was obtained with a component cooling system (CCS) water flow rate of 3500 gpm, the lower with a CCS flow rate of 2450 gpm. Note that water from the CCS system is used to cool the SFP HXs. To be conservative, the licensee assumed a UAF value of $1E6$ BTU/HR °F for the one HX used in the calculation for the normal case and for each HX used in the calculation for the maximum case. In addition, the licensee assumed a CCS flow rate of 3000 gpm to the HX in the normal case and 3000 gpm split between the HX's (1500 gpm to each) used in the two train analysis for the maximum case. The licensee noted that test data showed that one component cooling water pump is capable of delivering 3500 gpm to one HX. The licensee assumed an SFP coolant flow rate of 2300 gpm for each SFP coolant system pump while each is designed for a flow rate of 2840 gpm. The heat exchanger (UAF) and coolant flow rates used in the analysis, including the values for flow for the component cooling water and SFP coolant, are conservative and, thus, found to be acceptable.

3.2.3 SFP Coolant Temperatures

For the normal case, the licensee reported the results of the analysis using the Panther calculated decay heat generation value. The calculated SFP coolant temperature was reported to be 128° F when using one train. This result is acceptable since it is lower than the Standard Review Plan (SRP) guideline value of 140° F.

For the maximum case, the licensee reported that the analysis of coolant temperature in this case was determined to be 145° F. This result is acceptable since it is lower than the value of 150° F noted in the Catawba Safety Evaluation Report, NUREG-0954, and the guideline of 212° F noted in SRP, Section 9.1.3, "Spent Fuel Pool Cooling and Cleanup System."

Therefore, the analyzed values of SFP coolant temperatures are found acceptable for both the normal and maximum cases.

3.3 Protection of Deionizer

The resins in the deionizer in the cleanup portion of the SFPCS have an operating limit of 140° F. There is a temperature alarm, set to operate at a temperature of 135° F so as to permit an operator to shut off that portion of the system (when in operation) before damaging the resins. Therefore, the method by which the resins in the deionizer are protected from excessive temperature is found to be acceptable.

3.4 Standby Shutdown Facility (SSF) Event

The standby shutdown system (SSS), which is part of the SSF is designed to mitigate the consequences of a fire at the Catawba Nuclear Station. The basis of the design of the SSF is to allow maintenance of a hot standby condition for 72 hours. As part of this process, the standby makeup pump in each unit is designed to pump water from the SFP into the reactor coolant system (RCS) via the RCS pump seals. The makeup pump is capable of pumping at least 26 gpm of makeup water from the SFP into the RCS; 14 gpm for seal leakage and 12 gpm for RCS makeup. The licensee reported that the calculation of water loss from the SFP included RCS makeup, boiloff, with the assumption that the analysis was initialized with the minimum amount of water in the SFP. The licensee concluded that "--boiloff to the top of the fuel assemblies will not occur until well after 72 hours". The actual calculation showed that boiling was attained in 26 hours after initiation of the standby makeup pump (starting at an initial temperature of 135° F). The calculated time for the initiation of fuel uncover would occur 92 hours later, for a total time of 118 hours after initiation of the standby makeup pump.

This is found to be acceptable since the initiation of uncover of fuel in the spent fuel pool does not occur within 72 hours, in compliance with the design basis of the SSF.

3.5 SUMMARY

The staff has concluded that the licensee's submittal is acceptable in the areas of spent fuel pool cooling and heat transfer.

An issue associated with spent fuel pool cooling adequacy was identified in NRC Information Notice 93-83, "Potential Loss of Spent Fuel Pool Cooling Following a Loss of Coolant Accident (LOCA)," October 7, 1993, and in a 10 CFR Part 21 notification, dated November 27, 1992. The staff is evaluating this issue, as well as broader issues associated with spent fuel storage safety, as part of the NRC generic issue evaluation process. If the generic review concludes that additional requirements in the area of spent fuel pool safety are warranted, the staff will address those requirements to the licensee under separate correspondence.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the South Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

Pursuant to 10 CFR 51.21, 51.32, and 51.35, an environmental assessment and finding of no significant impact have been prepared and published in the Federal Register on August 28, 1995 (60 FR 44513). Accordingly, based upon the environmental assessment, the Commission has determined that the issuance

this amendment will not have a significant impact on the quality of the human environment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors L. Kopp, SRXB
 N. Wagner, SPLB

Date: August 31, 1995