

Jul 1, 1997

SShaeff (A), RII  
BBoger

Mr. G. R. Peterson  
Site Vice President  
Catawba Nuclear Station  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745-9635

Distribution ~~XXXXXX~~  
Docket File ACRS T-2 E26  
PUBLIC OGC  
PDII-2 RF G.Hill(4)  
~~XXXXXX~~ e-mail TLH3 SE only  
JJohnson,RII TSB, 0-11 F23

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2  
(TAC NOS. M98861 AND M98862)

Dear Mr. Peterson:

The Nuclear Regulatory Commission has issued the enclosed Amendment No.160 to Facility Operating License NPF-35 and Amendment No.152 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments are in response to your application dated May 27, 1997.

The amendments delete Section 4.7.13.3.a.2 of each unit's Technical Specifications, regarding the minimum volume and boron concentration of boroated water available to the Standby Makeup Pump of the Standby Shutdown System.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Peter S. Tam, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 160 to NPF-35
2. Amendment No. 152 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\CATAWBA\CAT98861.AMD

OFFICE	PDII-2/PM	PDII-2/IA	OGC	SPLB/SC	PDII-2/D
NAME	P.TAM:cn	L.BERRY	S.HOW	G.Hubbard	H.BERKOWITZ
DATE	6/30/97	6/27/97	7/13/97	6/30/97	7/14/97
COPY	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

9707240330 970721  
PDR ADOCK 05000413  
P PDR

NRC FILE CENTER COPY

CP-1



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 21, 1997

Mr. G. R. Peterson  
Site Vice President  
Catawba Nuclear Station  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745-9635

SUBJECT: ISSUANCE OF AMENDMENTS - CATAWBA NUCLEAR STATION, UNITS 1 AND 2  
(TAC NOS. M98861 AND M98862)

Dear Mr. Peterson:

The Nuclear Regulatory Commission has issued the enclosed Amendment No.160 to Facility Operating License NPF-35 and Amendment No.152 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments are in response to your application dated May 27, 1997.

The amendments delete Section 4.7.13.3.a.2 of each unit's Technical Specifications, regarding the minimum volume and boron concentration of boroated water available to the Standby Makeup Pump of the Standby Shutdown System.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, which appears to read "Peter S. Tam", is written over a large, stylized checkmark.

Peter S. Tam, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 160 to NPF-35
2. Amendment No. 152 to NPF-52
3. Safety Evaluation

cc w/encl: See next page

Catawba Nuclear Station  
Units 1 and 2

cc:

Mr. M. S. Kitlan  
Regulatory Compliance Manager  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745

Mr. Paul R. Newton  
Legal Department (PB05E)  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW  
Washington, DC 20005

North Carolina Municipal Power  
Agency Number 1  
1427 Meadowood Boulevard  
P. O. Box 29513  
Raleigh, North Carolina 27626-0513

Mr. Peter R. Harden, IV  
Account Sales Manager  
Westinghouse Electric Corporation  
Power Systems Field Sales  
P. O. Box 7288  
Charlotte, North Carolina 28241

County Manager of York County  
York County Courthouse  
York, South Carolina 29745

Richard P. Wilson, Esquire  
Assistant Attorney General  
South Carolina Attorney General's  
Office  
P. O. Box 11549  
Columbia, South Carolina 29211

Piedmont Municipal Power Agency  
121 Village Drive  
Greer, South Carolina 29651

Mr. T. Richard Puryear  
Owners Group (NCEMC)  
Duke Power Company  
4800 Concord Road  
York, South Carolina 29745

North Carolina Electric Membership  
Corporation  
P. O. Box 27306  
Raleigh, North Carolina 27611

Senior Resident Inspector  
4830 Concord Road  
York, South Carolina 29745

Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
Atlanta Federal Center  
61 Forsyth Street, S.W., Suite 23T85  
Atlanta, Georgia 30303

Max Batavia, Chief  
Bureau of Radiological Health  
South Carolina Department of  
Health and Environmental Control  
2600 Bull Street  
Columbia, South Carolina 29201

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242-0001

Saluda River Electric  
P. O. Box 929  
Laurens, South Carolina 29360

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335

Dayne H. Brown, Director  
Division of Radiation Protection  
N.C. Department of Environment,  
Health and Natural Resources  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY  
NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION  
SALUDA RIVER ELECTRIC COOPERATIVE, INC.  
DOCKET NO. 50-413  
CATAWBA NUCLEAR STATION, UNIT 1  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No.160  
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees), dated May 27, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9707240336 970721  
PDR ADOCK 05000413  
P PDR


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 160, which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Technical Specification Changes

Date of Issuance: July 21, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 160

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove

3/4 7-33

Insert

3/4 7-33

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

4.7.13.2 The Standby Shutdown System diesel starting 24-volt battery bank and charger shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying that:
  - 1) The electrolyte level of each battery is at or above the low mark and at or below the high mark; and
  - 2) The overall battery voltage is greater than or equal to 24 volts on float charge.
- b. At least once per 92 days by verifying that the individual cell voltage is greater than or equal to 1.36 volts on float charge, and
- c. At least once per 18 months by verifying that:
  - 1) The batteries, cell plates, and battery racks show no visual indication of physical damage or abnormal deterioration, and
  - 2) The battery-to-battery and terminal connections are clean, tight, and free of corrosion.

4.7.13.3 The Standby Makeup Pump water supply shall be demonstrated OPERABLE by:

- a. Verifying at least once per 7 days that the requirements of Specification 3.9.10 are met and the boron concentration in the storage pool is greater than or equal to the minimum specified in the Core Operating Limits Report.
- b. Verifying at least once per 92 days that the Standby Makeup Pump develops a flow of greater than or equal to 26 gpm at a pressure greater than or equal to 2488 psig.

4.7.13.4 The Standby Shutdown System 250/125-Volt Battery Bank and its associated charger shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying:
  - 1) That the electrolyte level of each battery is above the plates, and



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 152  
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees), dated May 27, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.




2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 152, which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment: Technical Specifications Changes

Date of Issuance: July 21, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 152

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

Remove

3/4 7-34

Insert

3/4 7-34

## PLANT SYSTEMS

### SURVEILLANCE REQUIREMENTS (Continued)

---

4.7.13.2 The Standby Shutdown System diesel starting 24-volt battery bank and charger shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying that:
  - 1) The electrolyte level of each battery is at or above the low mark and at or below the high mark; and
  - 2) The overall battery voltage is greater than or equal to 24 volts on float charge.
- b. At least once per 92 days by verifying that the individual cell voltage is greater than or equal to 1.36 volts on float charge, and
- c. At least once per 18 months by verifying that:
  - 1) The batteries, cell plates, and battery racks show no visual indication of physical damage or abnormal deterioration, and
  - 2) The battery-to-battery and terminal connections are clean, tight, and free of corrosion.

4.7.13.3 The Standby Makeup Pump water supply shall be demonstrated OPERABLE by:

- a. Verifying at least once per 7 days that the requirements of Specification 3.9.10 are met and the boron concentration in the storage pool is greater than or equal to the minimum specified in the Core Operating Limits Report.
- b. Verifying at least once per 92 days that the Standby Makeup Pump develops a flow of greater than or equal to 26 gpm at a pressure greater than or equal to 2488 psig.

4.7.13.4 The Standby Shutdown System 250/125-Volt Battery Bank and its associated charger shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying:
  - 1) That the electrolyte level of each battery is above the plates, and



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 160 TO FACILITY OPERATING LICENSE NPF-35  
AND AMENDMENT NO. 152 TO FACILITY OPERATING LICENSE NPF-52

DUKE POWER COMPANY, ET AL.

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated May 27, 1997, Duke Power Company, et al. (DPC, the licensee), submitted a request for changes to the Catawba Nuclear Station, Units 1 and 2, Technical Specifications (TS). The proposed changes would delete Section 4.7.13.3.a.2 regarding minimum borated water volume and boron concentration for the standby makeup pump (SMP) of the standby shutdown system (SSS).

2.0 DISCUSSION AND EVALUATION

The Catawba SSS is a non-safety-related system that is shared between Units 1 and 2. Details of the staff's review of the SSS functions and design objectives are delineated in Section 9.5.1.5, Supplement 4 of the Safety Evaluation Report (SSER 4) for Catawba, NUREG-0954, dated December 1984. SSER 4 provides the following description of the SSS:

The standby shutdown system (SSS) is designed to mitigate the consequences of a postulated fire incident to either Catawba Unit 1 or Unit 2 and consists of normal plant safety-related equipment (i.e., each unit's turbine-driven auxiliary feedwater pump) and dedicated equipment (i.e., the standby diesel generator and each unit's standby makeup pump). The SSS is designed to remove decay heat through the steam generator and provide normal reactor coolant system makeup to maintain hot standby. The SSS supplements the current shutdown capability described in Section 7.4 of the Final Safety Analysis Report (FSAR). It would be operated only in the event that installed normal and emergency systems were inoperable. Manual operator action is required to actuate the system. There is one SSS for both units of the station, but each unit has separate SSS controls.

SSER 4 describes the SMP as follows:

The standby makeup pump, which supplies reactor coolant makeup during SSS operation, is located in the containment annulus of each unit. The pump provides makeup for normal reactor coolant system leakage and reactor coolant pump seal leakage. The pump draws water from the spent fuel pool transfer canal through a pipe connected to the fuel

transfer tube in the annulus...[and] will provide at least 26 gallons per minutes (gpm) of borated water to the reactor coolant system. Approximately 14 gpm will be available for seal leakage, and the remaining 12 gpm is for reactor coolant system makeup and boration.

The SMP flow rate of 26 gpm is specified by TS Section 4.7.13.3.b, which is not a subject of the current amendment request. The licensee's data obtained from in-plant testing has shown that the actual flow rate of the SMP is in the range of 26 - 32 gpm. For the low end (as specified by the TS) of the flow rate, the total volume of borated water needed would be 112,320 gallons, as currently specified by TS Section 4.7.13.3.a.2; for the high end, the total volume would be 138,240 gallons.

Section E4.1 of NRC Inspection Report 50-413, 414/96-13 raised questions concerning such apparent nonconservative design assumptions. As a result, during additional review of this issue, the licensee determined that the source of borated water, the spent fuel pool, has much more water available to the SMP (415,000 gallons) than would be required by the SMP for a 3-day operation at maximum flow rate. While SMP suction from the spent fuel pool would deprive it of some inventory, borated makeup water can be supplied from the refueling water storage tank, demineralized water can be supplied by the reactor makeup water pumps, and emergency makeup water can be supplied from the nuclear service water system (see Section 9.1.3.1.4 of the Update Final Safety Analysis Report, and Section 9.1.3 of the Catawba Safety Evaluation Report, NUREG-0954). Thus, there is no shortage of water for the SMP from the spent fuel pool for the required 3-day operation capability.<sup>1</sup> The minimum volume requirement of TS Section 4.7.13.3.a.2 can be deleted with no impact on SMP performance.

The spent fuel pool water is required to be borated to "within the limit specified in the core operating limits report" (Section 3.9.12 of the TS). This requirement is identical to that currently specified for the SMP borated water source in TS Section 4.7.13.3.a.1. The minimum boration requirement of TS Section 4.7.13.3.a.2 can thus be deleted with no impact on SMP performance.

Other than the proposed deletion of TS Section 4.7.13.3.a.2, which has been shown above as redundant and unnecessary, the licensee proposed no change to SMP design or operation. There is no relaxation of any limiting conditions for operation, and no decrease in surveillance requirements. The staff,

---

<sup>1</sup>The volume of water available in the spent fuel pool to the SMP is 415,000 gallons. The minimum depth of water in the pool is at least 37.6 feet, corresponding to 23 feet over the top of irradiated fuel assemblies specified by Section 3.9.10 of the TS. In practice, the licensee keeps the water above the alarm level of 39 feet, nominally at 39.9 feet. Since 1 foot corresponds to about 17,000 gallons, the SMP could take suction from the spent fuel pool for about 8.8 hours before the alarm limit is reached, and about 20 hours before the TS limit is reached. There is thus ample time to activate any of the several makeup sources to prevent reaching the alarm or TS minimum level.

therefore, finds the licensee's proposed deletion of TS Section 4.7.13.3.a.2 acceptable.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the South Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendments change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (62 FR 33121 dated June 18, 1997). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

### 5.0 CONCLUSION

The staff has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Peter S. Tam

Date: July 21, 1997