

November 5, 2001

Mr. J. A. Scalice
Chief Nuclear Officer
and Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: BROWNS FERRY, UNIT 3 - SAFETY EVALUATION REGARDING THE RELIEF REQUEST TO UPDATE THE INSERVICE INSPECTION PROGRAM RELATED TO WELDED ATTACHMENTS IN CODE CLASS 1, 2, AND 3 COMPONENTS TO THE 1995 EDITION, ASME CODE, SECTION XI, INCLUDING THE 1996 ADDENDA (TAC NO. MB2586)

Dear Mr. Scalice:

By letter dated August 17, 2001, the Tennessee Valley Authority proposed to update the inservice inspection (ISI) program related to welded attachments in all Code Class 1, 2, and 3 components from the applicable American Society of Mechanical Engineers (ASME) Code, Section XI, 1989 Edition to that of the 1995 Edition including the 1996 Addenda for the Browns Ferry Nuclear Plant (BFN), Unit 3.

As discussed in the enclosed safety evaluation, the staff has determined that the use of the 1995 Edition with 1996 Addenda of the ASME Code during the second and the third inspection periods of the second 10-year inspection interval of Unit 3 for the examination of welded attachments will provide an acceptable level of quality and safety until BFN Unit 3 fully adopts the newer edition of the ASME Code. Therefore, pursuant to Title 10 of the *Code of Federal Regulations*, Section 50.55a(a)(3)(i), the proposed alternative is authorized for the remainder of the second 10-year ISI interval at BFN Unit 3.

This completes our efforts under TAC No. MB2586. If you have any questions regarding this issue, please contact Allen Hansen, BFN Project Manager, at 301-415-1390.

Sincerely,

/RA/

Richard Correia, Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-296

Enclosure: Safety Evaluation

cc w/encl: See next page

November 5, 2001

Mr. J. A. Scalice
Chief Nuclear Officer
and Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: BROWNS FERRY, UNIT 3 - SAFETY EVALUATION REGARDING THE RELIEF REQUEST TO UPDATE THE INSERVICE INSPECTION PROGRAM RELATED TO WELDED ATTACHMENTS IN CODE CLASS 1, 2, AND 3 COMPONENTS TO THE 1995 EDITION, ASME CODE, SECTION XI, INCLUDING THE 1996 ADDENDA (TAC NO. MB2586)

Dear Mr. Scalice:

By letter dated August 17, 2001, the Tennessee Valley Authority proposed to update the inservice inspection (ISI) program related to welded attachments in all Code Class 1, 2, and 3 components from the applicable American Society of Mechanical Engineers (ASME) Code, Section XI, 1989 Edition to that of the 1995 Edition including the 1996 Addenda for the Browns Ferry Nuclear Plant (BFN), Unit 3.

As discussed in the enclosed safety evaluation, the staff has determined that the use of the 1995 Edition with 1996 Addenda of the ASME Code during the second and the third inspection periods of the second 10-year inspection interval of Unit 3 for the examination of welded attachments will provide an acceptable level of quality and safety until BFN Unit 3 fully adopts the newer edition of the ASME Code. Therefore, pursuant to Title 10 of the *Code of Federal Regulations*, Section 50.55a(a)(3)(i), the proposed alternative is authorized for the remainder of the second 10-year ISI interval at BFN Unit 3.

This completes our efforts under TAC No. MB2586. If you have any questions regarding this issue, please contact Allen Hansen, BFN Project Manager, at 301-415-1390.

Sincerely,
/RA/
Richard Correia, Chief, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-296

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

ACRS, RidsAcrsAcnwMailCenter	SRosenberg, EDO	PUBLIC
RCorreia, RidsNrrDlpmLpdii2	BClayton (hard copy)	AHansen (hard copy)
HBerkow, RidsNrrDlpmLpdii	OGC, RidsOgcRp	PPatnaik
PFredrickson, RidsRgn2MailCenter	PDII-2 Reading	GHill (hard copy)

ADAMS ACCESSION NUMBER: **ML013090341**

* No substantive change to SE

OFFICE	PDII-2/PM	PDII-2/LA	SC/EMCB	OGC	PDII-2/SC
NAME	AHansen	BClayton	TChan *	BHoefling	RCorreia
DATE	10/24/2001	10/24/2001	10/23/2001	10/30/2001	11/5/2001

OFFICIAL RECORD COPY

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
UPDATE REFERENCED ASME CODE EDITION AND ADDENDA
TENNESSEE VALLEY AUTHORITY
BROWNS FERRY, UNIT 3
DOCKET NO. 50-296

1.0 INTRODUCTION

By letter dated August 17, 2001, the Tennessee Valley Authority (TVA) proposed to update the inservice inspection (ISI) program related to welded attachments in all Code Class 1, 2, and 3 components from the applicable American Society of Mechanical Engineers (ASME) Code, Section XI, 1989 Edition to that of the 1995 Edition including the 1996 Addenda for the Browns Ferry Nuclear Plant (BFN), Unit 3.

2.0 EVALUATION

The TVA letter stated that, pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.55a(g)(4)(iv), TVA plans to update during the second and the third periods of the current second 10-year interval of BFN Unit 3, the inservice examination of the welded attachments to components in Code Class 1, 2, and 3 to the 1995 Edition, ASME Code, Section XI, including the 1996 Addenda. The letter further states that Browns Ferry Unit 2, currently in its third 10-year ISI interval, has already adopted the 1995 Edition, ASME Code, Section XI, including the 1996 Addenda for its inservice inspection program. Both units have implemented a risk-informed inservice inspection program.

The Nuclear Regulatory Commission encourages licensees with identical units to adopt the same Code for their ISI programs even though both units may be in different inspection intervals, in order to reduce the administrative burden of implementing two different programs while not affecting the health and safety of the public. BFN Unit 2 has a program in place for inservice examination of welded attachments in the examination categories B-K, C-C, and D-A, which correspond to the ASME Code, Section XI, Class 1, 2, and 3 components, respectively. Unit 3 is in transition to adopt the 1995 Edition with 1996 Addenda of the ASME Code for its next ISI interval.

3.0 CONCLUSION

Since the portion of the ISI program related to welded attachments is independent of the balance of the ISI program, the staff has determined that the use of the 1995 Edition with 1996 Addenda of the ASME Code during the second and the third inspection periods of the second 10-year inspection interval of Unit 3 for the examination of welded attachments will provide an acceptable level of quality and safety until BFN Unit 3 fully adopts the newer edition of the ASME Code. Therefore, pursuant to 10 CFR 50.55a(a)(3)(i), the proposed alternative is authorized for the remainder of the second 10-year ISI interval at BFN Unit 3.

Principal Contributor: Prakash Patnaik, NRR

Date: November 5, 2001

Mr. J. A. Scalice
Tennessee Valley Authority

BROWNS FERRY NUCLEAR PLANT

cc:

Mr. Karl W. Singer, Senior Vice President
Nuclear Operations
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager
Nuclear Licensing
Tennessee Valley Authority
4X Blue Ridge
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Jon R. Rupert, Vice President (Acting)
Engineering & Technical Services
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Mr. Timothy E. Abney, Manager
Licensing and Industry Affairs
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Mr. Ashok S. Bhatnagar, Site Vice President
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Browns Ferry Nuclear Plant
10833 Shaw Road
Athens, AL 35611

General Counsel
Tennessee Valley Authority
ET 11A
400 West Summit Hill Drive
Knoxville, TN 37902

State Health Officer
Alabama Dept. of Public Health
RSA Tower - Administration
Suite 1552
P.O. Box 303017
Montgomery, AL 36130-3017

Mr. Robert J. Adney, General Manager
Nuclear Assurance
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, TN 37402-2801

Chairman
Limestone County Commission
310 West Washington Street
Athens, AL 35611

Mr. Robert G. Jones, Plant Manager
Browns Ferry Nuclear Plant
Tennessee Valley Authority
P.O. Box 2000
Decatur, AL 35609