

Mr. G. R. Peterson
 Site Vice President
 Catawba Nuclear Station
 Duke Energy Corporation
 4800 Concord Road
 York, South Carolina 29745-9635

August 13, 1999

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: ISSUANCE OF AMENDMENTS (TAC NOS. MA4315 AND MA4316)

Dear Mr. Peterson:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 179 to Facility Operating License NPF-35 and Amendment No. 171 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 25, 1999.

The amendments revise various parts of the Technical Specifications (Appendix A of the Catawba operating licenses) to identify that the TRIP SETPOINTS for the reactor trip system and engineered safety feature actuation system instrumentation are in reality NOMINAL TRIP SETPOINTS. Details are set forth in the associated Safety Evaluation (enclosed).

We will publish a Notice of Issuance in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:
 Peter S. Tam, Senior Project Manager, Section 1
 Project Directorate II
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 179 to NPF-35
 2. Amendment No. 171 to NPF-52
 3. Safety Evaluation
- cc w/encs: See next page

Distribution:

Docket File
 PUBLIC
 PD II-1 R/F
 COgle, RII
 RScholl (e-mail SE only)
 WBeckner, TSB

OGC
 ACRS
 GHill (4)
 JZwolinski/SBlack

DF011

DOCUMENT NAME: G:\PDII-1\CATAWBA\c4315amd.wpd

To receive a copy of this document, indicate in the box C=Copy w/o attachment/enclosure E=Copy with attachment/enclosure N = No copy

OFFICE	PDII-1/PM	PDII-1/LA	E	OGC*	PDII-1/SC	PDII/D
NAME	PTAM:cr <i>BS</i>	CHawes <i>CMH</i>	Suttal	REMCH <i>R/E</i>	HBERKOW	<i>[Signature]</i>
DATE	8/11/99	8/13/99	8/5/99	8/12/99	8/12/99	

* See previous concurrence

OFFICIAL RECORD COPY

CP1

9908200214 990813
 PDR ADOCK 05000413
 P PDR

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 13, 1999

Mr. G. R. Peterson
Site Vice President
Catawba Nuclear Station
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745-9635

SUBJECT: CATAWBA NUCLEAR STATION, UNITS 1 AND 2 RE: ISSUANCE OF
AMENDMENTS (TAC NOS. MA4315 AND MA4316)

Dear Mr. Peterson:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 179 to Facility Operating License NPF-35 and Amendment No. 171 to Facility Operating License NPF-52 for the Catawba Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 25, 1999.

The amendments revise various parts of the Technical Specifications (Appendix A of the Catawba operating licenses) to identify that the TRIP SETPOINTS for the reactor trip system and engineered safety feature actuation system instrumentation are in reality NOMINAL TRIP SETPOINTS. Details are set forth in the associated Safety Evaluation (enclosed).

We will publish a Notice of Issuance in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink that reads "Peter S. Tam".

Peter S. Tam, Senior Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-413 and 50-414

Enclosures:

1. Amendment No. 179 to NPF-35
2. Amendment No. 171 to NPF-52
3. Safety Evaluation

cc w/encls: See next page

Catawba Nuclear Station

cc:

Mr. Gary Gilbert
Regulatory Compliance Manager
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Ms. Lisa F. Vaughn
Legal Department (PB05E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

Anne Cottingham, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626

County Manager of York County
York County Courthouse
York, South Carolina 29745

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
4830 Concord Road
York, South Carolina 29745

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209

Catawba Nuclear Station

cc:

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745

Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY CORPORATION
NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION
SALUDA RIVER ELECTRIC COOPERATIVE, INC.
DOCKET NO. 50-413
CATAWBA NUCLEAR STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 179
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Energy Corporation, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees), dated March 25, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9908200219 990813
PDR ADOCK 05000413
P PDR

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 179, which are attached hereto, are hereby incorporated into this license. Duke Energy Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 45 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard L. Emch, Jr., Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: August 13, 1999



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY CORPORATION
NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1
PIEDMONT MUNICIPAL POWER AGENCY
DOCKET NO. 50-414
CATAWBA NUCLEAR STATION, UNIT 2
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 171
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Energy Corporation, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees), dated March 25, 1999, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 171, which are attached hereto, are hereby incorporated into this license. Duke Energy Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 45 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Richard L. Emch, Jr., Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: August 13, 1999

ATTACHMENT TO LICENSE AMENDMENT NO. 179

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND LICENSE AMENDMENT NO. 171

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
1.1-4	1.1-4
1.1-5	1.1-5
1.1-6	1.1-6
1.1-7	1.1-7
3.3.1-14	3.3.1-14
3.3.1-15	3.3.1-15
3.3.1-16	3.3.1-16
3.3.1-17	3.3.1-17
3.3.1-18	3.3.1-18
3.3.1-19	3.3.1-19
3.3.2-11	3.3.2-11
3.3.2-12	3.3.2-12
3.3.2-13	3.3.2-13
3.3.2-14	3.3.2-14
3.3.2-15	3.3.2-15
3.3.5-2	3.3.5-2
3.3.6-3	3.3.6-3
3.4.12-1	3.4.12-1

Replace the following pages of the Technical Specifications Bases document with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

<u>Remove</u>	<u>Insert</u>
B3.3.1-1	B3.3.1-1
B3.3.1-2	B3.3.1-2
B3.3.1-4	B3.3.1-4
B3.3.1-30	B3.3.1-30

Remove

B3.3.1-31
B3.3.2-2
B3.3.2-3
B3.3.2-31
B3.3.2-32
B3.3.5-2
B3.3.5-3
B3.3.5-4

Insert

B3.3.1-31
B3.3.2-2
B3.3.2-3
B3.3.2-31
B3.3.2-32
B3.3.5-2
B3.3.5-3
B3.3.5-4

1.1 Definitions (continued)

MASTER RELAY TEST	A MASTER RELAY TEST shall consist of energizing each master relay and verifying the OPERABILITY of each relay. The MASTER RELAY TEST shall include a continuity check of each associated slave relay.
MODE	A MODE shall correspond to any one inclusive combination of core reactivity condition, power level, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
NOMINAL TRIP SETPOINT	The NOMINAL TRIP SETPOINT shall be the design value of a setpoint. The trip setpoint implemented in plant hardware may be less or more conservative than the NOMINAL TRIP SETPOINT by a calibration tolerance. If plant conditions warrant, the trip setpoint implemented in plant hardware may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the trip setpoint is conservative with respect to the NOMINAL TRIP SETPOINT.
OPERABLE — OPERABILITY	A system, subsystem, train, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PHYSICS TESTS	PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation. These tests are: a. Described in Chapter 14 of the UFSAR; b. Authorized under the provisions of 10 CFR 50.59; or c. Otherwise approved by the Nuclear Regulatory Commission.
QUADRANT POWER TILT RATIO (QPTR)	QPTR shall be the ratio of the maximum upper excore detector calibrated output to the average of the upper excore detector calibrated outputs, or the ratio of the maximum lower excore detector calibrated output to the average of the lower excore detector calibrated outputs, whichever is greater.

(continued)

1.1 Definitions (continued)

RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 3411 MWt.
REACTOR TRIP SYSTEM (RTS) RESPONSE TIME	The RTS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RTS trip setpoint at the channel sensor until loss of stationary gripper coil voltage. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.
SHUTDOWN MARGIN (SDM)	<p>SDM shall be the instantaneous amount of reactivity by which the reactor is subcritical or would be subcritical from its present condition assuming:</p> <ul style="list-style-type: none"> a. All rod cluster control assemblies (RCCAs) are fully inserted except for the single RCCA of highest reactivity worth, which is assumed to be fully withdrawn. With any RCCA not capable of being fully inserted, the reactivity worth of the RCCA must be accounted for in the determination of SDM; and b. In MODES 1 and 2, the fuel and moderator temperatures are changed to the nominal zero power design level.
SLAVE RELAY TEST	A SLAVE RELAY TEST shall consist of energizing each slave relay and verifying the OPERABILITY of each slave relay. The SLAVE RELAY TEST shall include, as a minimum, a continuity check of associated testable actuation devices.
STAGGERED TEST BASIS	A STAGGERED TEST BASIS shall consist of the testing of one of the systems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, subsystems, channels, or other designated components are tested during n Surveillance Frequency intervals, where n is the total number of systems, subsystems, channels, or other designated components in the associated function.
THERMAL POWER	THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

1.1 Definitions (continued)

TRIP ACTUATING DEVICE
OPERATIONAL TEST
(TADOT)

A TADOT shall consist of operating the trip actuating device and verifying the OPERABILITY of required alarm, interlock, and trip functions. The TADOT shall include adjustment, as necessary, of the trip actuating device so that it actuates at the required setpoint within the required accuracy.

Table 1.1-1 (page 1 of 1)
MODES

MODE	TITLE	REACTIVITY CONDITION (k_{eff})	% RATED THERMAL POWER(a)	AVERAGE REACTOR COOLANT TEMPERATURE (°F)
1	Power Operation	≥ 0.99	> 5	NA
2	Startup	≥ 0.99	≤ 5	NA
3	Hot Standby	< 0.99	NA	≥ 350
4	Hot Shutdown(b)	< 0.99	NA	$350 > T_{avg} > 200$
5	Cold Shutdown(b)	< 0.99	NA	≤ 200
6	Refueling(c)	NA	NA	NA

(a) Excluding decay heat.

(b) All reactor vessel head closure bolts fully tensioned.

(c) One or more reactor vessel head closure bolts less than fully tensioned.

Table 3.3.1-1 (page 1 of 7)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
1. Manual Reactor Trip	1,2	2	B	SR 3.3.1.14	NA	NA
	3(a), 4(a), 5(a)	2	C	SR 3.3.1.14	NA	NA
2. Power Range Neutron Flux						
a. High	1,2	4	D	SR 3.3.1.1 SR 3.3.1.2 SR 3.3.1.7 SR 3.3.1.11 SR 3.3.1.16	≤ 110.9% RTP	109% RTP
b. Low	1(b),2	4	E	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11 SR 3.3.1.16	≤ 27.1% RTP	25% RTP
3. Power Range Neutron Flux						
High Positive Rate	1,2	4	D	SR 3.3.1.7 SR 3.3.1.11	≤ 6.3% RTP with time constant ≥ 2 sec	5% RTP with time constant ≥ 2 sec
4. Intermediate Range Neutron Flux	1(b), 2(c)	2	F,G	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 31% RTP	25% RTP
	2(d)	2	H	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 31% RTP	25% RTP
5. Source Range Neutron Flux	2(d)	2	I,J	SR 3.3.1.1 SR 3.3.1.8 SR 3.3.1.11	≤ 1.4 E5 cps	1.0 E5 cps
	3(a), 4(a), 5(a)	2	J,K	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.11	≤ 1.4 E5 cps	1.0 E5 cps
6. Overtemperature ΔT	1,2	4	E	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16 SR 3.3.1.17	Refer to Note 1 (Page 3.3.1-18)	Refer to Note 1 (Page 3.3.1-18)

(continued)

- (a) With Reactor Trip Breakers (RTBs) closed and Rod Control System capable of rod withdrawal.
- (b) Below the P-10 (Power Range Neutron Flux) interlocks.
- (c) Above the P-6 (Intermediate Range Neutron Flux) interlocks.
- (d) Below the P-6 (Intermediate Range Neutron Flux) interlocks.

Table 3.3.1-1 (page 2 of 7)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
7. Overpower ΔT	1,2	4	E	SR 3.3.1.1 SR 3.3.1.3 SR 3.3.1.6 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16 SR 3.3.1.17	Refer to Note 2 (Page 3.3.1-19)	Refer to Note 2 (Page 3.3.1-19)
8. Pressurizer Pressure						
a. Low	1(e)	4	L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	$\geq 1938^{(f)}$ psig	1945 ^(f) psig
b. High	1,2	4	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≤ 2399 psig	2385 psig
9. Pressurizer Water Level - High	1(e)	3	L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10	$\leq 93.8\%$	92%
10. Reactor Coolant Flow - Low						
a. Single Loop	1(g)	3 per loop	M	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	$\geq 89.7\%$	91%
b. Two Loops	1(h)	3 per loop	L	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	$\geq 89.7\%$	91%

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

(f) Time constants utilized in the lead-lag controller for Pressurizer Pressure - Low are 2 seconds for lead and 1 second for lag.

(g) Above the P-8 (Power Range Neutron Flux) interlock.

(h) Above the P-7 (Low Power Reactor Trips Block) interlock and below the P-8 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 3 of 7)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
11. Undervoltage RCPs	1(e)	1 per bus	L	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.16	≥ 5016 V	5082 V
12. Underfrequency RCPs	1(e)	1 per bus	L	SR 3.3.1.9 SR 3.3.1.10 SR 3.3.1.16	≥ 55.9 Hz	56.4 Hz
13. Steam Generator (SG) Water Level - Low Low	1,2	4 per SG	E	SR 3.3.1.1 SR 3.3.1.7 SR 3.3.1.10 SR 3.3.1.16	≥ 9% (Unit 1) ≥ 35.1% (Unit 2) of narrow range span	10.7% (Unit 1) 36.8% (Unit 2) of narrow range span
14. Turbine Trip						
a. Stop Valve EH Pressure Low	1(i)	4	N	SR 3.3.1.10 SR 3.3.1.15	≥ 500 psig	550 psig
b. Turbine Stop Valve Closure	1(j)	4	O	SR 3.3.1.10 SR 3.3.1.15	≥ 1% open	NA
15. Safety Injection (SI) Input from Engineered Safety Feature Actuation System (ESFAS)	1,2	2 trains	P	SR 3.3.1.5 SR 3.3.1.14	NA	NA

(continued)

(e) Above the P-7 (Low Power Reactor Trips Block) interlock.

(i) Not used.

(j) Above the P-9 (Power Range Neutron Flux) interlock.

Table 3.3.1-1 (page 4 of 7)
Reactor Trip System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
16. Reactor Trip System Interlocks						
a. Intermediate Range Neutron Flux, P-6	2 ^(d)	2	R	SR 3.3.1.11 SR 3.3.1.13	≥ 6E-11 amp	1E-10 amp
b. Low Power Reactor Trips Block, P-7	1	1 per train	S	SR 3.3.1.5	NA	NA
c. Power Range Neutron Flux, P-8	1	4	S	SR 3.3.1.11 SR 3.3.1.13	≤ 50.2% RTP	48% RTP
d. Power Range Neutron Flux, P-9	1	4	S	SR 3.3.1.11 SR 3.3.1.13	≤ 70% RTP	69% RTP
e. Power Range Neutron Flux, P-10	1,2	4	R	SR 3.3.1.11 SR 3.3.1.13	≥ 7.8% RTP and ≤ 12.2% RTP	10% RTP
f. Turbine Impulse Pressure, P-13	1	2	S	SR 3.3.1.12 SR 3.3.1.13	≤ 12.2% RTP turbine impulse pressure equivalent	10% RTP turbine impulse pressure equivalent
17. Reactor Trip Breakers ^(k)						
	1,2	2 trains	Q,U	SR 3.3.1.4	NA	NA
	3(a), 4(a), 5(a)	2 trains	C	SR 3.3.1.4	NA	NA
18. Reactor Trip Breaker Undervoltage and Shunt Trip Mechanisms						
	1,2	1 each per RTB	T	SR 3.3.1.4	NA	NA
	3(a), 4(a), 5(a)	1 each per RTB	C	SR 3.3.1.4	NA	NA
19. Automatic Trip Logic						
	1,2	2 trains	P,U	SR 3.3.1.5	NA	NA
	3(a), 4(a), 5(a)	2 trains	C	SR 3.3.1.5	NA	NA

(continued)

- (a) With RTBs closed and Rod Control System capable of rod withdrawal.
- (d) Below the P-6 (Intermediate Range Neutron Flux) interlocks.
- (k) Including any reactor trip bypass breakers that are racked in and closed for bypassing an RTB.

Table 3.3.1-1 (page 5 of 7)
Reactor Trip System Instrumentation

Note 1: Overtemperature ΔT

The Overtemperature ΔT Function Allowable Value shall not exceed the following NOMINAL TRIP SETPOINT by more than 4.5% of RTP.

$$\Delta T \frac{(1 + \tau_1 s)}{(1 + \tau_2 s)} \left(\frac{1}{1 + \tau_3 s} \right) \leq \Delta T_0 \left\{ K_1 - K_2 \frac{(1 + \tau_4 s)}{(1 + \tau_5 s)} \left[T \frac{1}{(1 + \tau_6 s)} - T' \right] + K_3 (P - P') - f_1(\Delta I) \right\}$$

Where: ΔT is the measured RCS ΔT by loop narrow range RTDs, °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T' is the nominal T_{avg} at RTP (allowed by Safety Analysis), $\leq 585.1^\circ\text{F}$ (Unit 1)
 $\leq 590.8^\circ\text{F}$ (Unit 2).

P is the measured pressurizer pressure, psig

P' is the nominal RCS operating pressure, = 2235 psig

K_1 = Overtemperature ΔT reactor NOMINAL TRIP SETPOINT, as presented in the COLR,

K_2 = Overtemperature ΔT reactor trip heatup setpoint penalty coefficient, as presented in the COLR,

K_3 = Overtemperature ΔT reactor trip depressurization setpoint penalty coefficient, as presented in the COLR,

τ_1, τ_2 = Time constants utilized in the lead-lag compensator for ΔT , as presented in the COLR,

τ_3 = Time constant utilized in the lag compensator for ΔT , as presented in the COLR,

τ_4, τ_5 = Time constants utilized in the lead-lag compensator for T_{avg} , as presented in the COLR,

τ_6 = Time constant utilized in the measured T_{avg} lag compensator, as presented in the COLR, and

$f_1(\Delta I)$ = a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for $q_t - q_b$ between the "positive" and "negative" $f_1(\Delta I)$ breakpoints as presented in the COLR; $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent ΔI that the magnitude of $q_t - q_b$ is more negative than the $f_1(\Delta I)$ "negative" breakpoint presented in the COLR, the ΔT Trip Setpoint shall be automatically reduced by the $f_1(\Delta I)$ "negative" slope presented in the COLR; and

(continued)

Table 3.3.1-1 (page 6 of 7)
Reactor Trip System Instrumentation

- (iii) for each percent ΔI that the magnitude of $q_t - q_b$ is more positive than the $f_1(\Delta I)$ "positive" breakpoint presented in the COLR, the ΔT Trip Setpoint shall be automatically reduced by the $f_1(\Delta I)$ "positive" slope presented in the COLR.

Note 2: Overpower ΔT

The Overpower ΔT Function Allowable Value shall not exceed the following NOMINAL TRIP SETPOINT by more than 3% (Unit 1) 3.3% (Unit 2) of RTP.

$$\Delta T \frac{(1 + \tau_1 s)}{(1 + \tau_2 s)} \left(\frac{1}{1 + \tau_3 s} \right) \leq \Delta T_0 \left\{ K_4 - K_5 \frac{\tau_7 s}{1 + \tau_7 s} \left(\frac{1}{1 + \tau_6 s} \right) T - K_6 \left[T \frac{1}{1 + \tau_6 s} - T^* \right] - f_2(\Delta I) \right\}$$

Where: ΔT is the measured RCS ΔT by loop narrow range RTDs, °F.

ΔT_0 is the indicated ΔT at RTP, °F.

s is the Laplace transform operator, sec^{-1} .

T is the measured RCS average temperature, °F.

T^* is the nominal T_{avg} at RTP (calibration temperature for ΔT instrumentation), $\leq 585.1^\circ\text{F}$ (Unit 1) $\leq 590.8^\circ\text{F}$ (Unit 2).

K_4 = Overpower ΔT reactor NOMINAL TRIP SETPOINT as presented in the COLR,

K_5 = $0.02/^\circ\text{F}$ for increasing average temperature and 0 for decreasing average temperature,

K_6 = Overpower ΔT reactor trip heatup setpoint penalty coefficient as presented in the COLR for $T > T^*$ and $K_6 = 0$ for $T \leq T^*$,

τ_1, τ_2 = Time constants utilized in the lead-lag compensator for ΔT , as presented in the COLR,

τ_3 = Time constant utilized in the lag compensator for ΔT , as presented in the COLR,

τ_6 = Time constant utilized in the measured T_{avg} lag compensator, as presented in the COLR,

τ_7 = Time constant utilized in the rate-lag controller for T_{avg} , as presented in the COLR, and

$f_2(\Delta I)$ = a function of the indicated difference between top and bottom detectors of the power-range neutron ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for $q_t - q_b$ between the "positive" and "negative" $f_2(\Delta I)$ breakpoints as presented in the COLR; $f_2(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;

(continued)

Table 3.3.2-1 (page 1 of 5)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
1. Safety Injection						
a. Manual initiation	1,2,3,4	2	B	SR 3.3.2.8	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
c. Containment Pressure - High	1,2,3	3	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 1.4 psig	1.2 psig
d. Pressurizer Pressure - Low	1,2,3(a)	4	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 1839 psig	1845 psig
2. Containment Spray						
a. Manual Initiation	1,2,3,4	1 per train, 2 trains	B	SR 3.3.2.8	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
c. Containment Pressure - High High	1,2,3	4	E	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 3.2 psig	3.0 psig
3. Containment Isolation						
a. Phase A Isolation						
(1) Manual Initiation	1,2,3,4	2	B	SR 3.3.2.8	NA	NA
(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
(3) Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

Table 3.3.2-1 (page 2 of 5)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
3. Containment Isolation (continued)						
b. Phase B Isolation						
(1) Manual Initiation	1,2,3,4	1 per train, 2 trains	B	SR 3.3.2.8	NA	NA
(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
(3) Containment Pressure - High High	1,2,3	4	E	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 3.2 psig	3.0 psig
4. Steam Line Isolation						
a. Manual Initiation						
(1) System	1,2(b),3(b)	2 trains	F	SR 3.3.2.8	NA	NA
(2) Individual	1,2(b),3(b)	1 per line	G	SR 3.3.2.8	NA	NA
b. Automatic Actuation Logic and Actuation Relays	1,2(b),3(b)	2 trains	H	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
c. Containment Pressure - High High	1,2(b),3(b)	4	E	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 3.2 psig	3.0 psig
d. Steam Line Pressure						
(1) Low	1,2(b),3(a)(b)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 744 psig	775 psig

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

(b) Except when all MSIVs are closed and de-activated.

Table 3.3.2-1 (page 3 of 5)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
4. Steam Line Isolation (continued)						
(2) Negative Rate - High	3 ^{(b)(c)}	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 122.8 ^(d) psi	100 ^(d) psi
5. Turbine Trip and Feedwater Isolation						
a. Automatic Actuation Logic and Actuation Relays	1,2 ^(e)	2 trains	I	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
b. SG Water Level - High High (P-14)	1,2 ^(e)	4 per SG	J	SR 3.3.2.1 SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.5 SR 3.3.2.6 SR 3.3.2.9 SR 3.3.2.10	≤ 85.6% (Unit 1) ≤ 78.9% (Unit 2)	83.9% (Unit 1) 77.1% (Unit 2)
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
d. T _{avg} -Low	1,2 ^(e)	4	J	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9	≥ 561°F	564°F
coincident with Reactor Trip, P-4	Refer to Function 8.a (Reactor Trip, P-4) for all initiation functions and requirements.					
e. Doghouse Water Level - High High	1,2 ^(e)	2 per doghouse	L	SR 3.3.2.8	≤ 12 inches above 577 ft floor level	11 inches above 577 ft floor level
f. Trip of all main feedwater pumps	1,2 ^(a)	3 per MFW pump	K	SR 3.3.2.8	NA	NA

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

(b) Except when all MSIVs are closed and de-activated.

(c) Trip function automatically blocked above P-11 (Pressurizer Pressure) interlock and may be blocked below P-11 when Steam Line Isolation Steam Line Pressure - Low is not blocked.

(d) Time constant utilized in the rate/lag controller is ≥ 50 seconds.

(e) Except when all MFIVs, MFCVs, and associated bypass valves are closed and de-activated or isolated by a closed manual valve.

Table 3.3.2-1 (page 4 of 5)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
6. Auxiliary Feedwater						
a. Automatic Actuation Logic and Actuation Relays	1,2,3	2 trains	H	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
b. SG Water Level - Low Low	1,2,3	4 per SG	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 9% (Unit 1) ≥ 35.1% (Unit 2)	10.7% (Unit 1) 36.8% (Unit 2)
c. Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					
d. Loss of Offsite Power	1,2,3	3 per bus	D	SR 3.3.2.3 SR 3.3.2.9 SR 3.3.2.10	≥ 3242 V	3500 V
e. Trip of all Main Feedwater Pumps	1,2(a)	3 per pump	K	SR 3.3.2.8 SR 3.3.2.10	NA	NA
f. Auxiliary Feedwater Pump Train A and Train B Suction Transfer on Suction Pressure - Low	1,2,3	3 per train	M	SR 3.3.2.8 SR 3.3.2.10	A) ≥ 9.5 psig B) ≥ 5.2 psig (Unit 1) ≥ 5.0 psig (Unit 2)	A) 10.5 psig B) 6.2 psig (Unit 1) 6.0 psig (Unit 2)
7. Automatic Switchover to Containment Sump						
a. Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	C	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA	NA
b. Refueling Water Storage Tank (RWST) Level - Low	1,2,3,4	4	N	SR 3.3.2.1 SR 3.3.2.7 SR 3.3.2.9 SR 3.3.2.10	≥ 162.4 inches	177.15 inches
Coincident with Safety Injection	Refer to Function 1 (Safety Injection) for all initiation functions and requirements.					

(continued)

(a) Above the P-11 (Pressurizer Pressure) interlock.

Table 3.3.2-1 (page 5 of 5)
Engineered Safety Feature Actuation System Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE	NOMINAL TRIP SETPOINT
8. ESFAS Interlocks						
a. Reactor Trip, P-4	1,2,3	1 per train, 2 trains	F	SR 3.3.2.8	NA	NA
b. Pressurizer Pressure, P-11	1,2,3	3	O	SR 3.3.2.5 SR 3.3.2.9	≥ 1944 and ≤ 1966 psig	1955 psig
c. T _{avg} - Low Low, P-12	1,2,3	1 per loop	O	SR 3.3.2.5 SR 3.3.2.9	≥ 550°F	553°F
9. Containment Pressure Control System						
a. Start Permissive	1,2,3,4	4 per train	P	SR 3.3.2.1 SR 3.3.2.7 SR 3.3.2.9	≤ 0.45 psid	0.4 psid
b. Termination	1,2,3,4	4 per train	P	SR 3.3.2.1 SR 3.3.2.7 SR 3.3.2.9	≥ 0.25 psid	0.3 psid
10. Nuclear Service Water Suction Transfer - Low Pit Level	1,2,3,4	3 per pit	Q,R	SR 3.3.2.1 SR 3.3.2.9 SR 3.3.2.11	≥ El. 555.4 ft	El. 557.5 ft

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.3.5.1 -----NOTE----- Testing shall consist of voltage sensor relay testing excluding actuation of load shedding diesel start, and time delay times. ----- Perform TADOT.</p>	<p>31 days</p>
<p>SR 3.3.5.2 Perform CHANNEL CALIBRATION with NOMINAL TRIP SETPOINT and Allowable Value as follows:</p> <p>a. Loss of voltage Allowable Value \geq 3242 V. Loss of voltage NOMINAL TRIP SETPOINT = 3500 V.</p> <p>b. Degraded voltage Allowable Value \geq 3738 V. Degraded voltage NOMINAL TRIP SETPOINT = 3766 V.</p>	<p>18 months</p>

Containment Purge and Exhaust Isolation Instrumentation
3.3.6

Table 3.3.6-1 (page 1 of 1)
Containment Purge and Exhaust Isolation Instrumentation

FUNCTION	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	NOMINAL TRIP SETPOINT
1. Manual Initiation	2	SR 3.3.6.4	NA
2. Automatic Actuation Logic and Actuation Relays	2 trains	SR 3.3.6.1 SR 3.3.6.2 SR 3.3.6.3	NA
3. Safety Injection	Refer to LCO 3.3.2, "ESFAS Instrumentation," Table 3.3.2-1, Function 1, for all initiation functions and requirements.		

3:4 REACTOR COOLANT SYSTEM (RCS)

3.4.12 Low Temperature Overpressure Protection (LTOP) System

LCO 3.4.12 An LTOP System shall be OPERABLE with a maximum of one charging pump or one safety injection pump capable of injecting into the RCS, the accumulators isolated, reactor coolant pump operation limited as specified in Table 3.4.12-1 and either a or b below:

- a. Two power operated relief valves (PORVs) with nominal lift setting = 400 psig (as left calibrated), allowable value ≤ 425 psig (as found), with RCS cold leg temperature $\geq 65^{\circ}\text{F}$; or
- b. The RCS depressurized and an RCS vent of ≥ 4.5 square inches.

APPLICABILITY: MODE 4 when any RCS cold leg temperature is $\leq 285^{\circ}\text{F}$,
MODE 5,
MODE 6 when the reactor vessel head is on.

-----NOTE-----
Accumulator isolation is only required when accumulator pressure is greater than or equal to the maximum RCS pressure for the existing RCS cold leg temperature allowed by the P/T limit curves provided in Specification 3.4.3.

B 3.3 INSTRUMENTATION

B 3.3.1 Reactor Trip System (RTS) Instrumentation

BASES

BACKGROUND The RTS initiates a unit shutdown, based on the values of selected unit parameters, to protect against violating the core fuel design limits and Reactor Coolant System (RCS) pressure boundary during anticipated operational occurrences (AOOs) and to assist the Engineered Safety Features (ESF) Systems in mitigating accidents.

The protection and monitoring systems have been designed to assure safe operation of the reactor. This is achieved by specifying limiting safety system settings (LSSS) in terms of parameters directly monitored by the RTS, as well as specifying LCOs on other reactor system parameters and equipment performance.

The LSSS, defined in this specification as the Allowable Value, in conjunction with the LCOs, establish the threshold for protective system action to prevent exceeding acceptable limits during Design Basis Accidents (DBAs).

During AOOs, which are those events expected to occur one or more times during the unit life, the acceptable limits are:

1. The Departure from Nucleate Boiling Ratio (DNBR) shall be maintained above the Safety Limit (SL) value to prevent departure from nucleate boiling (DNB);
2. Fuel centerline melt shall not occur; and
3. The RCS pressure SL of 2735 psig shall not be exceeded.

Operation within the SLs of Specification 2.0, "Safety Limits (SLs)," also maintains the above values and assures that offsite dose will be within the 10 CFR 20 and 10 CFR 100 criteria during AOOs.

Accidents are events that are analyzed even though they are not expected to occur during the unit life. The acceptable limit during accidents is that offsite dose shall be maintained within an acceptable fraction of 10 CFR 100 limits. Different accident categories are allowed a different fraction of these limits, based on probability of occurrence. Meeting the acceptable dose limit for an accident category is considered having acceptable consequences for that event.

BASES

BACKGROUND (continued)

The RTS instrumentation is segmented into four distinct but interconnected categories as illustrated in UFSAR, Chapter 7 (Ref. 1), and as identified below:

1. Field transmitters or process sensors: provide a measurable electronic signal based upon the physical characteristics of the parameter being measured;
2. Process monitoring systems, including the Process Control System, the Nuclear Instrumentation System (NIS), and various field contacts and sensors: monitors various plant parameters, provides any required signal processing, and provides digital outputs when parameters exceed predetermined limits. They may also provide outputs for control, indication, alarm, computer input, and recording;
3. Solid State Protection System (SSPS), including input, logic, and output bays: combines the input signals from the process monitoring systems per predetermined logic and initiates a reactor trip and ESF actuation when warranted by the process monitoring systems inputs; and
4. Reactor trip switchgear, including reactor trip breakers (RTBs) and bypass breakers: provides the means to interrupt power to the control rod drive mechanisms (CRDMs) and allows the rod cluster control assemblies (RCCAs), or "rods," to fall into the core and shut down the reactor. The bypass breakers allow testing of the RTBs at power.

Field Transmitters or Sensors

To meet the design demands for redundancy and reliability, more than one, and often as many as four, field transmitters or sensors are used to measure unit parameters. To account for the calibration tolerances and instrument drift, which are assumed to occur between calibrations, statistical allowances are provided in the NOMINAL TRIP SETPOINT. The OPERABILITY of each transmitter or sensor can be evaluated when its "as found" calibration data are compared against its documented acceptance criteria.

BASES

BACKGROUND (continued)

Trip Setpoints and Allowable Values

The NOMINAL TRIP SETPOINTS are the nominal values at which the bistables are set. Any bistable is considered to be properly adjusted when the "as left" value is within the band for CHANNEL CALIBRATION tolerance.

The NOMINAL TRIP SETPOINTS used in the bistables are based on the analytical limits (Ref. 1, 2, and 3). The selection of these NOMINAL TRIP SETPOINTS is such that adequate protection is provided when all sensor and processing time delays, calibration tolerances, instrumentation uncertainties, instrument drift, and severe environment errors for those RTS channels that must function in harsh environments as defined by 10 CFR 50.49 (Ref. 5) are taken into account. The actual as-left setpoint of the bistable assures that the actual trip occurs in time to prevent an analytical limit from being exceeded.

The Allowable Value accounts for changes in random measurement errors between COTs. One example of such a change in measurement error is drift during the surveillance interval. If the COT demonstrates that the loop trips within the Allowable Value, the loop is OPERABLE. A trip within the Allowable Value ensures that the predictions of equipment performance used to develop the NOMINAL TRIP SETPOINT are still valid, and that the equipment will initiate a trip in response to an AOO in time to prevent an analytical limit from being exceeded (and that the consequences of DBAs will be acceptable, providing the unit is operated from within the LCOs at the onset of the AOO or DBA and the equipment functions as designed). Note that in the accompanying LCO 3.3.1, the Allowable Values of Table 3.3.1-1 are the LSSS.

Each channel of the process control equipment can be tested on line to verify that the signal or setpoint accuracy is within the specified allowance requirements. Once a designated channel is taken out of service for testing, a simulated signal is injected in place of the field instrument signal. The process equipment for the channel in test is then tested, verified, and calibrated. SRs for the channels are specified in the SRs section.

The determination of the NOMINAL TRIP SETPOINTS and Allowable Values listed in Table 3.3.1-1 incorporates all of the known uncertainties applicable for each channel. The magnitudes of these uncertainties are factored into the determination of each NOMINAL TRIP SETPOINT. All field sensors and signal processing equipment

BASES

APPLICABLE SAFETY ANALYSES, LCO, and APPLICABILITY (continued)

19. Automatic Trip Logic

The LCO requirement for the RTBs (Functions 17 and 18) and Automatic Trip Logic (Function 19) ensures that means are provided to interrupt the power to allow the rods to fall into the reactor core. Each RTB is equipped with an undervoltage coil and a shunt trip coil to trip the breaker open when needed. Each train RTB has a bypass breaker to allow testing of the trip breaker while the unit is at power. The reactor trip signals generated by the RTS Automatic Trip Logic cause the RTBs and associated bypass breakers to open and shut down the reactor.

The LCO requires two trains of RTS Automatic Trip Logic to be OPERABLE. Having two OPERABLE channels ensures that random failure of a single logic channel will not prevent reactor trip.

These trip Functions must be OPERABLE in MODE 1 or 2 when the reactor is critical. In MODE 3, 4, or 5, these RTS trip Functions must be OPERABLE when the RTBs and associated bypass breakers are closed, and the CRD System is capable of rod withdrawal.

The RTS instrumentation satisfies Criterion 3 of 10 CFR 50.36 (Ref. 6).

ACTIONS

A Note has been added to the ACTIONS to clarify the application of Completion Time rules. The Conditions of this Specification may be entered independently for each Function listed in Table 3.3.1-1. When the Required Channels in Table 3.3.1-1 are specified (e.g., on a per steam line, per loop, per SG, etc., basis), then the Condition may be entered separately for each steam line, loop, SG, etc., as appropriate.

A channel shall be OPERABLE if the point at which the channel trips is found more conservative than the Allowable Value. In the event a channel's trip setpoint is found less conservative than the Allowable Value, or the transmitter, instrument loop, signal processing electronics, or bistable is found inoperable, then all affected Functions provided by that channel must be declared inoperable and the LCO Condition(s) entered for the protection Function(s) affected. If plant conditions warrant, the trip setpoint may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the trip setpoint is conservative with respect to the NOMINAL TRIP SETPOINT. If the trip setpoint is found outside of the NOMINAL TRIP SETPOINT calibration tolerance band and non-conservative with respect to the NOMINAL TRIP

BASES

ACTIONS (continued)

SETPOINT, the setpoint shall be re-adjusted.

When the number of inoperable channels in a trip Function exceed those specified in one or other related Conditions associated with a trip Function, then the unit is outside the safety analysis. Therefore, LCO 3.0.3 must be immediately entered if applicable in the current MODE of operation.

A.1

Condition A applies to all RTS protection Functions. Condition A addresses the situation where one or more required channels for one or more Functions are inoperable at the same time. The Required Action is to refer to Table 3.3.1-1 and to take the Required Actions for the protection functions affected. The Completion Times are those from the referenced Conditions and Required Actions.

B.1 and B.2

Condition B applies to the Manual Reactor Trip in MODE 1 or 2. This action addresses the train orientation of the SSPS for this Function. With one channel inoperable, the inoperable channel must be restored to OPERABLE status within 48 hours. In this Condition, the remaining OPERABLE channel is adequate to perform the safety function.

The Completion Time of 48 hours is reasonable considering that there are two automatic actuation trains and another manual initiation channel OPERABLE, and the low probability of an event occurring during this interval.

If the Manual Reactor Trip Function cannot be restored to OPERABLE status within the allowed 48 hour Completion Time, the unit must be brought to a MODE in which the requirement does not apply. To achieve this status, the unit must be brought to at least MODE 3 within 6 additional hours (54 hours total time). The 6 additional hours are reasonable, based on operating experience, to reach MODE 3 from full power operation in an orderly manner and without challenging unit systems. With the unit in MODE 3, the MODE 1 and 2 requirements for this trip Function are no longer required and Condition C is entered.

BASES

BACKGROUND (continued)

provided in the NOMINAL TRIP SETPOINT. The OPERABILITY of each transmitter or sensor can be evaluated when its "as found" calibration data are compared against its documented acceptance criteria.

Signal Processing Equipment

Generally, three or four channels of process control equipment are used for the signal processing of unit parameters measured by the field instruments. The process control equipment provides signal conditioning, comparable output signals for instruments located on the main control board, and comparison of measured input signals with setpoints established by safety analyses. These setpoints are defined in UFSAR, Chapter 6 (Ref. 1), Chapter 7 (Ref. 2), and Chapter 15 (Ref. 3). If the measured value of a unit parameter exceeds the predetermined setpoint, an output from a bistable is forwarded to the SSPS for decision logic processing. Channel separation is maintained up to and through the input bays. However, not all unit parameters require four channels of sensor measurement and signal processing. Some unit parameters provide input only to the SSPS, while others provide input to the SSPS, the main control board, the unit computer, and one or more control systems.

Generally, if a parameter is used only for input to the protection circuits, three channels with a two-out-of-three logic are sufficient to provide the required reliability and redundancy. If one channel fails in a direction that would not result in a partial Function trip, the Function is still OPERABLE with a two-out-of-two logic. If one channel fails such that a partial Function trip occurs, a trip will not occur and the Function is still OPERABLE with a one-out-of-two logic.

Generally, if a parameter is used for input to the SSPS and a control function, four channels with a two-out-of-four logic are sufficient to provide the required reliability and redundancy. The circuit must be able to withstand both an input failure to the control system, which may then require the protection function actuation, and a single failure in the other channels providing the protection function actuation. Again, a single failure will neither cause nor prevent the protection function actuation.

These requirements are described in IEEE-279-1971 (Ref. 4). The actual number of channels required for each unit parameter is specified in the UFSAR.

BASES

BACKGROUND (continued)

Trip Setpoints and Allowable Values

The NOMINAL TRIP SETPOINTS are the nominal values at which the bistables are set. Any bistable is considered to be properly adjusted when the "as left" value is within the band for CHANNEL CALIBRATION tolerance.

The NOMINAL TRIP SETPOINTS used in the bistables are based on the analytical limits (Ref. 1, 2, and 3). The selection of these NOMINAL TRIP SETPOINTS is such that adequate protection is provided when all sensor and processing time delays, calibration tolerances, instrumentation uncertainties, instrument drift, and severe environment errors for those ESFAS channels that must function in harsh environments as defined by 10 CFR 50.49 (Ref. 5) are taken into account. The actual as-left setpoint of the bistable assures that the actual trip occurs before the Allowable Value is reached. The Allowable Value accounts for changes in random measurement errors detectable by a COT. One example of such a change in measurement error is drift during the surveillance interval. If the point at which the loop trips does not exceed the Allowable Value, the loop is considered OPERABLE.

A trip within the Allowable Value ensures that the consequences of Design Basis Accidents (DBAs) will be acceptable, providing the unit is operated from within the LCOs at the onset of the DBA and the equipment functions as designed.

Each channel can be tested on line to verify that the signal processing equipment and setpoint accuracy is within the specified allowance requirements. Once a designated channel is taken out of service for testing, a simulated signal is injected in place of the field instrument signal. The process equipment for the channel in test is then tested, verified, and calibrated. SRs for the channels are specified in the SR section.

The determination of the NOMINAL TRIP SETPOINTS and Allowable Values listed in Table 3.3.2-1 incorporates all of the known uncertainties applicable for each channel. The magnitudes of these uncertainties are factored into the determination of each NOMINAL TRIP SETPOINT. All field sensors and signal processing equipment for these channels are assumed to operate within the allowances of these uncertainty magnitudes.

BASES

APPLICABLE SAFETY ANALYSES, LCO, and APPLICABILITY (continued)

valves, and start the NSWS pumps. This function is initiated on a two-out-of-three logic from either NSWS pump pit.

This function must be OPERABLE in MODES 1, 2, 3, and 4 to ensure cooling water remains available to essential components during a DBA. In MODES 5 and 6, the sufficient time exists for manual operator action to realign the NSWS pump suction, if required.

The ESFAS instrumentation satisfies Criterion 3 of 10 CFR 50.36 (Ref. 6).

ACTIONS

A Note has been added in the ACTIONS to clarify the application of Completion Time rules. The Conditions of this Specification may be entered independently for each Function listed on Table 3.3.2-1. When the Required Channels in Table 3.3.2-1 are specified (e.g., on a per steam line, per loop, per SG, etc., basis), then the Condition may be entered separately for each steam line, loop, SG, etc., as appropriate.

A channel shall be OPERABLE if the point at which the channel trips is found more conservative than the Allowable Value. In the event a channel's trip setpoint is found less conservative than the Allowable Value, or the transmitter, instrument loop, signal processing electronics, or bistable is found inoperable, then all affected Functions provided by that channel must be declared inoperable and the LCO Condition(s) entered for the protection Function(s) affected. If plant conditions warrant, the trip setpoint may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the trip setpoint is conservative with respect to the NOMINAL TRIP SETPOINT. If the trip setpoint is found outside of the NOMINAL TRIP SETPOINT calibration tolerance band and non-conservative with respect to the NOMINAL TRIP SETPOINT, the setpoint shall be re-adjusted.

When the number of inoperable channels in a trip function exceed those specified in one or other related Conditions associated with a trip function, then the unit is outside the safety analysis. Therefore, LCO 3.0.3 should be immediately entered if applicable in the current MODE of operation.

A.1

Condition A applies to all ESFAS protection functions.

BASES

ACTIONS (continued)

Condition A addresses the situation where one or more channels or trains for one or more Functions are inoperable at the same time. The Required Action is to refer to Table 3.3.2-1 and to take the Required Actions for the protection functions affected. The Completion Times are those from the referenced Conditions and Required Actions.

B.1, B.2.1 and B.2.2

Condition B applies to manual initiation of:

- SI;
- Containment Spray;
- Phase A Isolation; and
- Phase B Isolation.

This action addresses the train orientation of the SSPS for the functions listed above. If a channel or train is inoperable, 48 hours is allowed to return it to an OPERABLE status. Note that for containment spray and Phase B isolation, failure of one or both channels in one train renders the train inoperable. Condition B, therefore, encompasses both situations. The specified Completion Time is reasonable considering that there are two automatic actuation trains and another manual initiation train OPERABLE for each Function, and the low probability of an event occurring during this interval. If the train cannot be restored to OPERABLE status, the unit must be placed in a MODE in which the LCO does not apply. This is done by placing the unit in at least MODE 3 within an additional 6 hours (54 hours total time) and in MODE 5 within an additional 30 hours (84 hours total time). The allowable Completion Times are reasonable, based on operating experience, to reach the required unit conditions from full power conditions in an orderly manner and without challenging unit systems.

C.1, C.2.1 and C.2.2

Condition C applies to the automatic actuation logic and actuation relays for the following functions:

- SI;
- Containment Spray;
- Phase A Isolation;

BASES

BACKGROUND (continued)

Trip Setpoints and Allowable Values

The NOMINAL TRIP SETPOINTS used in the relays are based on the analytical limits presented in UFSAR, Chapter 15 (Ref. 2). The selection of these Trip Setpoints is such that adequate protection is provided when all sensor and processing time delays are taken into account.

The actual as-left setpoint of the relays is normally still more conservative than that required by the Allowable Value. If the measured setpoint does not exceed the Allowable Value, the relay is considered OPERABLE.

Setpoints adjusted in accordance with the Allowable Value ensure that the consequences of accidents will be acceptable, providing the unit is operated from within the LCOs at the onset of the accident and that the equipment functions as designed.

Allowable Values and NOMINAL TRIP SETPOINTS are specified for each Function in the LCO. The NOMINAL TRIP SETPOINTS are selected to ensure that the setpoint measured by the surveillance procedure does not exceed the Allowable Value if the relay is performing as required. A relay shall be OPERABLE if the point at which the relay trips is found more conservative than the Allowable Value. In the event a relay's trip setpoint is found less conservative than the Allowable Value, or the transmitter, instrument loop, signal processing electronics, or bistable is found inoperable, then all affected Functions provided by that relay must be declared inoperable and the LCO Condition(s) entered for the protection Function(s) affected. If plant conditions warrant, the trip setpoint may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the trip setpoint is conservative with respect to the NOMINAL TRIP SETPOINT. If the trip setpoint is found outside of the NOMINAL TRIP SETPOINT calibration tolerance band and non-conservative with respect to the NOMINAL TRIP SETPOINT, the setpoint shall be re-adjusted. Each Allowable Value and NOMINAL TRIP SETPOINT specified is more conservative than the analytical limit assumed in the transient and accident analyses in order to account for instrument uncertainties appropriate to the trip function. These uncertainties are defined in setpoint calculations.

APPLICABLE SAFETY ANALYSES	The LOP DG start instrumentation is required for the Engineered Safety Features (ESF) Systems to function in any accident with a loss of offsite power. Its design basis is that of the ESF Actuation System (ESFAS).
----------------------------	---

BASES

APPLICABLE SAFETY ANALYSES (continued)

Accident analyses credit the loading of the DG based on the loss of offsite power during a loss of coolant accident (LOCA). The actual DG start has historically been associated with the ESFAS actuation. The DG loading has been included in the delay time associated with each safety system component requiring DG supplied power following a loss of offsite power. The analyses assume a non-mechanistic DG loading, which does not explicitly account for each individual component of loss of power detection and subsequent actions.

The required channels of LOP DG start instrumentation, in conjunction with the ESF systems powered from the DGs, provide unit protection in the event of any of the analyzed accidents discussed in Reference 2, in which a loss of offsite power is assumed.

The delay times assumed in the safety analysis for the ESF equipment include the 10 second DG start delay, and the appropriate sequencing delay, if applicable. The response times for ESFAS actuated equipment in LCO 3.3.2, "Engineered Safety Feature Actuation System (ESFAS) Instrumentation," include the appropriate DG loading and sequencing delay. The LOP DG start instrumentation channels satisfy Criterion 3 of 10 CFR 50.36 (Ref. 3).

LCO

The LCO for LOP DG start instrumentation requires that three channels per bus of both the loss of voltage and degraded voltage Functions shall be OPERABLE in MODES 1, 2, 3, and 4 when the LOP DG start instrumentation supports safety systems associated with the ESFAS. In MODES 5 and 6, the three channels must be OPERABLE whenever the associated DG is required to be OPERABLE to ensure that the automatic start of the DG is available when needed. Loss of the LOP DG Start Instrumentation Function could result in the delay of safety systems initiation when required. This could lead to unacceptable consequences during accidents. During the loss of offsite power the DG powers the motor driven auxiliary feedwater pumps. Failure of these pumps to start would leave only one turbine driven pump, as well as an increased potential for a loss of decay heat removal through the secondary system.

BASES

APPLICABILITY The LOP DG Start Instrumentation Functions are required in MODES 1, 2, 3, and 4 because ESF Functions are designed to provide protection in these MODES. Actuation in MODE 5 or 6 is required whenever the required DG must be OPERABLE so that it can perform its function on an LOP or degraded power to the vital bus.

ACTIONS A channel shall be OPERABLE if the point at which the channel trips is found more conservative than the Allowable Value. In the event a channel's trip setpoint is found less conservative than the Allowable Value, or the transmitter, instrument loop, signal processing electronics, or bistable is found inoperable, then all affected Functions provided by that channel must be declared inoperable and the LCO Condition(s) entered for the protection Function(s) affected. If plant conditions warrant, the trip setpoint may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the trip setpoint is conservative with respect to the NOMINAL TRIP SETPOINT. If the trip setpoint is found outside of the NOMINAL TRIP SETPOINT calibration tolerance band and non-conservative with respect to the NOMINAL TRIP SETPOINT, the setpoint shall be re-adjusted.

Because the required channels are specified on a per bus basis, the Condition may be entered separately for each bus as appropriate.

A Note has been added in the ACTIONS to clarify the application of Completion Time rules. The Conditions of this Specification may be entered independently for each Function listed in the LCO. The Completion Time(s) of the inoperable channel(s) of a Function will be tracked separately for each Function starting from the time the Condition was entered for that Function.

A.1

Condition A applies to the LOP DG start Function with one loss of voltage or degraded voltage channel per bus inoperable.

If one channel is inoperable, Required Action A.1 requires that channel to be placed in trip within 6 hours. With a channel in trip, the LOP DG start instrumentation channels are configured to provide a one-out-of-two logic to initiate a trip of the incoming offsite power.

The specified Completion Time is reasonable considering the Function remains fully OPERABLE on every bus and the low probability of an event occurring during these intervals.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 179 TO FACILITY OPERATING LICENSE NPF-35
AND AMENDMENT NO. 171 TO FACILITY OPERATING LICENSE NPF-52
DUKE ENERGY CORPORATION, ET AL.
CATAWBA NUCLEAR STATION, UNITS 1 AND 2
DOCKET NOS. 50-413 AND 50-414

1.0 INTRODUCTION

By letter dated March 25, 1999, Duke Energy Corporation (the licensee) submitted a request to amend the facility operating licenses NPF-35 and NPF-52 for Catawba Nuclear Station, Units 1 and 2. The proposed amendments would revise those parts of the station's Technical Specifications (TS) regarding reactor trip system (RTS) and engineered safety features actuation system (ESFAS) instrumentation trip setpoints (TSP) as follows:

- Remove the inequality signs applied to the TRIP SETPOINT column of TS Tables 3.3.1-1, "Reactor Trip System Instrumentation," and 3.3.2-1, "Engineered Safety Feature Actuation System Instrumentation," and revise the TRIP SETPOINT column heading to read "NOMINAL TRIP SETPOINT." Also change Notes 1 and 2 of this table to replace "TRIP SETPOINT" with "NOMINAL TRIP SETPOINT."
- Add the definition of NOMINAL TRIP SETPOINT to Section 1.1.
- Change the column heading "TRIP SETPOINT" in Table 3.3.6-1, "Containment Purge and Exhaust Isolation Instrumentation," to "NOMINAL TRIP SETPOINT."
- Delete inequality signs in Surveillance Requirement (SR) 3.3.5.2 and change "TRIP SETPOINT" to "NOMINAL TRIP SETPOINT."
- Revise Limiting Condition for Operation (LCO) 3.4.12, "Low Temperature Overpressure Protection (LTOP) System," to remove inequality signs from the lift setting value (400 psig) and change "LIFT SETTING" to "NOMINAL LIFT SETTING."
- Delete the response time associated with Functions 11 and 12 in TS Table 3.3.1-1.
- Change the TS Bases to correspond with the TS revisions.

2.0 BACKGROUND

The staff identified a generic concern during inspections at the Watts Bar and Sequoyah plants. The concern deals with the nominal values associated with tolerances beyond maximum and minimum TSPs (inequalities) shown in the TS. The staff concluded that the existing practice of

setting the TSP in a manner inconsistent with the Improved Technical Specifications (ITS) TSP inequalities would render the instrument inoperable on the basis of the ITS surveillance requirements, LCOs, and Actions/Conditions. The inequalities were being interpreted as limits that would require entry into the appropriate LCO remedial action when exceeded.

The staff has identified a similar concern at the Vogtle plant. The licensee for Vogtle chose to revise the Vogtle TS to adopt the term "NOMINAL TRIP SETPOINT" and to allow calibration tolerance bands (lower and upper bands) around the TSP value. This approach was consistent with the licensee's setpoint methodology and previous revisions to the ITS, and was found acceptable by the staff. The licensee for Catawba has taken a similar approach to resolve the concern.

3.0 EVALUATION

The proposed changes by the licensee and the staff's evaluation of the changes are discussed below:

3.1 Tables 3.3.3-1 and 3.3.2-1

The licensee proposed to delete the inequality signs as applied to the TSP column of Tables 3.3.1-1 and 3.3.2-1. The licensee also proposed to revise the TSP column to read "NOMINAL TRIP SETPOINT." In addition the licensee proposes to add the definition of NOMINAL TRIP SETPOINT to Section 1.1.

The licensee has defined the limiting safety system setting (LSSS) to be the allowable value, and the nominal TSP is the value set into the instrument. In accordance with the setpoint methodology used at Catawba, no action is required as long as the LSSS value is not exceeded, and it is acceptable for the applicable safety-related instrumentation as-left TSP to be exceeded by the instrumentation calibration setting tolerances.

The removal of the inequality signs from the TSPs as assigned to Tables 3.3.1-1 and 3.3.2-1 is consistent with the licensee's setpoint methodology and the ITS as revised by the staff (Watts Bar ITS). The removal of the inequality signs from the TSP value will allow the licensee to set the TSP value consistent with the two-sided calibration tolerance defined in the setpoint methodology.

The Bases associated with these TS sections provide clarifying information related to the as-left setpoints for the RTS and ESFAS instrumentation. The Bases allow for a channel to be considered operable with a nominal TSP found outside its calibration tolerance band, provided the TSP value is conservative with respect to its allowable value and is readjusted to within the established tolerance band of the nominal TSP. The Bases section also clarifies that if the plant condition warrants, the TSP may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the TSP is conservative with respect to the NOMINAL TRIP SETPOINT.

The licensee has added the definition of NOMINAL TRIP SETPOINT in TS Section 1.1 to incorporate the details previously discussed herein and reads as follows:

The NOMINAL TRIP SETPOINT shall be the design value of a setpoint. The TSP implemented in plant hardware may be less or more conservative than the NOMINAL TRIP SETPOINT by a calibration tolerance. If plant conditions warrant, the TSP implemented in plant hardware may be set outside the NOMINAL TRIP SETPOINT calibration tolerance band as long as the TSP is conservative with respect to the NOMINAL TRIP SETPOINT.

The staff finds the proposed changes acceptable as these changes are consistent with the licensee's setpoint methodology.

3.2 Table 3.3.6-1

The licensee proposed to revise the column heading "TRIP SETPOINT" in Table 3.3.6-1 to read "NOMINAL TRIP SETPOINT."

Table 3.3.6-1 contains the requirements for containment purge and exhaust isolation instrumentation and identifies no additional setpoint requirements beyond those already specified in Table 3.3.2-1 for ESFAS instrumentation. The licensee proposed this administrative change solely to ensure consistency with Table 3.3.2-1. The staff finds this change acceptable.

3.3 SR 3.3.5.2

The licensee proposed to change TRIP SETPOINT to NOMINAL TRIP SETPOINT and to delete the inequality sign. The licensee also proposed to revise the Bases section to incorporate these changes.

This change has been discussed above in Section 3.1 and is, therefore, acceptable to the staff.

3.4 Section 3.4.12

The licensee proposed to revise the LCO to change "LIFT SETTING" to "NOMINAL LIFT SETTING" and to remove the inequality sign from the NOMINAL LIFT SETTING value.

The licensee proposed this change because its review of the safety analyses associated with the power-operated relief valve in the LTOP mode of operation has indicated that the as-left lift setting is indeed a nominal value. The proposed change will thus more accurately describe the nature of the lift setpoint, i.e. as nominal. The staff finds this change acceptable.

3.5 Functions 11 and 12 of Table 3.3.1-1

The licensee proposed to delete the response time associated with Functions 11 and 12 in Table 3.3.1-1.

Functions 11 and 12 pertain to the undervoltage and the underfrequency condition for the reactor coolant pumps. These functions identify a 0.7- and a 0.2-second response time, respectively. The term "response time" is misleading as these values are, in reality, time delays incorporated into the trip circuits to prevent spurious trips. The licensee's justification for removing these time delays from the TS is based on the fact that overall reactor trip response

times (1.5 seconds and 0.6 seconds, respectively) must be met for these functions, which will account for the time delays. Also, the Westinghouse Standard TS (NUREG-1431) do not specify inclusion of these time delays in the TS. On the basis of this information, the staff finds the proposed change acceptable.

3.6 Summary of Staff Evaluation

The staff finds the licensee's proposed TS changes to be acceptable. The proposed changes are consistent with the licensee's setpoint methodology regarding nominal TSP, the Westinghouse Standard TS, NUREG-1431 (two-column format) and the guidance of Regulatory Guide 1.105, Revision 2. The removal of the setpoint column inequalities is consistent with the use of a nominal TSP by the licensee. As delineated above, the staff found the proposed TS changes for RTS and ESFAS acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, South Carolina State official Mr. Virgil Autrey was notified of the proposed issuance of the amendments to Catawba. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20, and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The staff has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (64 FR 24195 dated May 5, 1999). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: Hukam C. Garg

Date: August 13, 1999