

Mr. M. S. Tuckman
 Senior Vice President
 Nuclear Generation
 Duke Power Company
 P. O. Box 1006
 Charlotte, NC 28201

August 17 1995

SUBJECT: ISSUANCE OF SCHEDULAR EXEMPTION FROM THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX J, FOR CATAWBA NUCLEAR STATION UNIT NO. 2 REGARDING DELAY OF NEXT REQUIRED TYPE A LEAKAGE RATE TEST (TAC NO. M92382)

Dear Mr. Tuckman:

By letters dated May 18 and 31, 1995, Duke Power Company requested a one-time schedular exemption to delay performance of a Type A test, as required by 10 CFR Part 50, Appendix J, for a period of approximately 30 months.

The NRC staff has reviewed the information provided in support of your schedular exemption request. On the basis of the submitted information and as discussed in the enclosed Exemption, the NRC staff has concluded that there is a high degree of confidence that the containment will not degrade to an unacceptable extent while this exemption is in effect. Thus, the NRC staff has concluded that your request is justified and your request for a schedular exemption to delay performance of the Type A test until the 1997 refueling outage is granted.

We find that granting the exemption from the requirements of 10 CFR Part 50, Appendix J, Section III.D.1.(a), is authorized by law, will not present an undue risk to the public health and safety, is consistent with the common defense and security, and meets the special circumstances described in 10 CFR 50.12(a)(2)(ii).

A copy of the Exemption is enclosed. The Exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY L.L.WHEELER f/

Herbert N. Berkow, Director
 Project Directorate II-2
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Docket No. 50-414

Enclosure: Exemption

cc w/encl: See next page

BC: SSS, OSSA, JCP
 C. Berlin
 8/13/95

DISTRIBUTION:
~~SECRET~~
 PUBLIC
 PD22 Reading
 J. Zwolinski
 R. Spessard, DOTS
 G. Tracy, EDO
 R. Crljenjak, RII
 E. Merschoff, RII
 E. Jordan, AEOD
 S. Varga, NRR
 R. Zimmerman, NRR
 J. Lieberman, OE
 W. Russell/F. Miraglia, NRR
 OGC
 ACRS (4)
 G. Hill (2)
 S. Varga

OFFICE	PDII-3/PM	PDII-3/PM	OGC* per concurrence for Exemption	PDIA-3/D	DRPE/D
NAME	L. BERRY	R. MARTIN		H. BERKOW	S. VARGA
DATE	7/10/95	7/16/95	8/17/95	8/17/95	8/17/95

OFFICIAL RECORD COPY

FILE NAME: G:\CATAWBA\CAT92382.EXE

9508240251 950817
 PDR ADOCK 05000414
 P PDR

185

NRC FILE CENTER COPY

DFD
 52-3

Mr. M. S. Tuckman
 Senior Vice President
 Nuclear Generation
 Duke Power Company
 P. O. Box 1006
 Charlotte, NC 28201

August 17 1995

SUBJECT: ISSUANCE OF SCHEDULAR EXEMPTION FROM THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX J, FOR CATAWBA NUCLEAR STATION UNIT NO. 2 REGARDING DELAY OF NEXT REQUIRED TYPE A LEAKAGE RATE TEST (TAC NO. M92382)

Dear Mr. Tuckman:

By letters dated May 18 and 31, 1995, Duke Power Company requested a one-time schedular exemption to delay performance of a Type A test, as required by 10 CFR Part 50, Appendix J, for a period of approximately 30 months.

The NRC staff has reviewed the information provided in support of your schedular exemption request. On the basis of the submitted information and as discussed in the enclosed Exemption, the NRC staff has concluded that there is a high degree of confidence that the containment will not degrade to an unacceptable extent while this exemption is in effect. Thus, the NRC staff has concluded that your request is justified and your request for a schedular exemption to delay performance of the Type A test until the 1997 refueling outage is granted.

We find that granting the exemption from the requirements of 10 CFR Part 50, Appendix J, Section III.D.1.(a), is authorized by law, will not present an undue risk to the public health and safety, is consistent with the common defense and security, and meets the special circumstances described in 10 CFR 50.12(a)(2)(ii).

A copy of the Exemption is enclosed. The Exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY L.L.WHEELER f/

Herbert N. Berkow, Director
 Project Directorate II-2
 Division of Reactor Projects - I/II
 Office of Nuclear Reactor Regulation

Docket No. 50-414

Enclosure: Exemption

cc w/encl: See text page

DISTRIBUTION:
 Docket File R.Crlenjak, RII OGC
 PUBLIC E.Merschhoff, RII ACRS (4)
 PD22 Reading E.Jordan, AEOD
 J.Zwolinski S.Varga, NRR G.Hill(2)
 R.Spessard, DOTS R.Zimmerman, NRR S.Varga
 G.Tracy, EDO J.Lieberman, OE
 W.Russell/F.Miraglia, NRR

BC: SSA, SSA JCP
 C. Berling
 8/13/95

OFFICE	PDII-3/PM	PDII-3/PM	OGC* per concurrence of Exemption	PDII-3/D	DRPE/D
NAME	L. BERRY	R. MARTIN		H. BERKOW	S. VARGA
DATE	7/12/95	7/16/95	8/17/95	8/17/95	8/17/95

OFFICIAL RECORD COPY

FILE NAME: G:\CATAWBA\CAT92382.EXE



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 17, 1995

Mr. M. S. Tuckman
Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1006
Charlotte, NC 28201

SUBJECT: ISSUANCE OF SCHEDULAR EXEMPTION FROM THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX J, FOR CATAWBA NUCLEAR STATION UNIT NO. 2 REGARDING DELAY OF NEXT REQUIRED TYPE A LEAKAGE RATE TEST (TAC NO. M92382)

Dear Mr. Tuckman:


By letters dated May 18 and 31, 1995, Duke Power Company requested a one-time schedular exemption to delay performance of a Type A test, as required by 10 CFR Part 50, Appendix J, for a period of approximately 30 months.

The NRC staff has reviewed the information provided in support of your schedular exemption request. On the basis of the submitted information and as discussed in the enclosed Exemption, the NRC staff has concluded that there is a high degree of confidence that the containment will not degrade to an unacceptable extent while this exemption is in effect. Thus, the NRC staff has concluded that your request is justified and your request for a schedular exemption to delay performance of the Type A test until the 1997 refueling outage is granted.

We find that granting the exemption from the requirements of 10 CFR Part 50, Appendix J, Section III.D.1.(a), is authorized by law, will not present an undue risk to the public health and safety, is consistent with the common defense and security, and meets the special circumstances described in 10 CFR 50.12(a)(2)(ii).

A copy of the Exemption is enclosed. The Exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,


Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-414

Enclosure: Exemption

cc w/encl: See next page

Duke Power Company

cc:

Mr. Z. L. Taylor
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Dayne H. Brown, Director
Division of Radiation Protection
N.C. Department of Environment,
Health and Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Catawba Nuclear Station

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Senior Resident Inspector
4830 Concord Road
York, South Carolina 29745

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

Mr. William R. McCollum
Site Vice President
Catawba Nuclear Station
Duke Power Company
4800 Concord Road
York, South Carolina 29745

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
DUKE POWER COMPANY, ET AL.)	Docket No. 50-414
)	
(Catawba Nuclear Station,)	
Unit No. 2))	

EXEMPTION

I.

The Duke Power Company, et al. (DPC or the licensee) is the holder of Facility Operating License No. NPF-52, which authorizes operation of the Catawba Nuclear Station, Unit No. 2 (the facility), at a steady-state reactor power level not in excess of 3411 megawatts thermal. The facility is a pressurized water reactor located at the licensee's site in York County, South Carolina. The license provides, among other things, that the Catawba Nuclear Station is subject to all rules, regulations, and Orders of the U.S. Nuclear Regulatory Commission (the Commission or NRC) now or hereafter in effect.

II.

Section III.D.1.(a) of Appendix J to 10 CFR Part 50 requires the performance of three Type A containment integrated leakage rate tests (ILRTs) at approximately equal intervals during each 10-year service period of the primary containment. The third test of each set shall be conducted when the plant is shut down for the 10-year inservice inspection of the primary containment.

9508240278 950817
PDR ADOCK 05000414
P PDR

III.

By letters dated May 18, 1995, and May 31, 1995, the licensee requested temporary relief from the requirement to perform a set of three Type A tests at approximately equal intervals during each 10-year service period of the primary containment. The requested exemption would permit a one-time interval extension of the third Type A test by approximately 30 months (from the 1995 refueling outage, which begins in October 1995, to the end-of-cycle 8 (EOC-8) refueling outage, currently scheduled for March 1997) and would permit the third Type A test of the second 10-year inservice inspection period to not correspond with the end of the current inservice inspection interval.

The licensee's request concluded that the proposed change, a one-time extension of the interval between the second and third ILRTs at Catawba Unit 2, is justified for the following reasons.

The previous testing history at Catawba Unit 2 provides substantial justification for the proposed test interval extension. In each of the two previous periodic ILRTs at Catawba Unit 2, the as-found leakage was less than or equal to 48.7% of the allowable leakage, thereby demonstrating that Catawba Unit 2 is a low-leakage containment. There are no mechanisms which would adversely affect the structural integrity of the containment, or that would be a factor in extending the test interval by 30 months. However, as a preventative maintenance measure, a containment civil inspection, currently required by Appendix J prior to a Type A test, will be performed during EOC-7 in October 1995 to verify that no structural degradation exists. Any additional risk created by the longer interval between ILRTs is considered to be negligible, primarily because Type B and C testing will continue unchanged.

Additionally, the licensee stated that its exemption request meets the requirements of 10 CFR 50.12, paragraphs (a)(1) and (a)(2)(ii), for the following reasons:

In order to justify the granting of an exemption to the requirements of 10 CFR Part 50, paragraph 50.12(a)(1) requires that the licensee show that the proposed exemption will not pose an undue risk to the public. That this proposed change will not pose an undue risk is demonstrated by the analysis presented in draft NUREG-1493, which concludes that an increase in the test interval to once every 20 years would "lead to an imperceptible increase in risk." The analyses in draft NUREG-1493 are considered to be specifically applicable to Catawba because: 1) the requested exemption would result in a one-time increase in the test interval to about 5 years, not 20; 2) the population density around Catawba is less than that used in the study (329 people per square mile, vs. 340 used in the study); 3) no ILRT at Catawba has failed; 4) the core inventory used in the study was represented by a 3412 Mwt PWR [pressurized water reactor]. Catawba is a 3411 Mwt PWR. Other factors which lead to the conclusion that the proposed change will not pose an undue risk include the fact that local leak rate testing, which identifies 97% of leakage in excess of prescribed limits, will remain in place at its current test frequency; the detailed, proceduralized containment civil inspection which is normally performed in conjunction with an ILRT will be performed in place of the scheduled ILRT, to identify potential structural deteriorations; and the historical leak-tightness of the containment structure, as evidenced by two successive ILRTs in which the as-found leakage did not exceed 48.7% of the allowable leakage rate. A table which shows the leak test history of Catawba Unit 2 follows this Attachment.

A comparison was made between the risk analysis presented in draft NUREG-1493 and a probabilistic risk assessment performed for Catawba Nuclear Station. While the quantitative results of the NUREG are not directly applicable to plants not used in the study, conclusions similar to those presented in the NUREG can be made concerning Catawba. NUREG-1493 indicates that reactor accident risks are dominated by accident sequences that result in failure or bypass of the containment. This conclusion is also valid for Catawba. Considering only the Catawba accident sequences that do not result in containment failure, containment leakage contributes approximately 0.08 to 0.09 percent to off-site risk (whole-body person-rem, thyroid nodules, and latent fatalities). NUREG-1493 indicated that containment leakage contributed from 0.02 to 0.10 percent to latent cancer risk. The comparison between the analysis of NUREG-1493 and the Catawba PRA concludes that increases in containment leakage at Catawba are expected to produce increases in accident risk similar to the results in NUREG-1493.

Special circumstances, as defined in 10 CFR 50.12(a)(2)(ii), are considered to exist if "application of the regulation ... is not necessary to achieve the underlying purpose of the rule." The purposes of

of the rule, as stated in Section I of Appendix J, are to ensure that:

- a) leakage through the primary reactor containment and systems and components penetrating containment shall not exceed allowable values, and
- b) periodic surveillance of reactor containment penetrations and isolation valves is performed so that proper maintenance and repairs are made.

One of the significant factors in assuring that the proposed exemption will not pose an undue risk to the public, as noted above, is the local leak rate testing (LLRT) which is performed. That the LLRT program at Catawba provides an effective mechanism for maintaining containment integrity is perhaps best demonstrated by the fact that the most recent ILRT at Catawba Unit 2 was performed at the front end of the refueling outage; before any repairs or adjustments were made to valves or penetrations. Nevertheless, the as-found leakage did not exceed 48.7% of the allowable leakage rate. The fact that no leakage paths were identified by an ILRT, and that the ILRT met the acceptance criteria with significant margin confirms the results of the Type B and C testing.

The frequency and scope of the Type B and C LLRT program are not being changed by this exemption request. The LLRT program will continue to effectively detect containment leakage resulting from the degradation of active containment isolation components, as well as containment penetrations. Administrative limits have been established for each Type B or C component at a fraction of the allowable leak rate, such that any leakage detected in excess of the administrative limit will indicate a potential valve or penetration degradation. In instances in which a component's leakage exceeds its administrative limit, proceduralized controls in the test program require that a work order be written to repair the component.

IV.

Section III.D.1.(a) of Appendix J to 10 CFR Part 50 states that a set of three Type A leakage rate tests shall be performed at approximately equal intervals during each 10-year service period.

The licensee proposes an exemption to this section which would provide a one-time interval extension for the Type A test by approximately 30 months. The Commission has determined that, pursuant to 10 CFR 50.12(a)(1), this exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. The Commission further determined, for the reasons discussed below, that special circumstances, as provided in 10 CFR 50.12(a)(2)(ii), are present

justifying the exemption; namely, that application of the regulation in the particular circumstances is not necessary to achieve the underlying purpose of the rule. The underlying purpose of the requirement to perform Type A containment leak rate tests at approximately equal intervals during the 10-year service period, is to ensure that any potential leakage pathways through the containment boundary are identified within a time span that prevents significant degradation from continuing or becoming unknown. The NRC staff has reviewed the basis and supporting information provided by the licensee in the exemption request. The NRC staff has noted that the licensee has a good record of ensuring a leak-tight containment. All Type A tests have passed with significant margin and the licensee has noted that the results of the Type A testing have been confirmatory of the Type B and C tests which will continue to be performed. The licensee has stated that it will continue to perform the general containment civil inspection although it is only required by Appendix J (Section V.A.) to be performed in conjunction with Type A tests. The NRC staff considers that these inspections, though limited in scope, provide an important added level of confidence in the continued integrity of the containment boundary.

The NRC staff has also made use of a draft staff report, NUREG-1493, which provides the technical justification for the present Appendix J rulemaking effort which also includes a 10-year test interval for Type A tests. The integrated leakage rate test, or Type A test, measures overall containment leakage. However, operating experience with all types of containments used in this country demonstrates that essentially all containment leakage can be detected by local leakage rate tests (Type B and C). According to results given in NUREG-1493, out of 180 ILRT reports

covering 110 individual reactors and approximately 770 years of operating history, only 5 ILRT failures were found that local leakage rate testing could not detect. This is 3% of all failures. This study agrees with previous NRC staff studies which show that Type B and C testing can detect a very large percentage of containment leaks. The Catawba Unit 2 experience has also been consistent with this.


The Nuclear Management and Resources Council (NUMARC), now the Nuclear Energy Institute (NEI), collected and provided the NRC staff with summaries of data to assist in the Appendix J rulemaking effort. NUMARC collected results of 144 ILRTs from 33 units; 23 ILRTs exceeded $1.0L_a$. Of these, only nine were not due to Type B or C leakage penalties. The NEI data also added another perspective. The NEI data show that in about one-third of the cases exceeding allowable leakage, the as-found leakage was less than $2L_a$; in one case the leakage was found to be approximately $2L_a$; in one case the as-found leakage was less than $3L_a$; one case approached $10L_a$; and in one case the leakage was found to be approximately $21L_a$. For about half of the failed ILRTs, the as-found leakage was not quantified. These data show that, for those ILRTs for which the leakage was quantified, the leakage values are small in comparison to the leakage value at which the risk to the public starts to increase over the value of risk corresponding to L_a (approximately $200L_a$, as discussed in NUREG-1493).

Based on generic and plant-specific data, the NRC staff finds the licensee's proposed one-time exemption to permit a schedular extension of one cycle for the performance of the Appendix Type A test to be acceptable.

Pursuant to 10 CFR 51.32, the Commission has determined that granting this exemption will not have a significant impact on the human environment (60 FR 32567).

This exemption is effective upon issuance and shall expire at the completion of the 1997 refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION



Steven A. Varga, Director
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland,
this 17th day of August 1995

Pursuant to 10 CFR 51.32, the Commission has determined that granting this exemption will not have a significant impact on the human environment (60 FR 32567).

This exemption is effective upon issuance and shall expire at the completion of the 1997 refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION

ORIGINAL SIGNED BY:

Steven A. Varga, Director
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Dated at Rockville, Maryland,
this 17th day of August 1995

BC: SCSB/...
C Berlinger
8/13/95

OFFICE	PDII-2/NA	PDII-2/PM	OGC	NOTE	PDII-2/B	DPRE/D
NAME	L. BERRY	R. MARTIN	CM/CO	Changes	H. BERKOW	S. VARGA
DATE	7/18/95	7/16/95	8/17/95		8/17/95	8/17/95

OFFICIAL RECORD COPY

FILE NAME: G:\CATAWBA\CAT92382.EXE