November 5, 1986

Docket Nos. 50-348 and 50-364

Mr. R. P. McDonald Senior Vice President Alabama Power Company Post Office Box 2641 Birmingham, Alabama 35291-0400

Dear Mr. McDonald:

DISTRIBUTION Docket File J. Partlow T. Barnhart (8) NRC PDR W. Jones Local PDR E. Butcher PAD#2 Rdg N. Thompson T. Novak V. Benaroya D. Miller ACRS (10) E. Reeves (2) C. Miles, OPA OGC-Bethesda L. Tremper, LFMB L. Harmon Gray File E. Jordan R. KARSCH B. Grimes BERLINGER

The Commission has issued the enclosed Amendment No. 68 to Facility Operating License No. NPF-2 and Amendment No. 60 to NPF-8 for the Joseph M. Farley Nuclear Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated July 3, 1986, supplemented August 27, 1986.

The amendments revise Technical Specifications 3.1.2.5.b.2 and 3.5.1.c by increasing the boron concentration limits by 300 ppm in the Refueling Water Storage Tank and in the reactor coolant system accumulators. By letter dated August 27, 1986, you requested changes to the implementation schedule for the amendments. The proposed schedule is reflected in the license amendment paragraph 3. for each unit.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular bi-weekly Federal Register notice.

Sincerely,

/s/

Edward A. Reeves, Project Manager PWR Project Directorate #2 Division of PWR Licensing-A Office of Nuclear Reactor Regulation

Enclosures: 1. Amendment No.68 to NPF-2 Amendment No.60 to NPF-8 2. Safety Evaluation 3. cc: w/enclosures See next page OGC PM: 1 Rube stein EReeves:hc 10/**<</**86 10/14/86 10/**31**/86 10/2 *५*/86 8612040123 861105 PDR 05000348 ADOCK

Mr. R. P. McDonald Alabama Power Company

cc: Mr. W. O. Whitt Executive Vice President Alabama Power Company Post Office Box 2641 Birmingham, Alabama 35291-0400

Mr. Louis B. Long, General Manager Southern Company Services, Inc. Post Office Box 2625 Birmingham, Alabama 35202

Chairman Houston County Commission Dothar, Alabama 36301

Ernest L. Blake, Jr., Esquire Shaw, Pittman, Potts and Trowbridge 2300 N Street, N.W. Washington, DC 20037

Robert A. Buettner, Esquire Balch, Bingham, Baker, Hawthorne, Williams and Ward Post Office Box 306 Birmingham, Alabama 35201

Resident Inspector U.S. Nuclear Regulatory Commission Post Office Box 24 - Route 2 Columbia, Alabama 36319 Joseph M. Farley Nuclear Plant

D. Biard MacGuineas, Esquire Volpe, Boskey and Lyons 918 16th Street, N.W. Washington, DC 20006

Charles R. Lowman Alabama Electric Corporation Post Office Box 550 Andalusia, Alabama 36420

Regional Administrator, Region II U.S. Nuclear Regulatory Commissior 101 Marietta Street, Suite 2900 Atlanta, Georgia 30303

Claude Earl Fox, M.D. State Health Officer State Department of Public Health State Office Building Montgomery, Alabama 36130

Mr. J. D. Woodard General Manager - Nuclear Plant Post Office Box 470 Ashford, Alabama 36312

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555



DOCKET NO. 50-348

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 68 License No. NPF-2

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Alabama Power Company (the licensee) dated July 3, 1986, supplemented August 27, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-2 is hereby amended to read as follows:



Solution of the second se

REGU

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 68, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

 This license amendment is effective as of its date of issuance and shall be implemented during Modes 5 and 6 of the eighth refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION

() Lester S. Rubenstein, Director

J PWR Project Directorate #2 Division of PWR Licensing-A Office of Nuclear Reactor Regulation

Attachment: Charges to the Technical Specifications

Date of Issuance: November 5, 1986

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 68

TO FACILITY OPERATING LICENSE NO. NPF-2

DOCKET NO. 50-348

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Remove Pages	Insert Pages
3/4 1-11	3/4 1-11
3/4 1-12	3/4 1-12
3/4 5-1	3/4 5-1
3/4 5-11	3/4 5-11
B3/4 1-3	B3/4 1-3
B3/4 5-2	B3/4 5-2

BORATED WATER SOURCES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A boric acid storage system with:
 - 1. A minimum contained borated water volume of 2000 gallons,
 - 2. Between 7000 and 7700 ppm of boron, and
 - 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1. A minimum contained borated water volume of 30,000 gallons,
 - 2. A minimum boron concentration of 2300 ppm, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 5 and 6.

ACT10%:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.

SURVEILLANCE REDUIREMENTS

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1. Verifying the boron concentration of the water,
 - 2. Verifying the contained borated water volume, and
 - 3. Verifying the boric acid storage tank solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the RWST temperature when it is the source of borated water and the outside air temperature is less than 35°F.

FARLEY-UNIT 1

AMENDMENT NO. 28,63

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2:

- a. A boric acid storage system with:
 - 1. A minimum contained borated water volume of 11,336 gallons,
 - 2. Between 7000 and 7700 ppm of boron, and
 - 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1. A minimum contained borated water volume of 471,000 gallons,
 - 2. Retween 2300 and 2500 ppm of boron, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTI04:

- a. With the boric acid storage system inoperable and being used as one of the above required borated water sources, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F; restore the boric acid storage system to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3/4.5 EMERGENCY CORE COOLING SYSTEMS (ECCS)

3/4.5.1 ACCUMULATORS

· ·

LIMITING CONDITION FOR OPERATION

3.5.1 Each reactor coolant system accumulator shall be OPERABLE with:

- a. The isolation valve open,
- b. A contained borated water volume of between 7,555 (31.4%) and 7,780 (58.4%) gallons,
- c. A boron concentration of between 2200 and 2500 ppm, and
- d. A nitrogen cover-pressure of between 601 and 649 psig.

APPLICABILITY: MODES 1, 2 and 3.*

ACTION:

- a. With one accumulator inoperable, except as a result of a closed isolation valve, restore the inoperable accumulator to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With one accumulator inoperable due to the isolation valve being closed, either immediately open the isolation valve or be in at least HOT STANDBY within one hour and in HOT SHUTDOWN within the following 12 hours.

SURVEILLANCE REDUIREMENTS

4.5.1.1 Each accumulator shall be demonstrated OPERABLE:

- a. At least once per 12 hours by:
 - 1. Verifying the contained borated water volume and nitrogen cover-pressure in the tanks, and
 - 2. Verifying that each accumulator isolation valve is open.

*Pressurizer Pressure above the P-11 setpoint.

FARLEY-UNIT 1

AMENDMENT NO. 26,68

t

EMERGENCY CORE COOLING SYSTEMS

SU. FILLANCE REQUIREMENTS (Continued)

- b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the accumulator solution.
- c. At least once per 31 days when the RCS pressure is above the P-11 setpoint by verifying that power to each isolation valve operator is disconnected by a locked open disconnect device.
- d. At least once per 18 months by verifying that each accumulator isolation valve opens automatically under each of the following conditions:
 - When the RCS pressure (actual or simulated) exceeds the P-11 (Pressurizer Pressure Block of Safety Injection) setpoint,
 - 2. Upon receipt of a safety injection test signal.

EMERGENCY CORE COOLING SYSTEMS

3/4.5.5 REFUELING WATER STORAGE TANK

LIMITING CONDITION FOR OPERATION

3.5.5 The refueling water storage tank (RWST) shall be OPERABLE with:

- A minimum contained borated water volume of 471,000 gallons, а.
- b. A boron concentration of between 2300 and 2500 ppm of boron, and
- c. A minimum water temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the refueling water storage tank inoperable, restore the tank to OPERAFLE status within 1 hour or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.5.5 The RWST shall be demonstrated OPERABLE:

- At least once per 7 days by: а.
 - 1. Verifying the contained borated water volume in the tank, and
 - 2. Verifying the boron concentration of the water.
- At least once per 24 hours by verifying the RWST temperature when b. the outside air temperature is less than 35°F.

FARLEY-UNIT 1

BASES

BORATION SYSTEMS (Continued)

MARGIN from expected operating conditions of 1.77% delta k/k after xenon decay and cooldown to 200°F. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires 11,335 gallons of 7000 ppm borated water from the boric acid storage tanks or 44,826 gallons of 2300 ppm borated water from the refueling water storage tank.

With the RCS temperature below 200°F, one injection system is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity changes in the event the single injection system becomes inoperable.

The limitation for a maximum of one centrifugal charging pump to be OPERABLE and the Surveillance Requirement to verify all charging pumps excent the required OPERABLE pump to be inoperable below 180°F provides assurance that a mass addition pressure transient can be relieved by the operation of a single RHR relief valve.

The boron capability required below 200°F is sufficient to provide a SHUTDOWN MARGIN of 1% delta k/k after xenon decay and cooldown from 200°F to 140°F. This condition requires either 2,000 gallons of 7000 ppm borated water from the boric acid storage tanks or 7,750 gallons of 2300 ppm borated water from the refueling water storage tank.

The contained water volume limits include allowance for water not available because of discharge line location and other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 8.5 and 11.0 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

The OPERABILITY of one boron injection system during REFUELING ensures that this system is available for reactivity control while in MODE 6.

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

The specifications of this section ensure that (1) acceptable power distribution limits are maintained, (2) the minimum SHUTDOWN MARGIN is maintained, and (3) limit the potential effects of rod misalignment on associated accident analyses. OPERABILITY of the control rod position indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits.

FARLEY-UNIT 1

AMENDMENT NO. 28,68

BASES

For purposes of determining compliance with Technical Specification 3.1.3.1, any inoperability of full length control rod(s), due to being immovable, invokes ACTION statement "a".

The intent of Technical Specification 3.1.3.1 ACTION statement "a" is to ensure that before leaving ACTION statement "a" and utilizing ACTION statement "c" that the rod urgent failure alarm is illuminated or that an obvious electrical problem is detected in the rod control system by minimal electrical troubleshooting techniques. Expeditious action will be taken to determine if rod immovability is due to an electrical problem in the rod control system.

The ACTION statements which permit limited variations from the basic requirements are accompanied by additional restrictions which ensure that the original design criteria are met. Misalignment of a rod requires measurement of peaking factors or a restriction in THERMAL POWER; either of these restrictions provide assurance of fuel rod integrity during continued operation. In addition, those safety analyses affected by a misaligned rod are reevaluated to confirm that the results remain valid during future operation.

The maximum rod drop time restriction is consistent with the assumed rod drop time used in the safety analyses. Measurement with T_{avg} greater than or equal to 541°F and with all reactor coolant pumps operating ensures that the measured drop times will be representative of insertion times experienced during a reactor trip at operating conditions.

Control rod positions and OPERABILITY of the rod position indicators are required to be verified on a nominal basis of once per 12 hours with more frequent verifications required if an automatic monitoring channel is inoperable. These verification frequencies are adequate for assuring that the applicable LCO's are satisfied.

3/4.5 EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.1 ACCUMULATORS

The OPERABILITY of each Reactor Coolant System (RCS) accumulator ensures that a sufficient volume of borated water will be immediately forced into the reactor core through each of the cold legs in the event the RCS pressure falls below the pressure of the accumulators. This initial surge of water into the core provides the initial cooling mechanism during large RCS pipe ruptures.

The limits on accumulator volume, boron concentration and pressure ensure that the assumptions used for accumulator injection in the safety analysis are met.

The accumulator power operated isolation valves are considered to be "operating bypasses" in the context of IEEE Std. 279-1971, which requires that bypasses of a protective function be removed automatically whenever permissive conditions are not met. In addition, as these accumulator isolation valves fail to meet single failure criteria, removal of power to the valves is required.

The limits for operation with an accumulator inoperable for any reason except an isolation valve closed minimizes the time exposure of the plant to a LOCA event occurring concurrent with failure of an additional accumulator which may result in unacceptable peak cladding temperatures. If a closed isolation valve cannot be immediately opened, the full capability of one accumulator is not available and prompt action is required to place the reactor in a mode where this capability is not required.

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS

The OPERABILITY of two independent ECCS subsystems ensures that sufficient emergency core cooling capability will be available in the event of a LOCA assuming the loss of one subsystem through any single failure consideration. Either subsystem operating in conjunction with the accumulators is capable of supplying sufficient core cooling to limit the peak cladding temperatures within acceptable limits for all postulated break sizes ranging from the double ended break of the largest RCS cold leg pipe downward. In addition, each ECCS subsystem provides long term core cooling capability in the recirculation mode during the accident recovery period.

With the RCS temperature below 350°F, one OPERABLE ECCS subsystem is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the limited core cooling requirements.

FARLEY-UNIT 1

AMENDMENT NO. 26

EMERGENCY CORE COOLING SYSTEMS

BASES

The Surveillance Requirements provided to ensure OPERABILITY of each component ensures that at a minimum the assumptions used in the safety analyses are met and that subsystem OPERABILITY is maintained. Surveillance requirements for throttle valve position stops and flow balance testing provide assurance that proper ECCS flows will be maintained in the event of a LOCA. Maintenance of proper flow resistance and pressure drop in the piping system to each injection point is necessary to: (1) prevent total pump flow from exceeding runout conditions when the system is in its minimum resistance configuration, (2) provide the proper flow split between injection points in accordance with the assumptions used in the ECCS-LOCA analyses, and (3) provide an acceptable level of total ECCS flow to all injection points equal to or above that assumed in the ECCS-LOCA analyses.

3/4.5.4 BOPON INJECTION SYSTEM

THIS SPECIFICATION DELETED.

3/4.5.5 REFUELING WATER STORAGE TANK

The OPERABILITY of the Refueling Water Storage Tank (RWST) as part of the ECCS ensures that sufficient negative reactivity is injected into the core to counteract any positive increase in reactivity caused by RCS system cooldowr. RCS cooldown can be caused by inadvertent depressurization, a loss-of-coolant accident on a steam line rupture.

The OPERABILITY of the RWST as part of the ECCS also ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that 1) sufficient water is available within containment to permit recirculation cooling flow to the core, and 2) the reactor will remain subcritical in the cold condition following mixing of the RWST and the RCS water volumes with all control rods inserted except for the most reactive control assembly in the event of a small break LOCA and with no control rods inserted in the event of a large break LOCA. These assumptions are consistent with the LOCA analyses.

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

ALABAMA POWEP COMPANY

DOCKET NO. 50-364

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 60 License No. NPF-8

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Alabama Power Company (the licensee) dated July 3, 1986, supplemented August 27, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-8 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 60, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

 This license amendment is effective as of its date of issuance and shall be implemented during Modes 5 and 6 of the fifth refueling outage.

FOR THE NUCLEAR REGULATORY COMMISSION

Lester S. Rubenstein, Director

WR Project Directorate #2 Division of PWR Licensing-A Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: November 5, 1986

- 2 -

ATTACHMENT TO LICENSE AMENDMENT NO. 60

TO FACILITY OPERATING LICENSE NO. NPF-8

DOCKET NO. 50-364

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Remove Pages	<u>Insert Pages</u>
3/4 1-11	3/4 1-11
3/4 1-12	3/4 1-12
3/4 5-1	3/4 5-1
3/4 5-11	3/4 5-11
B3/4 1-3	B3/4 1-3
B3/4 5-2	B3/4 5-2

2

۰.

BORATED NATER SOURCES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.1.2.5 As a minimum, one of the following borated water sources shall be OPERABLE:

- a. A boric acid storage system with:
 - 1. A minimum contained borated water volume of 2000 gallons,

- 2. Between 7000 and 7700 ppm of boron, and
- 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1. A minimum contained borated water volume of 30,000 gallons,
 - 2. A minimum boron concentration of 2300 ppm, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 5 and 6.

ACTION:

With no borated water source OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.

SURVEILLANCE REDUIREMENTS

4.1.2.5 The above required borated water source shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1. Verifying the boron concentration of the water,
 - 2. Verifying the contained borated water volume, and
 - Verifying the boric acid storage tank solution temperature when it is the source of borated water.
- b. At least once per 24 hours by verifying the RWST temperature when it is the source of borated water and the outside air temperature is less than 35°F.

÷

BORATED WATER SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.1.2.6 As a minimum, the following borated water source(s) shall be OPERABLE as required by Specification 3.1.2.2:

- a. A boric acid storage system with:
 - 1. A minimum contained borated water volume of 11,336 gallons,
 - 2. Between 7000 and 7700 ppm of boron, and
 - 3. A minimum solution temperature of 65°F.
- b. The refueling water storage tank with:
 - 1. A minimum contained borated water volume of 471,000 gallons,
 - 2. Between 2300 and 2500 ppm of boron, and
 - 3. A minimum solution temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With the boric acid storage system inoperable and being used as one of the above required borated water sources, restore the storage system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and borated to a SHUTDOWN MARGIN equivalent to at least 1% delta k/k at 200°F; restore the boric acid storage system to OPERABLE status within the next 7 days or be in COLD SHUTDOWN within the next 30 hours.
- b. With the refueling water storage tank inoperable, restore the tank to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3/4.5 EMERGENCY CORE COOLING SYSTEMS

3/4.5.1 ACCUMULATORS

LIMITING CONDITION FOR OPERATION

3.5.1 Each reactor coolant system accumulator shall be OPERABLE with:

- a. The isolation valve open,
- b. A contained borated water volume of between 7,555 (31.4%) and 7,780 (58.4%) gallons,
- c. A boron concentration of between 2200 and 2500 ppm, and
- d. A nitrogen cover-pressure of between 601 and 649 psig.

APPLICABILITY: MODES 1, 2 and 3.*

ACTION:

- a. With one accumulator inoperable, except as a result of a closed isolation valve, restore the inoperable accumulator to OPERABLE status within one hour or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWY within the following 6 hours.
- b. With one accumulator inoperable due to the isolation valve being closed, either immediately open the isolation valve or be in at least HOT STANDBY within one hour and in HOT SHUTDOWN within the following 12 hours.

SURVEILLANCE REQUIREMENTS

4.5.1.1 Each accumulator shall be demonstrated OPERABLE:

- a. At least once per 12 hours by:
 - 1. Verifying the contained borated water volume and nitrogen cover-pressure in the tanks, and
 - 2. Verifying that each accumulator isolation valve is open.

*Pressurizer Pressure above the P-11 setpoint.

FARLEY-UNIT 2

F TRENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- b. At least once per 31 days and within 6 hours after each solution volume increase of greater than or equal to 1% of tank volume by verifying the boron concentration of the accumulator solution.
- c. At least once per 31 days when the RCS pressure is above the P-11 setpoint by verifying that power to each isolation valve operator is disconnected by a locked open disconnect device.
- d. At least once per 18 months by verifying that each accumulator isolation valve opens automatically under each of the following conditions:
 - 1. When the RCS pressure (actual or simulated) exceeds the P-11 (Pressurizer Pressure Block of Safety Injection) setpoint,
 - 2. Upon receipt of a safety injection test signal.

EMERGENCY CORE COOLING SYSTEMS

3/4.5.5 REFUELING WATER STORAGE TANK

LIMITING CONDITION FOR OPERATION

3.5.5 The refueling water storage tank (RWST) shall be OPERABLE with:

a. A minimum contained borated water volume of 471,000 gallons,

- b. A boron concentration of between 2300 and 2500 ppm of boron, and
- c. A minimum water temperature of 35°F.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With the refueling water storage tank inoperable, restore the tank to OPERABLE status within 1 hour or be in at least HOT STANDBY within 6 hours and in COLD SHUTDOW', within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.5.5 The RWST shall be demonstrated OPERABLE:

- a. At least once per 7 days by:
 - 1. Verifying the contained borated water volume in the tank, and

2. Verifying the boron concentration of the water.

b. At least once per 24 hours by verifying the RWST temperature when the outside air temperature is less than 35°F.

FARLEY-UNIT 2

AMENDMENT NO. 60

BASES

BORATION SYSTEMS (Continued)

MARGIN from expected operating conditions of 1.77% delta k/k after xenon decay and cooldown to 200°F. The maximum expected boration capability requirement occurs at EOL from full power equilibrium xenon conditions and requires 11,336 gallons of 7000 ppm borated water from the boric acid storage tanks or 44,826 gallons of 2300 ppm borated water from the refueling water storage tank.

With the RCS temperature below 200°F, one injection system is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the additional restrictions prohibiting CORE ALTERATIONS and positive reactivity changes in the event the single injection system becomes inoperable.

The limitation for a maximum of one centrifugal charging pump to be OPERABLE and the Surveillance Requirement to verify all charging pumps except the required OPERABLE pump to be inoperable below 180°F provides assurance that a mass addition pressure transient can be relieved by the operation of a single RHE relief valve.

The boron capability required below 200°F is sufficient to provide a SHUTDOWN MARGIN of 1% delta k/k after xenon decay and cooldown from 200°F to 140°F. This condition requires either 2,000 gallons of 7000 ppm borated water from the boric acid storage tanks or 7,750 gallons of 2300 ppm borated water from the refueling water storage tank.

The contained water volume limits include allowance for water not available because of discharge line location and other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 8.5 and 11.0 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

The OPERABILITY of one boron injection system during REFUELING ensures that this system is available for reactivity control while in MODE 6.

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

The specifications of this section ensure that (1) acceptable power distribution limits are maintained, (2) the minimum SHUTDOWN MARGIN is maintained, and (3) limit the potential effects of rod misalignment on associated accident analyses. OPERABILITY of the control rod position indicators is required to determine control rod positions and thereby ensure compliance with the control rod alignment and insertion limits.

FARLEY-UNIT 2

BASES

For purposes of determining compliance with Technical Specification 3.1.3.1, any inoperability of full length control rod(s), due to being immovable, invokes ACTION statement "a".

The intent of Technical Specification 3.1.3.1 ACTION statement "a" is to ensure that before leaving ACTION statement "a" and utilizing ACTION statement "c" that the rod urgent failure alarm is illuminated or that an obvious electrical problem is detected in the rod control system by minimal electrical troubleshooting techniques. Expeditious action will be taken to determine if rod immovability is due to an electrical problem in the rod control system.

The ACTION statements which permit limited variations from the basic requirements are accompanied by additional restrictions which ensure that the original design criteria are met. Misalignment of a rod requires measurement of peaking factors or a restriction in THERMAL POWER; either of these restrictions provide assurance of fuel rod integrity during continued operation. In addition, those safety analyses affected by a misaligned rod are reevaluated to confirm that the results remain valid during future operation.

The maximum rod drop time restriction is consistent with the assumed rod drop time used in the safety analyses. Measurement with T_{avg} greater than or equal to 541°F and with all reactor coolant pumps operating ensures that the measured drop times will be representative of insertion times experienced during a reactor trip at operating conditions.

Control rod positions and OPERABILITY of the rod position indicators are required to be verified on a nominal basis of once per 12 hours with more frequent verifications required if an automatic monitoring channel is inoperable. These verification frequencies are adequate for assuring that the applicable LCO's are satisfied.

3/4.5 EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.1 ACCUMULATORS

The OPERABILITY of each Reactor Coolant System (RCS) accumulator ensures that a sufficient volume of borated water will be immediately forced into the reactor core through each of the cold legs in the event the RCS pressure falls below the pressure of the accumulators. This initial surge of water into the core provides the initial cooling mechanism during large RCS pipe ruptures.

The limits on accumulator volume, boron concentration and pressure ensure that the assumptions used for accumulator injection in the safety analysis are met.

The accumulator power operated isolation valves are considered to be "operating bypasses" in the context of IEEE Std. 279-1971, which requires that bypasses of a protective function be removed automatically whenever permissive conditions are not met. In addition, as these accumulator isolation valves fail to meet single failure criteria, removal of power to the valves is required.

The limits for operation with an accumulator inoperable for any reason except an isolation valve closed minimizes the time exposure of the plant to a LOCA event occurring concurrent with failure of an additional accumulator which may result in unacceptable peak cladding temperatures. If a closed isolation valve cannot be immediately opened, the full capability of one accumulator is not available and prompt action is required to place the reactor in a mode where this capability is not required.

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS

The OPERABILITY of two independent ECCS subsystems ensures that sufficient emergency core cooling capability will be available in the event of a LOCA assuming the loss of one subsystem through any single failure consideration. Either subsystem operating in conjunction with the accumulators is capable of supplying sufficient core cooling to limit the peak cladding temperatures within acceptable limits for all postulated break sizes ranging from the double ended break of the largest RCS cold leg pipe downward. In addition, each ECCS subsystem provides long term core cooling capability in the recirculation mode during the accident recovery period.

With the RCS temperature below 350°F, one OPERABLE ECCS subsystem is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the limited core cooling requirements.

EMERGENCY CORE COOLING SYSTEMS

BASES

The Surveillance Requirements provided to ensure OPERABILITY of each component ensures that at a minimum the assumptions used in the safety analyses are met and that subsystem OPERABILITY is maintained. Surveillance requirements for throttle valve position stops and flow balance testing provide assurance that proper ECCS flows will be maintained in the event of a LOCA. Maintenance of proper flow resistance and pressure drop in the piping system to each injection point is necessary to: (1) prevent total pump flow from exceeding runout conditions when the system is in its minimum resistance configuration, (2) provide the proper flow split between injection points in accordance with the assumptions used in the ECCS-LOCA analyses, and (3) provide an acceptable level of total ECCS flow to all injection points equal to or above that assumed in the ECCS-LOCA analyses.

3/4.5.4 BORON INJECTION SYSTEM

THIS SPECIFICATION DELETED.

3/4.5.5 REFUELING WATER STORAGE TANK

The OPERABILITY of the Refueling Water Storage Tank (RWST) as part of the ECCS ensures that sufficient negative reactivity is injected into the core to counteract any positive increase in reactivity caused by RCS system cooldowr. RCS cooldown can be caused by inadvertent depressurization, a loss-of-coolant accident on a steam line rupture.

The OPERABILITY of the RWST as part of the ECCS also ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that 1) sufficient water is available within containment to permit recirculation cooling flow to the core, and 2) the reactor will remain subcritical in the cold condition foll ling mixing of the RWST and the RCS water volumes with all control rods inserted except for the most reactive control assembly in the event of a small break LOCA and with no control rods inserted in the event of a large break LOCA.

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D., C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. NPF-2

AND AMENDMENT NO. 60 TO FACILITY OPERATING LICENSE NO. NPF-2

ALABAMA POWER COMPANY

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT NOS. 1 AND 2

DOCKET NOS. 50-348 AND 50-364

INTRODUCTION

By letter dated July 3, 1986, supplemented August 27, 1986, Alabama Power Company (APCo, the licensee) submitted proposed Technical Specification (TS) changes to the boron concentration limits from the present values of 2000-2200 ppm for the Refueling Water Storage Tank (PWST) and from 1900-2200 ppm for the reactor coolant system accumulators to 2300-2500 ppm and 2200-2500 ppm, respectively. The proposal also included a correction to the TS Bases to reflect the criteria for subcriticality for both large and small break Loss of Coolant Accidents (LOCAs). Also, the licensee presented an evaluation of the effects of the change and the results of accident analyses. By letter dated August 27, 1986, APCo advised us of a schedule change for implementing the boron changes consistent with plant conditions (Mode 5 and 6) for the eighth refueling outage on Unit 1 and for the fifth refueling outage on Unit 2. The August 27, 1986 letter provided supplemental information and did not change the initial determination published in the FEDERAL REGISTER on July 30, 1986.

DISCUSSION

Farley Nuclear Plant fuel cycle design is being changed from 12-month to 18-month fuel cycles with anticipated capacity factors in excess of 90%. As a result of designing these high energy cycles the calculated critical boron concentration for the low end of the previous cycle burnup window is required to be increasingly high. The presently approved boron concentrations are at a level that reduces the available margin for ensuring subcriticality from emergency core cooling system (ECCS) injection alone. At the presently specified boron concentration the Unit 2 Cycle 5 reload core required an increase in the number of burnable absorbers from 592 to 1120. Therefore, the licensee has requested an increase in the boron concentration limits in the RWST and in the accumulators to ensure sufficient shutdown margin for the ECCS without the addition of an excessive number of burnable absorbers as was required for the Unit 2 Cycle 5 design. The licensee contends that the design alternatives using increased boron concentrations will provide added assurance of maintaining reactor subcriticality at all times for the widest spectrum of possible accidents.



The increased ECCS requirement for boration is provided by injection of borated coolant from the RWST and from the accumulators. The boron from these sources provides negative reactivity to ensure core shutdown for the LOCA and other accidents. The current TSs require that the RWST boron concentration be maintained between 2000 and 2200 ppm, while the accumulators boron concentration must be maintained between 1900 and 2200 ppm. By raising the allowed boron concentration limits by 300 ppm as APCo proposes, future high energy core reloads would maintain the necessary shutdown requirements without addition of an excessive number of burnable absorbers. An increase in the boron concentration affects several areas. The licensee has addressed these by evaluating the impact of the increased boron concentration on the following: accidents affected by core boration, post-LOCA boron precipitation, post accident sump pH and equipment qualification, non-LOCA accident analyses, RWST solubility limits and plant chemistry. The licensee's proposed change to Bases 3/4.5.5 is strictly a clarification which was identified during the review. As presently written, the TS Bases state that the RWST boron concentration limits ensure the reactor will remain subcritical following mixing of the RWST and reactor coolant system water volumes with all control rods inserted except the most reactive control assembly. This assumption is only for the small break LOCA. The large break LOCA analysis assumes the core must remain subcritical with no credit taken for control rod insertion.

Thus, the postulated loss of coolant accidents would require increased boration. The licensee has analyzed the effects of increased boron concentration on both large break and small break LOCAs. The licensee characterized the large break LOCA by two phases: ECCS operation and long term cooling. Peak clad temperature, maximum cladding oxidation and maximum hydrogen generation occur during the first phase of the accident; therefore, these effects are not dependent on the boron concentration injected later from the accumulators or the RWST. Void formation would shut down the reactor initially following a double-ended guillotine break. For these reasons the current accident analysis remains valid.

The results of the licensee's analysis of the increased boron concentration indicates that the reactor will remain shutdown during the reflood and long term cooling phase even with no control rods inserted into the core. The small break LOCA model assumes the insertion of all control rods except for the most reactive assembly in the calculation of core shutdown. Consequently, the boron concentration required to achieve the level of negative reactivity necessary to assure shutdown is significantly lower than the concentration required to assure shutdown for a large break LOCA. The increase in boron concentration provides additional conservatism for the small break LOCA. The licensee has not specifically reanalyzed the effects of increased RWST and accumulator boron concentration citing the above reasoning for the continued validity of previous analysis; i.e., raising the limits for allowable boron concentration in the RWST and accumulators will provide additional margin for maintaining the core subcritical.

One effect of boration during a LOCA is the progressive increase with time of the boron concentration in the core. This occurs because the water lost during steaming out through the break leaves behind the boron that the water originally contained. If the concentration exceeds a critical value, boric acid can crystalize in the core and precipitate out of solution. The concern is that the precipitation of boric acid crystals could block core cooling.

To preclude the possibility of boron precipitation, the concentration should not exceed 23.53 weight percent, which is the boric acid solubility limit less a 4 weight percent margin. The licensee has analyzed this situation and determined that boron precipitation can be prevented if the operator alternates between hot leg and cold leg recirculation every fifteen hours. The increased boron concentration in the RWST and accumulators will require a shorter hot-leg/cold-leg recirculation switchover time than that which was calculated in the original analysis. This will require a change to the Farley Nuclear Plant Emergency Operating Procedures (EOPs) which should be implemented concurrently with the increase in boron concentration.

The licensee performed an evaluation to determine the impact that an increase in boron concentration would have on sump pH and how this would affect the environmental qualification of safety-related electrical equipment inside containment. The results demonstrate that the pH range is maintained within the range noted in TS Bases 3/4.1.2 and Bases 3/4.5.5. Consequently, there is no impact on environmental qualification of safety-related electrical equipment inside containment from this change. The following five non-LOCA accidents were analyzed to determine the effects of the proposed increase in the RWST and accumulator boron concentration: uncontrolled boron dilution, main steam line break, inadvertent operation of the ECCS during power operation and at hot zero power, and accidental depressurization of the main steam system. The analyses found that the increase in boron concentration will provide additional safety margin for each of these non-LOCA transients and accidents. The current Final Safety Analysis Report (FSAR) analyses were reviewed and determined by the licensee to provide equal or more limiting results.

The boron solubility limit at 35°F coolant temperature is 4900 ppm. An increase in the boron concentration to 2500 ppm will not cause crystallization of the RWST contents. Margin in excess of TS limits is maintained despite the increase in boron concentrations since TSs require RWST temperature to be no less than 35°F.

The increase in boron concentration can affect pH control of the primary coolant during startup. The licensee has committed to develop the appropriate Li/B curves prior to the start of any cycle utilizing the increased boron concentrations.

Stress corrosion cracking in the primary system and emergency core cooling system piping can be caused by hydroxide or chloride concentration in cracks or crevices on pipe surfaces under tensile stress. The effect of increasing the RWST boron concentration has been determined by the licensee to reduce the pH to less than 0.1 pH unit. Reduction in pH tends to reduce the likelihood of caustic stress corrosion cracking. Chloride stress corrosion is an intergranular process that occurs in austenitic stainless steel in the presence of oxygen, chloride ions and tensile stress. Increasing the boron concentrations will have no effect on the level of chloride stress corrosion cracking.

1

EVALUATION AND SAFETY SUMMARY

The NRC staff has reviewed the licensee's submittal dated July 3, 1986, as supplemented August 27, 1986. As part of this review, the NRC staff was particularly concerned about boron precipitation in the core and the boron solubility limit in the RWST and in the accumulators. The problem of boron precipitation in the core can be avoided by decreasing the current hot leg/ cold leg recirculation switchover time from twenty hours to fifteen hours. The licensee has stated that the affected EOPs will be revised as necessary.

The NRC staff recommends that the plant operators be provided with training regarding this area if such training has not already been provided. We understand that APCo's current training procedures would require that operator's training be upgraded to include such EOP changes such as this change.

Regarding the change in solubility limits caused by the increased boron concentrations, the NRC staff has verified that sufficient margin exists to preclude boron "freeze-up" in the tanks and piping. Additional conclusions are as follows:

- 1. The licensee's request to correct the TS Bases 3/4.5.5 to note that the core must remain subcritical following a large break LOCA despite no control rod insertion is consistent with NPC requirements for accident analysis assumptions and is acceptable.
- 2. The licensee has demonstrated satisfactory assessment of the effects of increased boron concentration on large and small break LOCAs, post LOCA boron precipitation in the reactor vessel, equipment qualification, non-LOCA accidents, RWST solubility limits and overall plant chemistry. The licensee's request to increase the TS limits for boron concentration in the RWST and in the reactor coolant system accumulators from 2000-2200 ppm for the RWST and 1900-2200 ppm for the accumulators to 2300-2500 ppm and 2200-2500 ppm, respectively, is acceptable.

ENVIRONMENTAL CONSIDERATION

These amendments involve a change in the installation or use of the facilities components located within the restricted areas as defined in 10 CFR 20. The staff has determined that these amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that these amendments involve no significant hazards consideration and there has been no public comment on such finding. Accordingly, these amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments.

CONCLUSION

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Dated: November 5, 1986

Principal Contributors:

R. Karsch

E. Reeves