

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.2.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed in MODES 1 and 2. 2. Not required to be met until the first startup after September 27, 2001. <p>-----</p> <p>Verify closure time of each MSIV is \leq 5 seconds.</p>	<p>In accordance with the Inservice Testing Program</p>
<p>SR 3.7.2.2 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed in MODES 1 and 2. 2. Not required to be met until the first startup after September 27, 2001. <p>-----</p> <p>Verify each MSIV actuates to the isolation position on an actual or simulated actuation signal.</p>	<p>18 months</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.7.2.1 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed in MODES 1 and 2. 2. Not required to be met until the first startup after September 27, 2001. <p>-----</p> <p>Verify closure time of each MSIV is ≤ 5 seconds.</p>	<p>In accordance with the Inservice Testing Program</p>
<p>SR 3.7.2.2 -----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed in MODES 1 and 2. 2. Not required to be met until the first startup after September 27, 2001. <p>-----</p> <p>Verify each MSIV actuates to the isolation position on an actual or simulated actuation signal.</p>	<p>18 months</p>