

October 4, 1984

Docket Nos. 50-348
and 50-364

Mr. R. P. McDonald
Senior Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Dear Mr. McDonald:

DISTRIBUTION

Docket File

NRC PDR
L PDR
Gray File 4
ORB#1 Rdg
DEisenhut
OELD
CParrish
EReeves 2
JFairobent
ACRS 10

TBarnhart 8
WJones
JNGrace
EJordan
RDiggs
LHarmon
DBrinkman
RFerguson
CMiles

The Commission has issued the enclosed Amendment No. 49 to Facility Operating License No. NPF-2 and Amendment No. 40 to NPF-8 for the Joseph M. Farley Nuclear Plant, Unit Nos. 1 and 2, respectively. The amendments consist of changes to the Technical Specifications in response to your application transmitted by letter dated March 2, 1984.

The amendments modify the Technical Specifications (TS) to upgrade existing TSs for meteorological monitoring instrumentation (TS 3/4.3.3.4) to conform with the Commission Standard Technical Specifications. The change also adds surveillance requirements and minimum number of operable channels for air temperature delta T to Tables 3.3-8 and 4.3-5.

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's next regular monthly Federal Register notice.

Sincerely,

/s/EReeves

Edward A. Reeves, Project Manager
Operating Reactors Branch #1
Division of Licensing

Enclosures:

1. Amendment No. 49 to NPF-2
2. Amendment No. 40 to NPF-8
3. Safety Evaluation

cc: w/enclosures
See next page

ORB#1:DL *CP* ORB#1:DL *ER*
CParrish EReeves;ps
9/19/84 9/20/84

ORB#1:DL
S. Wanga
9/27/84

OELD
9/25/84

AD-OR:DL
GLainas
10/1/84

8410240122 841004
PDR ADOCK 05000348
PDR
P