

November 13, 2001

Mr. Jeffrey S. Forbes
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT - REQUEST FOR ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT REQUEST (TAC NO. MB2855)

Dear Mr. Forbes:

By application dated August 30, 2001, as supplemented October 10, 2001, Nuclear Management Company, LLC, requested a license amendment to revise the safety limit minimum critical power ratio (SLMCPR) for two recirculation pump operations for Cycle 21. Based on the staff's review of your application, we request that you provide the following additional information regarding Exhibit D-2:

1. Provide the specific fuel type, quantity (number of bundles), and cycle number for the fuel loaded into the core for Figures 1 and 2.
2. Provide justification that the overall GEXL14 uncertainty is valid, since a discrepancy was found in the databases during an NRC audit of the GEXL14 correlation. Also, discuss any impact on the SLMCPR calculation due to this discrepancy.

The enclosed request was discussed with Mr. D. Neve of your staff on November 8, 2001. A mutually agreeable target date of November 16, 2001, for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-2296 at the earliest opportunity.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. Jeffrey S. Forbes
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

November 13, 2001

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT - REQUEST FOR ADDITIONAL INFORMATION RELATED TO LICENSE AMENDMENT REQUEST (TAC NO. MB2855)

Dear Mr. Forbes:

By application dated August 30, 2001, as supplemented October 10, 2001, Nuclear Management Company, LLC, requested a license amendment to revise the safety limit minimum critical power ratio (SLMCPR) for two recirculation pump operations for Cycle 21. Based on the staff's review of your application, we request that you provide the following additional information regarding Exhibit D-2:

1. Provide the specific fuel type, quantity (number of bundles), and cycle number for the fuel loaded into the core for Figures 1 and 2.
2. Provide justification that the overall GEXL14 uncertainty is valid, since a discrepancy was found in the databases during an NRC audit of the GEXL14 correlation. Also, discuss any impact on the SLMCPR calculation due to this discrepancy.

The enclosed request was discussed with Mr. D. Neve of your staff on November 8, 2001. A mutually agreeable target date of November 16, 2001, for your response was established. If circumstances result in the need to revise the target date, please contact me at (301) 415-2296 at the earliest opportunity.

Sincerely,

/RA/

Carl F. Lyon, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PUBLIC OGC
PDIII-1 Reading ACRS
WReckley BBurgess, RGN-III
FLyon THuang
RBouling RCaruso

*Input provided by e-mail from THuang

OFFICE	PDIII-1/PM	PDIII-1/LA	SRXB/SC*	PDIII-1/SC(A)
NAME	FLyon	RBouling	RCaruso	WReckley
DATE			11/8/01	

ADAMS ACCESSION NO. **ML013120111**

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington, DC 20037

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Site Licensing Manager
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, MN 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
121 Seventh Place East
Suite 200
St. Paul, MN 55101-2145

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
445 Minnesota Street
Suite 900
St. Paul, MN 55101-2127

Mr. Roy A. Anderson
Executive Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall
Minneapolis, MN 55401