

August 12, 1994

Docket Nos. 50-348
and 50-364

Mr. D. N. Morey, Vice President
Southern Nuclear Operating Co., Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

Dear Mr. Morey:

SUBJECT: CHANGE TO TECHNICAL SPECIFICATION BASES SECTIONS REGARDING STATION
BLACKOUT - JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2 (TAC NOS.
M86241 AND M86242)

By letter dated July 28, 1994, Southern Nuclear Operating Company submitted a change to Technical Specification Bases Sections 3/4.8.1 and 3/4.8.2. The proposed changes were necessary to make the Bases consistent with the technical requirements contained in Amendment No. 101 to Operating License No. NPF-2 and Amendment No. 93 to Operating License No. NPF-8. Your letter stated that a 10 CFR 50.59 evaluation of the changes was made.

For administrative purposes, the TS Bases change needs to be provided to the staff to enable all copies of the Joseph M. Farley Technical Specifications to be updated in a consistent fashion.

Enclosed is a copy of the revised Bases Page B 3/4 8-1 for Unit 1 and Page B 3/4 8-1 for Unit 2.

Sincerely,

ORIGINAL SIGNED BY:

Byron L. Siegel, Senior Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

DISTRIBUTION

Docket File
NRC & Local PDRs
PDII-1 R/F
S. Varga
D. Matthews 170123
B. Siegel

OGC
D. Hagan
G. Hill (2)
C. Grimes
ACRS (10)
OPA

OC/LFDCB
E. Merschhoff, RII

OFC	LA: PD21:DRPE	PM: PD21:DRPE	D: PD21:DRPE	
NAME	PAnderson	BSiegel:irm	DMatthews	
DATE	8/12/94	8/12/94	8/12/94	1/94

OFFICIAL RECORD COPY
DOCUMENT NAME: G:\FARLEY\FA86241.LTR

9408180269 940812
PDR ADOCK 05000348
P PDR

Handwritten signature/initials



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 12, 1994

Docket Nos. 50-348
and 50-364

Mr. D. N. Morey, Vice President
Southern Nuclear Operating Co., Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

Dear Mr. Morey:

SUBJECT: CHANGE TO TECHNICAL SPECIFICATION BASES SECTIONS REGARDING STATION
BLACKOUT - JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2 (TAC NOS.
M86241 AND M86242)

By letter dated July 28, 1994, Southern Nuclear Operating Company submitted a change to Technical Specification Bases Sections 3/4.8.1 and 3/4.8.2. The proposed changes were necessary to make the Bases consistent with the technical requirements contained in Amendment No. 101 to Operating License No. NPF-2 and Amendment No. 93 to Operating License No. NPF-8. Your letter stated that a 10 CFR 50.59 evaluation of the changes was made.

For administrative purposes, the TS Bases change needs to be provided to the staff to enable all copies of the Joseph M. Farley Technical Specifications to be updated in a consistent fashion.

Enclosed is a copy of the revised Bases Page B 3/4 8-1 for Unit 1 and Page B 3/4 8-1 for Unit 2.

Sincerely,

A handwritten signature in cursive script, appearing to read "Byron L. Siegel".

Byron L. Siegel, Senior Project Manager
Project Directorate II-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. D. N. Morey
Southern Nuclear Operating
Company, Inc.

Joseph M. Farley Nuclear Plant

cc:

Mr. R. D. Hill, Jr.
General Manager - Farley Nuclear Plant
Southern Nuclear Operating Company
Post Office Box 470
Ashford, Alabama 36312

State Health Officer
Alabama Department of Public Health
434 Monroe Street
Montgomery, Alabama 36130-1701

Mr. B. L. Moore, Licensing Manager
Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201-1295

Chairman
Houston County Commission
Post Office Box 6406
Dothan, Alabama 36302

Mr. M. Stanford Blanton
Balch and Bingham Law Firm
Post Office Box 306
1710 Sixth Avenue North
Birmingham, Alabama 35201

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta St., N.W., Ste. 2900
Atlanta, Georgia 30323

Mr. J. D. Woodard
Executive Vice President
Southern Nuclear Operating Company
P.O. Box 1295
Birmingham, Alabama 35201

Resident Inspector
U.S. Nuclear Regulatory Commission
7388 N. State Highway 95
Columbia, Alabama 36319

3/4.8 ELECTRICAL POWER SYSTEMS

BASES

3/4.8/1 AND 3/4.8.2 A.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS

The OPERABILITY of the A.C. and D.C. power sources and associated distribution systems during operation ensures that sufficient power will be available to supply the safety-related equipment required for 1) the safe shutdown of the facility and 2) the mitigation and control of accident conditions within the facility. The minimum specified independent and redundant A.C. and D.C. power sources and distribution systems satisfy the requirements of General Design Criterion 17 of Appendix "A" to 10 CFR 50.

The ACTION requirements specified for the levels of degradation of the power sources provide restriction upon continued facility operation commensurate with the level of degradation. The OPERABILITY of the power sources is consistent with the initial condition assumptions of the safety analyses and is based upon maintaining at least one redundant set of onsite A.C. and D.C. power sources and associated distribution systems OPERABLE during accident conditions coincident with an assumed loss of offsite power and single failure of the other onsite A.C. source.

The OPERABILITY of the minimum specified A.C. and D.C. power sources and associated distribution systems during shutdown and refueling ensures that 1) the facility can be maintained in the shutdown or refueling condition for extended time periods and 2) sufficient instrumentation and control capability is available for monitoring and maintaining the unit status.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guide 1.9, "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971. The criteria of NUREG/CR 0660, "Enhancement of On Site Diesel Generator Reliability," February 1979, the manufacturer's recommendations, and operating experience have been utilized to develop a diesel reliability program which provides an extremely high confidence in diesel operability. The surveillance test frequency is based on Regulatory Guide 1.108, "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977, with adjustments made to preclude over testing which has been verified by the manufacturer to be detrimental to diesel generator reliability.

The Surveillance Requirements for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of IEEE Standard 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

9408180278 940812
PDR ADDCK 05000348
P PDR

3/4.8 ELECTRICAL POWER SYSTEMS

BASES

3/4.8.1 AND 3/4.8.2 A.C. SOURCES AND ONSITE POWER DISTRIBUTION SYSTEMS

The OPERABILITY of the A.C. and D.C. power sources and associated distribution systems during operation ensures that sufficient power will be available to supply the safety-related equipment required for 1) the safe shutdown of the facility and 2) the mitigation and control of accident conditions within the facility. The minimum specified independent and redundant A.C. and D.C. power sources and distribution systems satisfy the requirements of General Design Criterion 17 of Appendix "A" to 10 CFR 50.

The ACTION requirements specified for the levels of degradation of the power sources provide restriction upon continued facility operation commensurate with the level of degradation. The OPERABILITY of the power sources is consistent with the initial condition assumptions of the safety analyses and is based upon maintaining at least one redundant set of onsite A.C. and D.C. power sources and associated distribution systems OPERABLE during accident conditions coincident with an assumed loss of offsite power and single failure of the other onsite A.C. source.

The OPERABILITY of the minimum specified A.C. and D.C. power sources and associated distribution systems during shutdown and refueling ensures that 1) the facility can be maintained in the shutdown or refueling condition for extended time periods and 2) sufficient instrumentation and control capability is available for monitoring and maintaining the unit status.

The Surveillance Requirements for demonstrating the OPERABILITY of the diesel generators are in accordance with the recommendations of Regulatory Guides 1.9, "Selection of Diesel Generator Set Capacity for Standby Power Supplies," March 10, 1971, and 1.108, "Periodic Testing of Diesel Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants," Revision 1, August 1977.

The Surveillance Requirements for demonstrating the OPERABILITY of the Station batteries are based on the recommendations of IEEE Standard 450-1980, "IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations."

3/4.8.3 ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

Containment electrical penetrations and penetration conductors are protected by either deenergizing circuits not required during reactor operation or by demonstrating the OPERABILITY of overcurrent protection circuit breakers during periodic surveillance.