

Distribution
 Docket File
 ORB 1
 NRC PDR
 L PDR
 C Parrish
 E Reeves (2)
 D Eisenhut
 E Jordan
 J Taylor
 ACRS -10
 OELD

NOV 30 1983

Docket No. 50-364

Mr. F. L. Clayton
 Senior Vice President
 Alabama Power Company
 Post Office Box 2641
 Birmingham, Alabama 35291

Dear Mr. Clayton:

The Commission issued Amendment No. 24 to Facility Operating License No. NPF-8 for the Joseph M. Farley Nuclear Plant Unit 2 on August 2, 1983. However, due to an inadvertent clerical error, this amendment was issued with an incorrect allowable outage time in the ACTION statement of Technical Specification 3.7.5. The correct allowable outage time is 7 days as approved by Amendment No. 13 issued on May 5, 1982.

Enclosed is the corrected Technical Specification Page 3/4 7-13 which you should use to replace the one issued on August 2, 1983. The page has been identified as "corrected page", Amendment No. 24.

We apologize for any inconvenience this error may have caused you.

Sincerely,

Edward A. Reeves, Project Manager
 Operating Reactors Branch No. 1
 Division of Licensing

Enclosure:
 T.S. Page 3/4 7-13

cc w/enclosure:
 See next page

8312070420 831130
 PDR ADDCK 05000364
 P PDR

OFFICE	ORB#1	C-ORB#1					
SURNAME	EReeves;et						
DATE	11-29-83	11-29-83					

Mr. F. L. Clayton
Alabama Power Company

cc: Mr. W. O. Whitt
Executive Vice President
Alabama Power Company
Post Office Box 2641
Birmingham, Alabama 35291

Ruble A. Thomas, Vice President
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

George F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Robert A. Buettner, Esquire
Balch, Bingham, Baker, Hawthorne,
Williams and Ward
Post Office Box 306
Birmingham, Alabama 35201

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 24-Route 2
Columbia, Alabama 36319

Mr. R. P. McDonald
Vice President - Nuclear Generation
Alabama Power Company
P.O. Box 2641
Birmingham, Alabama 35291

James P. O'Reilly
Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

PLANT SYSTEMS

3/4.7.5 . RIVER WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.5 At least two independent river water loops shall be OPERABLE with at least two river water pumps per loop.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With only one river water loop OPERABLE, restore at least two loops to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.5 Each river water loop shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic), in the flow path, servicing safety related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 18 months by:
 1. Verifying that each automatic valve servicing safety related equipment actuates to its correct position on a low pond level signal.
 2. Verifying that the buried piping is leak tight by a visual inspection of the ground area.

8312070434 831130
PDR ADOCK 05000364
P PDR