

NRC FORM 591 PART 1
(8-1997)
10 CFR 2.201

U.S. NUCLEAR REGULATORY COMMISSION

SAFETY AND COMPLIANCE INSPECTION

1. LICENSEE Battelle Memorial Institute Battelle Columbus Operations 505 King Avenue	2. REGIONAL OFFICE REGION III US NUCLEAR REGULATORY COMMISSION 801 WARRENVILLE ROAD LISLE IL 80532-4351
---	--

REPORT NUMBER(S) 070-0008	4. LICENSE NUMBER(S) SNM-0007	5. DATE(S) OF INSPECTION August 20-24, 2001
--	--	--

LICENSEE:
 The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the Inspector. The inspection findings are as follows:

- 1. Based on the inspection findings, no violations were identified.
- 2. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, NUREG-1600, to exercise discretion, were satisfied.
 _____ non-cited violation(s) were discussed involving the following requirement(s):

3. During this inspection certain of your activities, as described below and/or attached, were in violation of NRC requirements and are being cited. This form is a NOTICE OF VIOLATION, which is required to be posted in accordance with 10 CFR 19.11.

License Condition 12.B. incorporates the Licensee's "Decommissioning Plan" which requires that Decommissioning Procedures be treated as regulatory requirements. Contrary to the above, the licensees failed to comply with the procedural provisions of Radiation Work Permits (RWP). This is a Severity Level IV violation.

License Condition 12.E. requires the licensee to comply with the provisions of Licensee's Procedure HP-AP-36.0, Revision 0, "Control of Revisions to Radiation Protection Program Documents". Contrary to the above, the Licensee failed to comply with the procedural provisions of HP-AP-36.0. This is a Severity Level IV violation.

STATEMENT OF CORRECTIVE ACTIONS

I hereby state that, within 30 days, the actions described by me to the Inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

TITLE	PRINTED NAME	SIGNATURE	DATE
LICENSEE	Craig Jensen	<i>Craig Jensen</i>	10/10/2001
NRC INSPECTOR	George M. McCann	<i>George M. McCann</i>	09/24/2001