

November 7, 1984

Docket No. 50-364

Mr. R. P. McDonald  
Senior Vice President  
Alabama Power Company  
Post Office Box 2641  
Birmingham, Alabama 35291

Distribution

Docket file  
Local PDR  
DEisenhut  
EReeves - 2  
LHarmon  
PMcKee  
WJones  
OPA, CMiles  
JPartlow

NRC PDR  
ORB#1RDG.  
CParrish  
OELD  
EJordan  
TBarnhart (4)  
DBrinkman  
RDiggs  
RBallard

Dear Mr. McDonald:

SUBJECT: PAGE CORRECTION FOR LICENSE AMENDMENT NO. 38 JOSEPH M. FARLEY  
NUCLEAR PLANT UNIT 2

By letter dated October 23, 1984 you advised us that your letter dated December 12, 1983 requesting technical specification changes contained an administrative error. The error is unrelated to the proposed changes which we approved. You requested issuance of a corrected page expeditiously to replace page 3/4 6-19 for Unit 2 only which we issued with Amendment No. 38 on September 12, 1984.

You advised us that you have taken corrective action including "multiple proofing reviews" of technical specification pages prior to submittal to the NRC. This action resulted from our April 10, 1984 letter in which we advised you of the potential for such errors. You also noted that the submittal now in question predated the newer "proofing" system. To preclude further similar errors, you should assure that any other pending requests at NRC have been "proofed".

We have reviewed your request for an expeditions review and issuance of the corrected page. We agree that Unit 2 Technical Specification page 3/4 6-19 should be corrected to agree with the identical page on Unit 1. The correction is unrelated to the changes approved in Amendment No. 38. Therefore, enclosed is the corrected Technical Specification page 3/4 6-19 which you should use to replace the one issued on September 12, 1984. The page is identified as "corrected page", Amendment No. 38.

Sincerely,

/s/EReeves

Edward A. Reeves, Project Manager  
Operating Reactors Branch #1  
Division of Licensing

Enclosure:  
T.S. Page 3/4 6-19  
Farley - Unit 2

cc w/enclosure.  
See next page  
ORB#1:DL  
EReeves/ts  
10/29/84

ORB#1:DL  
CParrish  
11/1/84

2-ORB#1:DL  
SVanga  
10/29/84

8411200083 841107  
PDR ADOCK 05000364  
P PDR

Mr. R. P. McDonald  
Alabama Power Company

Joseph M. Farley Nuclear Plant  
Units 1 and 2

cc: Mr. W. O. Whitt  
Executive Vice President  
Alabama Power Company  
Post Office Box 2641  
Birmingham, Alabama 35291

Mr. Louis B. Long, General Manager  
Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202

Houston County Commission  
Dothan, Alabama 36301

George F. Trowbridge, Esquire  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N.W.  
Washington, DC 20036

Chairman  
Houston County Commission  
Dothan, Alabama 36301

Robert A. Buettner, Esquire  
Balch, Bingham, Baker, Hawthorne,  
Williams and Ward  
Post Office Box 306  
Birmingham, Alabama 35201

Resident Inspector  
U.S. Nuclear Regulatory Commission  
Post Office Box 24 - Route 2  
Columbia, Alabama 36319

State Department of Public Health  
ATTN: State Health Officer  
State Office Building  
Montgomery, Alabama 36104

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.E.  
Atlanta, GA 30308

D. Biard MacGuineas, Esquire  
Volpe, Boskey and Lyons  
918 16th Street, N.W.  
Washington, DC 20006

Charles R. Lowman  
Alabama Electric Corporation  
Post Office Box 550  
Andalusia, Alabama 36420

James P. O'Reilly  
Regional Administrator - Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 2900  
Atlanta, GA 30303

Ira L. Myers, M.D.  
State Health Officer  
State Department of Public Health  
State Office Building  
Montgomery, Alabama 36130

## CONTAINMENT SYSTEMS

### 3/4.6.4 COMBUSTIBLE GAS CONTROL

#### HYDROGEN ANALYZERS

#### LIMITING CONDITION FOR OPERATION

---

3.6.4.1 Two independent containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With one hydrogen monitor inoperable, restore the inoperable analyzer to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.
- b. With both hydrogen monitors inoperable, restore at least one monitor to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.6.4.1 Each hydrogen analyzer shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases containing:

- a. Ten volume percent hydrogen, balance nitrogen, for zero check.
- b. Ten volume percent hydrogen, balance nitrogen, mixed with compressed air, for span check.