

JUL 8 1981

Docket No. 50-369

Mr. William O. Parker, Jr.
Vice President, Steam Production
Duke Power Company
P.O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Parker:

SUBJECT: ISSUANCE OF AMENDMENT NO. 2 TO FACILITY OPERATING LICENSE NPF-9
MCQUIRE NUCLEAR STATION, UNIT 1

The Nuclear Regulatory Commission has issued Amendment No. 2 to Facility Operating License NPF-9 for the McGuire Nuclear Station, Unit 1 located in Mecklenburg County, North Carolina. This license amendment authorizes operation at 3411 megawatts thermal (100% power) in accordance with the Commission's Order of June 29, 1981. A copy of Amendment No. 2 is enclosed.

Also enclosed is a copy of the Federal Register Notice of Issuance of Amendment No. 2 to Facility Operating License NPF-9, which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 2 to Facility Operating License NPF-9
2. Federal Register Notice

8107140336 810708
PDR ADDCK 05000369
PDR

*E.K. 6/30/81 school to
see comment
ATTN: #4 (not attached)
more provided
with complete
per J&E memo 6/30/81
CLX*

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	DL:LB.#4/LA	DL:LB.#4	OELD	DL:LB.#4	AD:DL	DIR/DP	
SURNAME	*MRushbrook/hmc	*RBirkel	*EKetchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/25/81	6/27/81	7/2/81	7/6/81	

Docket No. 50-369

Mr. William O. Parker, Jr.
Vice President, Steam Production
Duke Power Company
P.O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Parker:

SUBJECT: ISSUANCE OF AMENDMENT NO. 2 TO FACILITY OPERATING LICENSE NPF-9
MCGUIRE NUCLEAR STATION, UNIT 1

The Nuclear Regulatory Commission has issued Amendment No. 2 to Facility Operating License NPF-9 for the McGuire Nuclear Station, Unit 1 located in Mecklenburg County, North Carolina. This license authorizes operation at 3411 megawatts thermal (100% power). A copy of Amendment No. 2 is enclosed.

Also enclosed is a copy of the Federal Register Notice of Issuance of Amendment No. 2 to Facility Operating License NPF-9, which has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 2 to Facility Operating License NPF-9
2. Federal Register Notice

See comments on license & notice of 6/29/81 EK
Requires condition of 6/29/81
E. K. subject to comments on 6/29/81

OFFICE	DL:LB #4/LA	DL:LB #4 CB	OELD PJ	DL:LB #4	AD:L/DL	DIR/DI	
SURNAME	MRushbrook	RBirkel/hmc	EKetchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/24/81	6/24/81	6/24/81	6/24/81	


AMENDMENT NO. 2 TO
FACILITY OPERATING LICENSE NPF-9 - MCGUIRE NUCLEAR STATION, UNIT NO. 1

DISTRIBUTION:
w/enclosure 1 & 2

bcc: w/enclosure 1 & 2

Branch Files
R. Birkel
Licensing Assistant Br. #4
M. Rushbrook
I&E (5)
E. Ketchen, OELD
G. Deegan (4)
E. Adensan
MPA
A. Toalston, DE
I. Dinitz, DE
R. Diggs, ADM
D. Eisenhut
R. Purple
R. Tedesco
T. Novak
F. Miralgia
B. J. Youngblood
J. Miller
A. Schwencer
S. Hanauer
R. Vollmer
R. Mattson
R. Murley
NMSS

✓ Docket No. 50-369
NRC PDR
Local PDR
NSIC
TERA
A. Rosenthal, ASLAB
ASLBP
ACRS (16)
B. Scharf - 10



OFFICE ▶
SURNAME ▶
DATE ▶

Mr. Willaim O. Parker, Jr.

- 2 -

JUL 8 1981

Attorney General
Department of Justice
Justice Building
Raleigh, North Carolina 27602

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Bruce Blanchard
Environmental Projects Review
Department of the Interior
Room 4256
18th and C Street, N.W.
Washington, D. C. 20240

U.S. Environmental Protection Agency
ATTN: Ms. Elizabeth V. Jankus
Office of Environmental Review
Room 2119 M, A-104
401 M Street, S.W.
Washington, D. C. 20460

Director, Criteria and Standards Div.
Office of Radiation Programs
(ANR-460)
U.S. Environmental Protection Agency
Washington, D. C. 20460

EIS Coordinator
U.S. Environmental Protection Agency
Region IV Office
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Chairman, North Carolina
Utilities Commission
430 North Salisbury Street
Dobbs Building
Raleigh, North Carolina 27602

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. David E. Smith
City of Charlotte
Legal Department
600 E. Trade Street
City Hall
Charlotte, North Carolina 28211

McGuire

JUL 8 1981

Mr. William O. Parker, Jr.
Vice President - Steam Production
Duke Power Company
P.O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. W. L. Porter
Duke Power Company
P.O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Shelley Blum, Esq.
1402 Vickers Avenue
Durham, North Carolina 27707

Mr. R. S. Howard
Power Systems Division
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 1530

Mr. E. J. Keith
EDS Nuclear Incorporated
220 Montgomery Street
San Francisco, California 94104

Mr. J. E. Houghtaling
NUS Corporation
2536 Countryside Boulevard
Clearwater, Florida 33515

Mr. Jesse L. Riley, President
The Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq.
Debevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Ms. M. J. Graham
Resident Inspector McGuire NPS
c/o U.S. Nuclear Regulatory Commission
P.O. Box 216
Cornelius, North Carolina 28031

DUKE POWER COMPANY

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Facility Operating License No. NPF-9
Amendment No. 2

1. The Nuclear Regulatory Commission (the Commission) with respect to full power - full term operation of McGuire Nuclear Station, Unit 1 has found that:
 - A. The application for license filed by the Duke Power Company (the licensee) complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the McGuire Nuclear Station, Unit 1 (the facility) has been substantially completed in conformity with Construction Permit No. CPPR-83 and the application, as amended, the provisions of the Act and the regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this amendment to the operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - E. The licensee is technically and financially qualified to engage in the activities authorized by this license amendment in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
 - F. The licensee has satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements", of the Commission's regulations;
 - G. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public;

OFFICE
SURNAME
DATE

8107140341 810708
PDR ADDCK 05000369
PDR

- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of this amendment to Facility Operating License No. NPF-9 is in accordance with 10 CFR Part 51, of the Commission's regulations and all applicable requirements have been satisfied;
- I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license amendment will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
- J. Prior public notice of this licensing action was given in, "Receipt of Application for Facility Operating Licenses; Availability of Applicant's Environmental Report; and Consideration of Issuance of Facility Operating Licenses and Notice of Opportunity for Hearing" (39 Fed. Reg. 20833-34; June 14, 1974). Hearings were held in connection with admitted contentions with respect to the operating license applications on March 28-31, April 1, 19-22, 1977; August 22-24, 30-31, 1978; and February 24-27, March 3-6, 10-13, 17-19, 1981, and an Initial Decision and a Supplemental Initial Decision issued, respectively, on April 18, 1979 and May 26, 1981.
2. Accordingly, Facility Operating License NPF-9 is amended by the following changes;
- (a) Change paragraph 2.C.(1) to read:
- Maximum Power Level
- The licensee is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% power).
- (b) Change paragraph 2.C.(8) to read:
- Radioactive Waste Treatment System
- Prior to initial criticality, the licensee shall ensure the operability of radwaste systems to the satisfaction of the Office of Inspection and Enforcement including completion of testing of HEPA filters and charcoal adsorbers associated with all ventilation systems.
- (c) Add paragraph 2.C.(11)h.(3) to read:
- Operation of the hydrogen mitigation igniter system shall be activated upon a safety injection signal with accompanying indications of a loss of coolant accident.

OFFICE ▶							
SURNAME ▶							
DATE ▶							

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Date of Issuance: JUL 8 1981

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	DL:LB.#4/LA....	DL:LB.#4	OELD	DL:LB.#4	AP:L/DL	DIR/DL	
SURNAME	*MRushbrook/hmc	*RBirke1	*EKetchen	EAdensam	Rfedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/26/81	7/ /81	7/2/81	7/6/81	

- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of this amendment to Facility Operating License No. NPF-9 is in accordance with 10 CFR Part 51, of the Commission's regulations and all applicable requirements have been satisfied;
- I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license amendment will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
- J. Prior public notice of this licensing action was given in, "Receipt of Application for Facility Operating Licenses; Availability of Applicant's Environmental Report; and Consideration of Issuance of Facility Operating Licenses and Notice of Opportunity for Hearing" (39 Fed. Reg. 20833-34; June 14, 1974). Hearings were held in connection with admitted contentions with respect to the operating license applications on March 28-31, April 1, 19-22, 1977; August 22-24, 30-31, 1978; and February 24-27, March 3-6, 10-13, 17-19, 1981, and an Initial Decision and a Supplemental Initial Decision issued, respectively, on April 18, 1979 and May 26, 1981.

2. Accordingly, Facility Operating License NPF-9 is amended by the following changes;

(a) Change paragraph 2.C.(1) to read:

Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% power). Operation of the facility is subject to compliance with construction items listed in Attachment 1.

(b) Add paragraph 2.C.(1).h.(3) to read:

Operation of the hydrogen mitigation igniter system shall be activated upon a safety injection signal with accompanying indications of a loss of coolant accident.

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*Subj. for review
Attachment #1
not attached*
E.K. Su
6/20 p.1

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

Date of Issuance:							
OFFICE	DL:LB.#4/LA	DL:LB.#4	OELD	DL:LB.#4	AD:L/DL	DIR/DL	
SURNAME	*MRushbrook/hmc	*RBirke	*Eketchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/26/81	6/ /81	6/ /81	6/ /81	

- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of this amendment to Facility Operating License No. NPF-9 is in accordance with 10 CFR Part 51, of the Commission's regulations and all applicable requirements have been satisfied;
- I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license amendment will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
- J. Prior public notice of this licensing action was given in, "Receipt of Application for Facility Operating Licenses; Availability of Applicant's Environmental Report, and Consideration of Issuance of Facility Operating Licenses and Notice of Opportunity for Hearing" (39 Fed. Reg. 20833-34; June 14, 1974). Hearings were held in connection with admitted contentions with respect to the operating license applications on March 28-31, April 1, 19-22, 1977; August 22-24, 30-31, 1978; and February 24-27, March 3-6, 10-13, 17-19, 1981, and an Initial Decision and a Supplemental Initial Decision issued, respectively, on April 18, 1979 and May 26, 1981.
2. Accordingly, the license is amended by changing paragraph 2.C.(1) of Facility Operating License NPF-9 to read as follows:
- 2.C.(1) Maximum Power Level
- The licensee is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% power).
3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Date of Issuance:

*E.K. 6/29/81 -
comment on
Dir. Amend. #2 and
on Notice of Hearing
and 101 Operation
of License + application.*

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	LA:LB #4/DL	DL:LB #4	OELD	DL:LB #4	AD:L/DL	DIR/DL	
SURNAME	*MRushbrook/hmc	RBirke1	*EKetchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/26/81	6/ /81	6/ /81	6/ /81	

DUKE POWER COMPANY

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Facility Operating License No. NPF-9
Amendment No. 2

1. The Nuclear Regulatory Commission (the Commission) with respect to full power - full term operation of McGuire Nuclear Station, Unit 1 has found that:
 - A. The application for license filed by the Duke Power Company (the licensee) complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I and all required notifications to other agencies or bodies have been duly made;
 - B. Construction of the McGuire Nuclear Station, Unit 1 (the facility) has been substantially completed in conformity with Construction Permit No. CPPR-83 and the application, as amended, the provisions of the Act and the regulations of the Commission;
 - C. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
 - D. There is reasonable assurance: (i) that the activities authorized by this operating license can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - E. The licensee is technically and financially qualified to engage in the activities authorized by this license in accordance with the Commission's regulations set forth in 10 CFR Chapter I;
 - F. The licensee has satisfied the applicable provisions of 10 CFR Part 140, "Financial Protection Requirements and Indemnity Agreements", of the Commission's regulations;
 - G. The issuance of this license will not be inimical to the common defense and security or to the health and safety of the public;

OFFICE							

- H. After weighing the environmental, economic, technical, and other benefits of the facility against environmental and other costs and considering available alternatives, the issuance of this amendment to Facility Operating License No. NPF-9 is in accordance with 10 CFR Part 51, of the Commission's regulations and all applicable requirements have been satisfied;
- I. The receipt, possession, and use of source, byproduct and special nuclear material as authorized by this license will be in accordance with the Commission's regulations in 10 CFR Parts 30, 40 and 70.
- J. Prior public notice of this licensing action was given in, "Receipt of Application for Facility Operating License; Availability of Applicant's Environmental Report; and Consideration of Issuance of Facility Operating Licenses and Notice of Opportunity for Hearing" (39 Fed. Reg. 20833-34; June 14, 1974). Hearings were held in connection with admitted contentions with respect to the operating license applications on March 28-31, April 1, 19-22, 1977; August 22-24, 30-31, 1978; and February 24-27, March 3-6, 10-13, 17-19, 1981, and an Initial Decision and Supplemental Decision issued, respectively, on April 18, 1979 and May 26, 1981.
2. Accordingly, the license is amended by changing paragraph 2.C.(1) of Facility Operating License NPF-9 to read as follows:
- 2.C.(1) Maximum Power Level
- The licensee is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% power).
3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Date of Issuance:

E.K. - 6/29 E.K. for committee not comments for Annual #2 note. D.L. & F.R.

*NOTE SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	LA:LB.#4/DL	DL:LB.#4	OELD	DL:LB.#4	AD:L/DL	DIR/DL	
SURNAME	*MRushbrook/hmc	*RBinkel	EKitchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/26/81	6/ /81	6/ /81	6/ /81	

DUKE POWER COMPANY

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Facility Operating License No. NPF-9
Amendment No. 2

1. The Nuclear Regulatory Commission (the Commission) has found that: *with respect to full power - full term operation of McGuire Nuclear Station, Unit 1*

- Make (Repeat) ALL FINDINGS made in NPF-9 for 5% here for 100% O.T.; i.e., repeat D.L. findings para. 2.A-2.I, here.*
- A. ~~The issuance of this license Amendment to Duke Power Company (Licensee), for its McGuire Nuclear Station, Unit 1 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations set forth in 10 CFR Chapter I;~~
- B. ~~The facility will operate in conformity with the license, as amended, the provisions of the Act, and the regulations of the Commission;~~
- C. ~~There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;~~
- D. ~~The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and~~
- E. ~~The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.~~
- F. ~~Prior public notice of this amendment was not required since it does not involve a significant hazards consideration.~~

Add Insert "A" as last lettered subpara. under para. 1.

2. Accordingly, the license is amended by changing paragraph 2.C.(1) of Facility Operating License NPF-9 to read as follows:

Add: Commission conditions if any
2.C.(1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% power).

3. This license amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Date of Issuance:

*6/29-8.K. see comments on Amendment 2
Subject to compliance on Amendment 2
with comments on Amendment 2
Amendment 2 note also addition
to cc list.*

OFFICE	LA:LB #4/DL	DL:LB #4	OELD	DL:LB #4	AD:L/DL	DIR/DL	
SURNAME	MRushnok/hmc	RBirke	EKitchen	EAdensam	RTedesco	DEisenhut	
DATE	6/24/81	6/24/81	6/25/81	6/25/81	6/25/81	6/25/81	

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-369

DUKE POWER COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE NO. NPF-9

Notice is hereby given that the U. S. Nuclear Regulatory Commission (the Commission), pursuant to the Initial Decision dated April 18, 1979, and the Supplemental Initial Decision dated May 26, 1981, respectively, of the Atomic Safety and Licensing Board, and pursuant to Commission Order dated June 29, 1981, has issued Amendment No. 2 to Facility Operating License No. NPF-9 to the Duke Power Company for its McGuire Nuclear Station, Unit 1. The license amendment authorizes operation of the McGuire Nuclear Station, Unit No. 1 at reactor core power levels not in excess of 3411 megawatts thermal (100% of rated power) in accordance with the provisions of the license, as amended, and the Technical Specifications and the Environmental Protection Plan. The McGuire Nuclear Station, Unit 1, is a pressurized water reactor located near Charlotte in Mecklenburg County, North Carolina. This amendment is effective as of its date of issuance.

The Initial Decision and the Supplemental Initial Decision are subject to review by the Atomic Safety and Licensing Appeal Board prior to their becoming final. Any decision or action taken by the Atomic Safety and Licensing Appeal Board in connection with the Initial Decision and the Supplemental Initial Decision may be reviewed by the Commission.

The application for this licensing action which is included as part of the applications for an operating license for McGuire Nuclear Station, Unit No. 1, complies with the standards and the requirements of the Act and the Commission's

OFFICE	rules and regulations. The Commission has made appropriate findings as required					
SURNAME	8107140344 810708 PDR ADDCK 05000369 PDR					
DATE	P					

by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the amendment. The application for the license, which includes Amendment No. 2 complies with the standards and requirements of the Act and the Commission's regulations.

Prior public notice of this licensing action was given in, "Receipt of Application for Facility Operating Licenses; Availability of Applicant's Environmental Report; and Consideration of Issuance of Facility Operating Licenses and Notice of Opportunity for Hearing" (39 Fed. Reg. 20833-34; June 14, 1974). Hearings were held in connection with admitted contentions with respect to the operating license applications on March 28-31, April 1, 19-22, 1977; August 22-24, 30-31, 1978; and February 24-27, March 3-6, 10-13, 17-19, 1981, and an Initial Decision and a Supplemental Initial Decision issued, respectively, on April 18, 1979 and May 26, 1981.

For further details in respect to this action, see (1) Amendment No. 2 to Facility Operating License NPF-9; (2) Amendment No. 1 to Facility Operating License NPF-9 w/revised pages to Technical Specifications, Appendix A, dated June 19, 1981; (3) Facility Operating License NPF-9 w/Technical Specifications, Appendix A & Environmental Protection Plan, Appendix B, NUREG-0759 Revision 1, dated June 12, 1981; (4) License NPF-9 for Fuel Loading and Zero Power Testing complete with Technical Specifications (NUREG-0759) dated January 23, 1981; (5) Amendment No. 1 to License NPF-9 for Fuel Loading and Zero Power Testing, dated January 28, 1981; (6) Amendment No. 2 to License NPF-9 for Fuel Loading and Zero Power Testing, dated April 2, 1981; (7) the report of the Advisory Committee on

[illegible]

Reactor Safeguards, dated April 12, 1978; (8) the Office of Nuclear Reactor Regulation's Safety Evaluation Report, dated March 1978 (NUREG-0422) and Supplements 1 through 5; (9) the Final Safety Analysis Report and Amendments thereto; (10) the Final Environmental Statement, dated May 30, 1974 and supplements thereto; (11) the Floodplain Aspects of the McGuire Nuclear Plant Site, dated September 3, 1980; (12) the Initial Decision, dated April 18, 1979; (13) the Supplemental Initial Decision, dated May 26, 1981; and (14) Commission Order dated June 29, 1981.

Items 1 through 6 and 11 are available upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing. Item 7 is included as Appendix B to Supplement No. 1 of item 8. Copies of items 8 and 10 may be purchased at current rates from the National Technical Information Service, Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161. All items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

Dated at Bethesda, Maryland, this day of .

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor Adensam, Acting Chief
Licensing Branch No. 4
Division of Licensing

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	LA/LB.#4:DLDL/LB.#4OELD.....	..DL/LB.#4			
SURNAME	*MRushbrook/hmc	*RBinkel	*EKetchen	*EAdensam			
DATE	6/24/81	6/24/81	6/26/81	7/1/81			

Reactor Safeguards, dated April 12, 1978; (8) the Office of Nuclear Reactor Regulation's Safety Evaluation Report, dated March 1978 (NUREG-0422) and Supplements 1 through 5; (9) the Final Safety Analysis Report and Amendments thereto; (10) the Final Environmental Statement, dated May 30, 1974 and supplements thereto; (11) the Floodplain Aspects of the McGuire Nuclear Plant Site, dated September 3, 1980; (12) the Initial Decision, dated April 18, 1979; (13) the Supplemental Initial Decision, dated May 26, 1981; and (14) Commission Order dated June 29, 1981.

Items 1 through 6 and 11 are available upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing. Copies of items 8 and 10 may be purchased at current rates from the National Technical Information Service, Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161. All items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

Dated at Bethesda, Maryland, this day of .

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor Adensam, Acting Chief
Licensing Branch No. 4
Division of Licensing

Eck *See comment 8/20/81 0.1 & subj to serial Attach #1 (not attached)*

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	LA:LB #4/DL	DL:LB #4	OELD	DL:LB #4			
SURNAME	MRushbrook/hmc	*RBirke1	*EKetchen	EAdensam			
DATE	6/24/81	6/24/81	6/26/81	6/.../81			

Reactor Safeguards, dated April 12, 1978; (8) the Office of Nuclear Reactor Regulation's Safety Evaluation Report, dated March 1978 (NUREG-0422) and Supplements 1 through 5; (9) the Final Safety Analysis Report and Amendments thereto; (10) the Final Environmental Statement, dated May 30, 1974 and supplements thereto; (11) the Floodplain Aspects of the McGuire Nuclear Plant Site, dated September 3, 1980; (12) the Initial Decision, dated April 18, 1979; and (13) the Supplemental Initial Decision, dated May 26, 1981.

Items 1 through 6 and 11 are available upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing. Copies of items 8 and 10 may be purchased at current rates from the National Technical Information Service, Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161. All items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

100w about this 7?

Dated at Bethesda, Maryland, this day of .

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor Adensam, Acting Chief
Licensing Branch No. 4
Division of Licensing

*8/26/29-522
minor comments on
Amend. #2 D.C.
@ F.R. note; Reami
Coord. re: operation of
reactor system*

*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	LA:LB.#4/LD.	DL:LB.#4	OELD	DL:LB.#4			
SURNAME	*MRushbrook/hmc	RBirke1	*EKetchen	EAdensam			
DATE	6/24/81	6/24/81	6/26/81	6/ /81			

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-369

DUKE POWER COMPANY

NOTICE OF ISSUANCE OF AMENDMENT TO
FACILITY OPERATING LICENSE NO. NPF-9

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 2 to Facility Operating License No. NPF-9. This amendment authorizes operation of the McGuire Nuclear Station, Unit No. 1 at reactor core power levels not in excess of 3411 megawatts thermal (100% of rated power). The McGuire Nuclear Station Unit 1 is a pressurized water reactor located near Charlotte, North Carolina in Mecklenburg County. This amendment is effective as of its date of issuance.

The application complies with the standards and the requirements of the Act and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the amendment.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR Section 51.5(d)(4) and environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details in respect to this action, see (1) Amendment No. 2 to Facility Operating License NPF-9; (2) Amendment No. 1 to Facility Operating License NPF-9 w/revised pages to Technical Specifications, Appendix A, dated June 19, 1981; (3) Facility Operating License NPF-9 w/Technical Specifications, Appendix A & Environmental Protection Plan, Appendix B, NUREG-0759 Revision 1,

OFFICE ▶							
SURNAME ▶							
DATE ▶							

dated June 12, 1981; (4) License NPF-9 for Fuel Loading and Zero Power Testing complete with Technical Specifications (NUREG-0759) dated January 23, 1981; (5) Amendment No. 1 to License NPF-9 for Fuel Loading and Zero Power Testing, dated January 28, 1981; (6) Amendment No. 2 to License NPF-9 for Fuel Loading and Zero Power Testing, dated April 2, 1981; (7) the report to the Advisory Committee on Reactor Safeguards, dated April 12, 1978; (8) the Office of Nuclear Reactor Regulation's Safety Evaluation Report, dated March 1978 (NUREG-0422) and Supplements 1 through 5; (9) the Final Safety Analysis Report and Amendments thereto; (10) the Final Environmental Statement, dated May 30, 1974 and supplements thereto; (11) the Floodplain Aspects of the McGuire Nuclear Plant Site, dated September 3, 1980; (12) the Initial Decision, dated April 18, 1979; and (13) the Supplemental Initial Decision, dated May 26, 1981.

Items 1 through 6 and 11 are available upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing. Copies of items 8 and 10 may be purchased at current rates from the National Technical Information Service, Department of Commerce, 5285 Port Royal Road, Springfield, Virginia 22161. All items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

Dated at Bethesda, Maryland, this day of .

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor Adensam, Acting Chief
Licensing Branch No. 4

OFFICE	A:LB.#4/DL	DL:LB.#4	OELD	Division of Licensing		
SURNAME	MRushbrook/hmc	RBirke	EKetchen	DL:LB.#4	EAdensam	
DATE	6/24/81	6/24/81	6/24/81	6/24/81		