

NUCLEAR REGULATORY COMMISSION MASHINGTON, D. C. 20555 May 14, 1985

Docket Nos: 50-369 and 50-370

Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Technical Specification Corrections

My March 22, 1985, letter transmitted Amendment No. 42 to Facility Operating License NPF-9 and Amendment No. 23 to Facility Operating License No. NPF-17 for the McGuire Nuclear Station, Units 1 and 2.

Two of the Technical Specification pages attached to these amendments contained typographical errors. Enclosed are corrected pages.

Please replace pages 2-5 and 3/4 3-9 in Amendments 42 and 23 with the attached corrected pages.

Sincerely,

3

J. allencem

Elinor G. Adensam, Chief Licensing Branch No. 4 Division of Licensing

Enclosures: As stated

cc w/encl: See next page

DESIGNATED ORIGINAL Certified By



McGuire

Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242 cc: Mr. A. Carr Duke Power Company P. 0. Box 33189 422 South Church Street Charlotte, North Carolina 28242 Mr. F. J. Twogood Power Systems Division Westinghouse Electric Corp. P. 0. Box 355 Pittsburgh, Pennsylvania 15230 Mr. Robert Gill Duke Power Company Nuclear Production Department P. O. Box 33189 Charlotte, North Carolina 28242 J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1200 Seventeenth Street, N.W. Washington, D. C. 20036 Mr. Wm. Orders Senior Resident Inspector c/o U.S. Nuclear Regulatory Commission Route 4, Box 529 Hunterville, North Carolina 28078 Regional Administrator U.S. Nuclear Regulatory Commission, Region II 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323 R. S. Howard **Operating Plants Projects** Regional Manager Westinghouse Electric Corporation - R&D 701 P. O. Box 2728 Pittsburgh, Pennsylvania 15230

FUNC	TIONAL UNIT	RESPONSE TIME
1.	Manual Reactor Trip	N.A.
2.	Power Range, Neutron Flux	<pre>< 0.5 second*</pre>
3.	Power Range, Neutron Flux, High Positive Rate	N.A.
4.	Power Range, Neutron Flux, High Negative Rate	<pre>< 0.5 second*</pre>
5.	Intermediate Range, Neutron Flux	Ν.Α.
6.	Source Range, Neutron Flux	Ν.Α.
7.	Overtemperature ∆T	<pre></pre>
8.	Overpower D T	<pre>< 6.0 (Unit 1), 8.0 (Unit 2) seconds*</pre>
9.	Pressurizer PressureLow	<pre>< 2.0 seconds</pre>
10.	Pressurizer PressureHigh	< 2.0 seconds
11.	Pressurizer Water LevelHigh	«N.A.

Neutron detectors are exempt from response time testing. Response time of the neutron flux signal portion of the channel shall be measured from detector output or input of first electronic component in channel.

ι.

3/4 3-9

McGUIRE -

UNITS

l and

 \sim

8505230686 850514 PDR ADOCK 05000369 PDR

> Amendment No.42(Unit 1) Amendment No.23(Unit 2)

Ŧ

TABLE 3.3-2

.

REACTOR TRIP SYSTEM INSTRUMENTATION RESPONSE TIMES

TABLE 2.2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNC	TIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
1.	Manual Reactor Trip	N.A.	N.A.
2.	Power Range, Neutron Flux	Low Setpoint -< 25% of RATED THERMAL POWER	Low Setpoint - ≤ 26% of RATED THERMAL POWER
		High Setpoint - ≤ 109% of RATED THERMAL POWER	High Setpoint ~ <u><</u> 110% of RATED THERMAL POWER
3.	Power Range, Neutron Flux, High Positive Rate	< 5% of RATED THERMAL POWER with \overline{a} time constant > 2 seconds	< 5.5% of RATED THERMAL POWER \overline{w} ith a time constant \geq 2 seconds
4.	Power Range, Neutron Flux, High Negative Rate	< 5% of RATED THERMAL POWER with \overline{a} time constant > 2 seconds	< 5.5% of RATED THERMAL POWER \overline{w} ith a time constant \geq 2 seconds
5.	Intermediate Range, Neutron Flux	< 25% of RATED THERMAL POWER \leftarrow	< 30% of RATED THERMAL POWER
6.	Source Range, Neutron Flux	< 10 ⁵ counts per second	\leq 1.3 x 10 ⁵ counts per second
7.	Overtemperature ΔT	See Note 1	See Note 3
8.	Overpower ∆T	See Note 2	See Note 3
9.	Pressurizer PressureLow	> 1945 psig	> 1935 psig
10.	Pressurizer PressureHigh	< 2385 psig	< 2395 psig
11.	Pressurizer Water LevelHigh	< 92% of instrument span	< 93% of instrument span
12.	Low Reactor Coolant Flow	> 90% of design flow per loop*	> 89% of design flow per loop*

. .

*Design flow is 98,400 gpm per loop for Unit 1 and 97,220 gpm per loop for Unit 2.

McGUIRE - UNITS 1 and

 \sim

• •

2-5

Amendment No. 42(Unit 1) Amendment No. 23(Unit 2)