

Docket Nos.: 50-369 and
50-370

22 APR 1986

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: TECHNICAL SPECIFICATION CORRECTIONS

My letter of April 7, 1986, transmitted Amendment No. 54 to Facility Operating License NPF-9 and Amendment No. 35 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2.

One of the Technical Specification pages attached to these amendments contained a typographical error. Enclosed is the corrected page.

Please replace page 3/4 3-3 in Amendments 54 and 35 with the enclosed corrected page.

Sincerely,

151

B. J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A

Enclosure: As stated

cc: See next page

DISTRIBUTION:

- Docket File
- NRC PDR
- Local PDR
- PD#4 Reading File
- BJYoungblood
- OELD
- EJordan
- BGrimes
- JPartlow
- DHood
- MDuncan
- ACRS (10)
- LHarmon
- T. Barnhart (4)
- WJones
- OPA
- LFMB

DSH
PWR#4:DPWR-A
DHood:lr
04/18/86

md
4/18/86

DSH
PWR#4:DPWR-A
BJYoungblood
04/18/86

8604280399 860422
PDR ADOCK 05000369
PDR

047

Mr. H. B. Tucker
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A. Carr
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, Pennsylvania 15230

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Box 33189
Charlotte, North Carolina 28242

Chairman, North Carolina Utilities
Commission
Dobbs Building
430 North Salisbury Street
Raleigh, North Carolina 27602

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P.O. Box 12200
Raleigh, North Carolina 27605

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

L. L. Williams
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation - R&D 701
P. O. Box 2728
Pittsburgh, Pennsylvania 15230

8604280404 860422
PDR ADDCK 05000369
PDR

MCGUIRE - UNITS 1 and 2

3/4 3-3

Amendment No54(Unit 1)
Amendment No35(Unit 2)

TABLE 3.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. Overpower ΔT					
Four Loop Operation	4	2	3	1, 2	6 [#]
Three Loop Operation	(**)	(**)	(**)	(**)	(**)
9. Pressurizer Pressure-Low	4	2	3	1	6 [#] (***)
10. Pressurizer Pressure--High	4	2	3	1, 2	6 [#] (***)
11. Pressurizer Water Level--High	3	2	2	1	6 [#]
12. Low Reactor Coolant Flow					
a. Single Loop (Above P-8)	3/loop	2/loop in any operating loop	2/loop in each operating loop	1	6 [#]
b. Two Loops (Above P-7 and below P-8)	3/loop	2/loop in two operating loops	2/loop each operating loop	1	6 [#]
13. Steam Generator Water Level--Low-Low	4/stm. gen.	2/stm. gen. in any operating stm. gen.	3/stm. gen. each operating stm. gen.	1, 2	6 [#] (***)