POR

April 17, 1986

Docket No. 50-369 and 50-370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Amendment No.55 to Facility Operating License NPF-9 and Amendment No.36 to Facility Operating License NPF-17 -McGuire Nuclear Station, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No.55 to Facility Operating License NPF-9 and Amendment No.36 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. These amendments are issued in response to your application dated April 1, 1985 and supplemental letter dated October 14, 1985.

The amendments revise a limiting condition for operation and bases associated with Technical Specification 3.7.10.1, Fire Suppression Water System. The amendments are effective as of their date of issuance.

A copy of the related safety evaluation supporting Amendment No.55 to Facility Operating License NPF-9 and Amendment No.36 to Facility Operating License NPF-17 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Original signed by: D. Hood

B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Enclosures: 1. Amendment No.<sup>55</sup> to NPF-9

- 2. Amendment No.36 to NPF-17
- 3. Safety Evaluation

8604290067 860417

ADOCK

cc w/enclosures: See next page DISTRIBUTION: See attached page

PWR#4/	DPWR-A	PWR## APPWR-A
DHood/	kab	MDuncan
04/	/86	04/ 7/86

000369

D Slt for PWR#4/DPWR-A BJYoungblood 04/7/86 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

- 2 -

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.<sup>55</sup>, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by: D. Hood

B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: April 17, 1986

PWR#A/DAWR-A MDuncan:kab 04/ /86 D51<sup>+</sup> PWR#4/DPWR-A DHood 04/ 2 /86



DSH fm PWR#4/DPWR-A BJYoungblood 04/2, /86

- Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:
  - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.36, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

\2\

B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: April 17, 1986

PWR#A/APWR-A MDuncan:kab 04///86 >><sup>1†</sup> PWR#4/DPWR-A DHood 04/ ∠ /86



DSI In PWR#4/DPWR-A BJYoungblood 04/ 2/86



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

April 17, 1986

Docket No. 50-369 and 50-370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Amendment No. 55 to Facility Operating License NPF-9 and Amendment No. 36 to Facility Operating License NPF-17 -McGuire Nuclear Station, Units 1 and 2

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 55 to Facility Operating License NPF-9 and Amendment No. 36 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. These amendments are issued in response to your application dated April 1, 1985 and supplemental letter dated October 14, 1985.

The amendments revise a limiting condition for operation and bases associated with Technical Specification 3.7.10.1, Fire Suppression Water System. The amendments are effective as of their date of issuance.

A copy of the related safety evaluation supporting Amendment No.55 to Facility Operating License NPF-9 and Amendment No.36 to Facility Operating License NPF-17 is enclosed.

Notice of issuance will be included in the Commission's next bi-weekly <u>Federal</u> Register notice.

Sincerely,

FARL HOOD

B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Enclosures:

- 1. Amendment No. 55 to NPF-9
- 2. Amendment No. 36 to NPF-17
- 3. Safety Evaluation

cc w/enclosures: See next page



# UNITED STATES

DUKE POWER COMPANY

# DOCKET NO. 50-369

# MCGUIRE NUCLEAR STATION, UNIT 1

#### AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 55 License No. NPF-9

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-9 filed by the Duke Power Company (the licensee) dated April 1, 1985, and supplemented October 14, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8604290071 860417 PDR ADOCK 05000369 P PDR

- 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:
  - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.55, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

ARL HOUS

HT B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: April 17, 1986

#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555



# DUKE POWER COMPANY

# DOCKET NO. 50-370

# MCGUIRE NUCLEAR STATION, UNIT 2

# AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 36 License No. NPF-17

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-17 filed by the Duke Power Company (the licensee) dated April 1, 1985, and supplemented October 14, 1985, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:
  - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No.36, are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

TARL HEOT

B. J. Youngblood, Director PWR Project Directorate #4 Division of PWR Licensing-A

Attachment: Technical Specification Changes

Date of Issuance: April 17, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 55

# FACILITY OPERATING LICENSE NO. NPF-9

# DOCKET NO. 50-369

### AND

# TO LICENSE AMENDMENT NO. 36

#### FACILITY OPERATING LICENSE NO. NPF-17

# DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change. The corresponding over-leaf pages are also provided to maintain document completeness.

Amended	Overleaf
Page	Page
3/4 7-32	3/4 7-31
B 3/4 7-6	

# PLANT SYSTEMS

# SURVEILLANCE REQUIREMENTS (Continued)

- b. Stored sources not in use Each sealed source and fission detector shall be tested prior to use or transfer to another licensee unless tested within the previous 6 months. Sealed sources and fission detectors transferred without a certificate indicating the last test date shall be tested prior to being placed into use; and
- c. Startup sources and fission detectors Each sealed startup source and fission detector shall be tested within 31 days prior to being subjected to core flux or installed in the core and following repair or maintenance to the source.

4.7.9.3 Reports - A report shall be prepared and submitted to the Commission on an annual basis if sealed source or fission detector leakage tests reveal the presence of greater than or equal to 0.005 microCurie of removable

McGUIRE - UNITS 1 and 2

#### PLANT SYSTEMS

# 3/4.7.10 FIRE SUPPRESSION SYSTEMS

# FIRE SUPPRESSION WATER SYSTEM

# LIMITING CONDITION FOR OPERATION

- 3.7.10.1 The Fire Suppression Water System shall be OPERABLE with:
  - a. At least two fire suppression pumps (either A and C or B and C), each with a capacity of 2500 gpm, with their discharge aligned to the fire suppression header; and
  - b. An OPERABLE flow path capable of taking suction from Lake Norman and transferring the water through distribution piping with OPERABLE sectionalizing control or isolation valves to the yard hydrant curb valves, the last valve ahead of the water flow alarm device on each sprinkler or hose standpipe, and the last valve ahead of the deluge valve on each Deluge or Spray System required to be OPERABLE per Specifications 3.7.10.2 and 3.7.10.4.

APPLICABILITY: At all times.

#### ACTION:

- a. With one of the above required pump and/or one water supply inoperable, restore the inoperable equipment to OPERABLE status within 7 days or provide an alternate backup pump or supply. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.
- b. With the Fire Suppression Water System otherwise inoperable establish a backup Fire Suppression Water System within 24 hours.

McGUIRE - UNITS 1 and 2

Amendment No. 55 (Unit 1) Amendment No. 36 (Unit 2)

#### SNUBBERS (Continued)

The service life of a snubber is established via manufacturer input and information through consideration of the snubber service conditions and associated installation and maintenance records (newly installed snubber, seal replaced, spring replaced, in high radiation area, in high temperature area, etc. . .). The requirement to monitor the snubber service life is included to ensure that the snubbers periodically undergo a performance evaluation in view of their age and operating conditions. These records will provide statistical bases for future consideration of snubber service life. The requirements for the maintenance of records and the snubber service life review not intended to affect plant operation.

# 3/4.7.9 SEALED SOURCE CONTAMINATION

The limitations on removable contamination for sources requiring leak testing, including alpha emitters, is based on 10 CFR 70.39(c) limits for plutonium. This limitation will ensure that leakage from Byproduct, Source, and Special Nuclear Material sources will not exceed allowable intake values.

Sealed sources are classified into three groups according to their use, with Surveillance Requirements commensurate with the probability of damage to a source in that group. Those sources which are frequently handled are required to be tested more often than those which are not. Sealed sources which are continuously enclosed within a shielded mechanism (i.e., sealed sources within radiation monitoring or boron measuring devices) are considered to be stored and need not be tested unless they are removed from the shielded mechanism.

# 3/4.7.10 FIRE SUPPRESSION SYSTEMS

The OPERABILITY of the Fire Suppression Systems ensures that adequate fire suppression capability is available to confine and extinguish fires occurring in any portion of the facility where safety-related equipment is located. The Fire Suppression System consists of the water system, spray, and/or sprinklers, Halon, and fire hose stations. The collective capability of the Fire Suppression Systems is adequate to minimize potential damage to safety-related equipment and is a major element in the facility fire protection program.

In the event that portions of the Fire Suppression Systems are inoperable, alternate backup fire-fighting equipment is required to be made available in the affected areas until the inoperable equipment is restored to service. When the inoperable fire-fighting equipment is intended for use as a backup means of fire suppression, a longer period of time is allowed to provide an alternate means of fire fighting than if the inoperable equipment is the primary means of fire suppression. For McGuire Nuclear Station pumps A and B serve as a backup for each other. Pump C is located separately with independent dedicated power supply.

McGuire - UNITS 1 and 2

Amendment No.55(Unit 1) Amendment No.36(Unit 2)



#### UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

#### SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

# RELATED TO AMENDMENT NO.55 TO FACILITY OPERATING LICENSE NPF-9

AND AMENDMENT NO. 36TO FACILITY OPERATING LICENSE NPF-17

#### DUKE POWER COMPANY

DOCKET NOS. 50-369 AND 50-370

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

#### INTRODUCTION

By letter dated April 1, 1985, Duke Power Company (the licensee) requested changes to Technical Specification 3.7.10.1, "Fire Suppression System" to require that either fire suppression Pumps A and C or Pumps B and C be operable at all times. The requested change would also supplement the associated Bases to state that, for McGuire Nuclear Station, Pumps A and B serve as backup for each other, and that Pump C is located separately with independent dedicated power supply. By letter dated October 14, 1985, the licensee provided additional information in support of this request.

#### EVALUATION

The previous Specification 3.7.10.1 required at least two of the fire suppression pumps (Pump A, B, or C) to be operable at all times. This allowed any one of the three pumps to be indefinitely inoperable. For example, fire suppression Pump C could have been inoperable indefinitely as long as Pumps A and B were operable.

The McGuire fire suppression water system consists of three fire pumps, each of which is electrically powered. Pumps A and B are powered by switchgear in the main switchyard, and Pump C is powered by a dedicated substation. None of the pumps is powered from the safety busses. Consequently, under the previous Technical Specification 3.7.10.1, if fire Pumps A and B were lost as a result of loss of their offsite power, a total loss of fire suppression water would have occurred if fire Pump C were out of service at the time. This situation negated the benefits of the independent offsite power source for fire Pump C. The change implemented by these amendments re-establishes this benefit by requiring as a limiting condition for operation that Pump C in combination with one of the other two pumps be operable at all times. The change, therefore, improves the reliability of the fire suppression system by imposing a more restrictive condition for operation with an inoperable fire pump. It causes no changes in our previous conclusions regarding the acceptability of the McGuire fire suppression water system. Moreover, based upon our review of this change and the supplemental information provided in the licensee's October 14, 1985, letter, we find that the fire pumps meet the intent of the fire protection guidelines of Appendix A to Branch Technical Position APCSB 9.5-1. The change is, therefore, acceptable.

8604290074 860417 PDR ADDCK 05000369 P PDR

#### ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant change in the types or significant increase in the amounts of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that this amendment involves no significant hazards consideration, and there have been no public comments on such findings. Accordingly, this amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9).

Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of this amendment.

#### CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (50 FR 29009) on July 17, 1985, and consulted with the state of North Carolina. No public comments were received, and the state of North Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations and the issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Darl S. Hood, PWR#4 S. West, PAPS J. Knight, PAEI

Dated: April 17, 1986