



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

JUN 15 1984

Docket Nos: 50-369
and 50-370

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Order Confirming Licensee Commitments
on Emergency Response Capability

The Commission has issued the enclosed Order confirming your commitments on emergency response capability for the McGuire Nuclear Station, Units 1 and 2. This Order is based on your letter dated April 14, 1983, committing to the actions specified in the Order.

A copy of this Order is being filed with the Office of the Federal Register for publication.

Sincerely,

5/

Elinor G. Adensam, Chief
Licensing Branch No. 4
Division of Licensing

Enclosure:
Order

cc w/encl:
See next page

DESIGNATED ORIGINAL

Certified By

[Signature]

8406280276 840615
PDR ADOCK 05000369
F PDR

McGuire

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. A. Carr
Duke Power Company
P.O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. G. A. Copp
Duke Power Company
Nuclear Production Department
P.O. Box 33189
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.
Debevoise & Liberman
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Wm. Orders
Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Hunterville, North Carolina 28078

James P. O'Reilly, Regional Admin.
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Attorney General
Department of Justice
Justice Building
Raleigh, North Carolina 27602

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Bruce Blanchard
Environmental Projects Review
Department of the Interior
Room 4256
18th and C Street, N.W.
Washington, D. C. 20240

EIS Coordinator
U.S. Environmental Protection Agency
Region IV Office
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Chairman, North Carolina
Utilities Commission
430 North Salisbury Street
Dobbs Building
Raleigh, North Carolina 27602

R. S. Howard
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation -
R&D 701
P.O. Box 2728
Pittsburgh, Pennsylvania 15230

| | | | | | | | |
|---------|--|--|--|--|--|--|--|
| OFFICE | | | | | | | |
| SURNAME | | | | | | | |
| DATE | | | | | | | |

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

DUKE POWER COMPANY

(McGuire Nuclear Station
Unit Nos. 1 & 2)

)
)
)
)
)
)

Docket Nos. 50-369
50-370

ORDER CONFIRMING LICENSEE COMMITMENTS
ON EMERGENCY RESPONSE CAPABILITY

I.

Duke Power Company (Duke) is the holder of Facility Operating License Nos. NPF-9 and NPF-17 which authorize the operation of the McGuire Nuclear Station, Unit Nos. 1 and 2 (the facilities) at steady-state power levels not in excess of 3411 megawatts thermal. The facilities are pressurized water reactors (PWRs) located in Mecklenburg County, North Carolina.

II.

Following the accident at Three Mile Island Unit No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial additional protection in the operation of nuclear facilities and significant upgrading of emergency response capability based on the experience from the accident at TMI-2 and the official studies and investigations of the accident. The requirements are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements," and in

8406280278 840615
PDR ADDCK 05000369
F PDR

Supplement 1 to NUREG-0737, "Requirements for Emergency Response Capability."

Among these requirements are a number of items consisting of emergency response facility operability, emergency procedure implementation, addition of instrumentation, possible control room design modifications, and specific information to be submitted.

On December 17, 1982, a letter (Generic Letter 82-33) was sent to all licensees of operating reactors, applicants for operating licenses, and holders of construction permits enclosing Supplement 1 to NUREG-0737. In this letter operating reactor licensees and holders of construction permits were requested to furnish the following information, pursuant to 10 CFR 50.54(f), no later than April 15, 1983:

- (1) A proposed schedule for completing each of the basic requirements for the items identified in Supplement 1 to NUREG-0737, and
- (2) A description of plans for phased implementation and integration of emergency response activities including training.

III.

Duke responded to Generic Letter 82-33 by letter dated April 14, 1983, including commitments to complete the basic requirements. The attached Table summarizes Duke's schedular commitments or current status.

Duke's commitments include (1) dates for providing required submittals to the NRC, and (2) dates for implementing certain requirements.

The NRC staff reviewed Duke's April 14, 1983, letter and finds that the dates are reasonable, achievable dates for meeting the Commission requirements. The NRC

staff concludes that the schedule proposed by the licensee will provide timely upgrading of the licensee's emergency response capability.

In view of the foregoing, I have determined that the implementation of Duke's commitments are required in the interest of the public health and safety and should, therefore, be confirmed by an immediately effective Order.

IV.

Accordingly, pursuant to Sections 103, 161i, 161o and 182 of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED, EFFECTIVE IMMEDIATELY, THAT the licensees shall:

Implement the specific items described in the Attachment to this ORDER in the manner described in Duke's submittals noted in Section III herein no later than the dates in the Attachment.

Extensions of time for completing these items may be granted by the Director, Division of Licensing, for good cause shown.

V.

The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. Any request for a hearing should be addressed to the Director, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555. A copy should also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is to be held, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order. This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland,
this 15 day of June 1984

Attachment:
Licensee's Commitments on
Requirements Specified in
Supplement 1 to NUREG-0737

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

| TITLE | REQUIREMENT | LICENSEE'S COMPLETION SCHEDULE (OR STATUS) |
|---|---|---|
| 1. Safety Parameter Display System (SPDS) | 1a. Submit a safety analysis and an implementation plan to the NRC. | Complete |
| | 1b. SPDS fully operational and operators trained. | November 1984 |
| 2. Detailed Control Room Design Review (DCRDR) | 2a. Submit a program plan to the NRC. | Complete |
| | 2b. Submit a summary report to the NRC including a proposed schedule for implementation. | Complete |
| 3. Regulatory Guide 1.97 - Application to Emergency Response Facilities | 3a. Submit a report to the NRC describing how the requirements of Supplement 1 to NUREG-0737 have been or will be met. | Complete |
| | 3b. Implement (installation or upgrade) requirements. | Complete |

LICENSEE'S COMMITMENTS ON SUPPLEMENT 1 TO NUREG-0737

| TITLE | REQUIREMENT | LICENSEE'S COMPLETION SCHEDULE (OR STATUS) |
|--|--|---|
| 4. Upgrade Emergency Operating Procedures (EOPs) | 4a. Submit a Procedures Generation Package to the NRC. | Complete |
| | 4b. Implement the upgraded EOPs. | November 1984 |
| 5. Emergency Response Facilities | 5a. Technical Support Center fully functional. | Complete |
| | 5b. Operational Support Center fully functional. | Complete |
| | 5c. Emergency Operations Facility fully functional. | Complete |

ORDER - McGUIRE NUCLEAR STATION, UNITS 1 & 2

JUN 15 1984

DISTRIBUTION:

Docket Nos. 50-369/370

NRC PDR

Local PDR

TERA

NSIC

LB #4 r/f

E. Adensam

R. Birkel

M. Duncan

Attorney, OELD (CYR)

D. Eisenhut/R. Purple

R. Hartfield, MPA

R. Diggs, ADM

T. Barnhart (8)

J. Souder

A. Rosenthal, ASLAB

W. Jones, OA (10)

ACRS (16)

ASLBP

E. L. Jordan, DEQA:I&E

J. M. Taylor, DRP:I&E

L. J. Harmon, I&E File (2)

D. Brinkman

H. Denton

DESIGNATED ORIGINAL

Certified By

[Handwritten Signature]