

Docket Nos.: 50-369
and 50-370

MAY 13 1987

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Correction to License Amendments (TACs 55874/55875/59263/59264)

My May 6, 1987, letter forwarded Amendment No. 71 to Facility Operating License NPF-9 and Amendment No. 52 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. Attached to the letter were Technical Specification page changes. One of those pages contained a typographical error.

Please replace page 3/4 8-1 of the May 6 transmittal with the enclosed revised page.

Sincerely,

151
Darl Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

Enclosure:
TS Page 3/4 8-1

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	L. Harmon	ARM/LFMB
NRC PDR	W. Jones	
Local PDR	S. Varga/G. Lainas	
PRC System	T. Barnhart (8)	
PD#23 Reading	D. Hagan	
MDuncan	GPA/PA	
DHood	E. Butcher	
BJYoungblood Reading		
OGC-Bethesda		
ACRS (10)		
JPartlow		
EJordan		

8705180455 870513
PDR ADDCK 05000369
P PDR

PD#II-3/DRP-I/II
MDuncan/mac
05/13/87

PD#II-3/DRP-I/II
DHood
05/13/87

md
PD#II-3/DRP-I/II
for BJYoungblood
05/13/87



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

MAY 13 1987

Docket Nos.: 50-369
and 50-370

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Correction to License Amendments (TACs 55874/55875/59263/59264)

My May 6, 1987, letter forwarded Amendment No. 71 to Facility Operating License NPF-9 and Amendment No. 52 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. Attached to the letter were Technical Specification page changes. One of those pages contained a typographical error.

Please replace page 3/4 8-1 of the May 6 transmittal with the enclosed revised page.

Sincerely,

A handwritten signature in black ink that reads "Darl Hood". The signature is stylized with a large, sweeping initial "D" and "H".

Darl Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

Enclosure:
TS Page 3/4 8-1

cc w/enclosure:
See next page

Mr. H. B. Tucker
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Box 33189
Charlotte, North Carolina 28242

Chairman, North Carolina Utilities
Commission
Dobbs Building
430 North Salisbury Street
Raleigh, North Carolina 27602

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
701 Barbour Drive
Raleigh, North Carolina 27603-2008

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

L. L. Williams
Area Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 239
P. O. Box 355
Pittsburgh, Pennsylvania 15230

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the Onsite Essential Auxiliary Power System, and
- b. Two separate and independent diesel generators, each with:
 - 1) A separate day tank containing a minimum volume of 120 gallons of fuel,
 - 2) A separate Fuel Storage System containing a minimum volume of 28,000 gallons of fuel, and
 - 3) A separate fuel transfer pump.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

- a. With an offsite circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1a. within 1 hour and at least once per 8 hours thereafter; separately demonstrate the operability of two diesel generators by performing Surveillance Requirements 4.8.1.1.2a.4 and 4.8.1.1.2a.5 within 24 hours unless this surveillance was performed within the previous 24 hours, or unless the diesel is operating, restore at least two offsite circuits and two diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable*, demonstrate the OPERABILITY of the remaining A.C. source by performing Surveillance Requirement 4.8.1.1.1a. within 1 hour and at least once per 8 hours thereafter; demonstrate the operability of the remaining diesel generator by performing Surveillance Requirements 4.8.1.1.2a.4 and 4.8.1.1.2a.5 within 8 hours unless this surveillance was performed within the previous 24 hours, or unless the diesel is operating**; restore at least one of the inoperable sources to OPERABLE status within 12 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours; with the diesel

*A diesel generator shall be considered to be inoperable from the time of failure until it satisfies the requirements of Surveillance Requirements 4.8.1.1.2a.4) and 4.8.1.1.2a.5).

**This test is required to be completed regardless of when the inoperable diesel generator is restored to OPERABLE status. The provisions of Specification 3.0.2 are not applicable.