

Docket Nos. 50-369
50-370

16 JUN 1986

Mr. H.B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

My letter of April 28, 1986, transmitted Amendment No. 56 to Facility Operating License NPF-9 and Amendment No. 37 to Facility Operating License No. NPF-17 for the McGuire Nuclear Station, Units 1 and 2.

Two of the Technical Specification pages attached to these amendments contained errors. Enclosed are corrected pages.

Please replace pages 3/4 3-27 and 3/4 3-36 in Amendments 56 and 37 with the enclosed corrected pages.

Sincerely,

151

Darl Hood, Project Manager
PWR Project Directorate #4
Division of PWR-A Licensing

Enclosures: As stated

cc: See next page

DISTRIBUTION:

Docket File
NRC PDR
Local PDR
PRC System
NSIC
PWR#4 Rdg
MDuncan
DHood
BJYoungblood Rdg
LHarmon
OELD
ACRS (10)
WJones
EButcher
NThompson
EJordan
BGrimes
JPartlow
TBarnhart (8)
OPA
LFMB

PWR#4/DPWR-A
MDuncan/rad
06/16/86

DSH
PWR#4/DPWR-A
DHood
06/16/86

DSH for
PWR#4/DPWR-A
BJYoungblood
06/16/86

8606240142 860616
PDR ADOCK 05000369
P PDR

Mr. H. B. Tucker
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A. Carr
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, Pennsylvania 15230

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Chairman, North Carolina Utilities
Commission

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Box 33189
Charlotte, North Carolina 28242

Dobbs Building
430 North Salisbury Street
Raleigh, North Carolina 27602

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P.O. Box 12200
Raleigh, North Carolina 27605

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

L. L. Williams
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation - R&D 701
P. O. Box 2728
Pittsburgh, Pennsylvania 15230

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
4. Steam Line Isolation		
a. Manual Initiation	N.A.	N.A.
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
c. Containment Pressure--High-High	≤ 2.9 psig	≤ 3.0 psig
d. Negative Steam Line Pressure Rate - High	≤ -100 psi/sec	≤ -120 psi/sec
e. Steam Line Pressure - Low	≥ 585 psig	≥ 565 psig
5. Turbine Trip and Feedwater Isolation		
a. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.
b. Steam Generator Water level--High-High (P-14)	$< 82\%$ of narrow range Instrument span each steam generator	$< 83\%$ of narrow range Instrument span each steam generator
c. Doghouse Water Level-High (Feedwater Isolation Only)	12"	13"
6. Containment Pressure Control System		
Start Permissive/Termination (SP/T)	$0.3 \leq SP/T \leq 0.4$ PSIG	$0.25 \leq SP/T \leq 0.45$ PSIG

8606240151 860616
PDR ADOCK 05000369
PDR

MCGUIRE - UNITS 1 & 2

3/4 3-27

Amendment No. 56 (Unit 1)
Amendment No. 37 (Unit 2)

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>ANALOG CHANNEL OPERATIONAL TEST</u>	<u>TRIP ACTUATING DEVICE OPERATIONAL TEST</u>	<u>ACTUATION LOGIC TEST</u>	<u>MASTER RELAY TEST</u>	<u>SLAVE RELAY TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
4. Steam Line Isolation								
a. Manual Initiation	N.A.	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2, 3
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	Q	1, 2, 3
c. Containment Pressure-- High-High	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3
d. Negative Steam Line Pressure Rate-High	S	R	M	N.A.	N.A.	N.A.	N.A.	3
e. Steam Line Pressure--Low	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3
5. Turbine Trip and Feedwater Isolation								
a. Automatic Actuation Logic and Actuation Relay	N.A.	N.A.	N.A.	N.A.	M(1)	M(1)	Q	1, 2
b. Steam Generator Water Level-High-High (P-14)	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2
c. Doghouse Water Level-High (Feedwater Isolation Only)	S	N.A.	N.A.	R	N.A.	N.A.	N.A.	1, 2
6. Containment Pressure Control System								
Start Permissive/ Termination	S	R	M	N.A.	N.A.	N.A.	N.A.	1, 2, 3, 4

McGUIRE - UNITS 1 & 2

3/4 3-36

Amendment No. 56 (Unit 1)
Amendment No. 37 (Unit 2)