

May 27, 1988

Docket Nos.: 50-369  
and 50-370

Mr. H. B. Tucker, Vice President  
Nuclear Production Department  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: CHANGES TO LICENSE AMENDMENTS (TACS 60178/60179)

My letter dated May 19, 1988, forwarded Amendments 84 and 65 to Facility Operating Licenses NPF-9 and NPF-17 for the McGuire Nuclear Station, Units 1 and 2. Attached to the amendments were revised pages for the Technical Specifications. Please replace pages 2-8, 2-9 and B2-5 which were forwarded with that letter with the enclosed, corrected pages.

Sincerely,

Original signed by:

Darl Hood, Project Manager  
Project Directorate II-3  
Division of Reactor Projects I/II

Enclosures:  
As stated

cc w/enclosures:  
See next page

DISTRIBUTION:

Docket File		OGC-WF	15-B-18
NRC PDR		W. Jones	P-130A
Local PDR		T. Barnhart (8)	P1-137
PDII-3 Reading		GPA-PA	17-F-2
S. Varga	14-E-4	ARM/LFMB	AR-2015
G. Lainas	14-H-3	E. Butcher	11-F-23
D. Matthews	14-H-25	D. Hagan	MNBB-3302
M. Rood	14-H-25		
D. Hood	14-H-25		
E. Jordan	MNBB-3302		
J. Partlow	9-A-2		
ACRS (10)	H-1016		
McGuire Reading			

LA:PDII-3  
MRood  
5/27/88

*DSA*  
PM:PDII-3  
DHood:pw  
5/27/88

*DSA*  
D:PDII-3  
DMatthews  
5/27/88

8806070257 880527  
PDR ADDCK 05000369  
P PDR

Mr. H. B. Tucker  
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.  
Duke Power Company  
P. O. Box 33189  
422 South Church Street  
Charlotte, North Carolina 28242

Dr. John M. Barry  
Department of Environmental Health  
Mecklenburg County  
1200 Blythe Boulevard  
Charlotte, North Carolina 28203

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Chief  
Radiation Protection Branch  
Division of Facility Services  
Department of Human Resources  
701 Barbour Drive  
Raleigh, North Carolina 27603-2008

Mr. Robert Gill  
Duke Power Company  
Nuclear Production Department  
P. O. Box 33189  
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq.  
Bishop, Liberman, Cook, Purcell  
and Reynolds  
1200 Seventeenth Street, N.W.  
Washington, D. C. 20036

Senior Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
Route 4, Box 529  
Huntersville, North Carolina 28078

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission,  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

S. S. Kilborn  
Area Manager, Mid-South Area  
ESSD Projects  
Westinghouse Electric Corporation  
MNC West Tower - Bay 239  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION

NOTE 1: OVERTEMPERATURE  $\Delta T$

$$\Delta T \left( \frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left( \frac{1}{1 + \tau_3 S} \right) \leq \Delta T_0 \{ K_1 - K_2 \left( \frac{1 + \tau_4 S}{1 + \tau_5 S} \right) [T \left( \frac{1}{1 + \tau_6 S} \right) - T'] + K_3 (P - P') - f_1(\Delta T) \}$$

Where:  $\Delta T$  = Measured  $\Delta T$  by RTD Manifold Instrumentation,

$\frac{1 + \tau_1 S}{1 + \tau_2 S}$  = Lead-lag compensator on measured  $\Delta T$ ,

$\tau_1, \tau_2$  = Time constants utilized in the lead-lag controller for  $\Delta T$ ,  $\tau_1 \geq 8$  sec.,  $\tau_2 \leq 3$  sec.,

$\frac{1}{1 + \tau_3}$  = Lag compensator on measured  $\Delta T$ ,

$\tau_3$  = Time constants utilized in the lag compensator for  $\Delta T$ ,  $\tau_3 \leq 2$  sec.

$\Delta T_0$  = Indicated  $\Delta T$  at RATED THERMAL POWER,

$K_1$   $\leq$  1.200,

$K_2$  = 0.0222

$\frac{1 + \tau_4 S}{1 + \tau_5 S}$  = The function generated by the lead-lag controller for  $T_{avg}$  dynamic compensation,

$\tau_4, \tau_5$  = Time constants utilized in the lead-lag controller for  $T_{avg}$ ,  $\tau_4 \geq 28$  sec,  $\tau_5 \leq 4$  sec.,

$T$  = Average temperature, °F,

$\frac{1}{1 + \tau_6 S}$  = Lag compensator on measured  $T_{avg}$ ,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

NOTE 1: (Continued)

- $\tau_6$  = Time constant utilized in the measured  $T_{avg}$  lag compensator,  $\tau_6 \leq 2$  sec
- $T'$  =  $\leq 588.2^\circ\text{F}$  Reference  $T_{avg}$  at RATED THERMAL POWER,
- $K_3$  = 0.001095,
- $P$  = Pressurizer pressure, psig,
- $P'$  = 2235 psig (Nominal RCS operating pressure),
- $S$  = Laplace transform operator,  $\text{sec}^{-1}$ ,

and  $f_1(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for  $q_t - q_b$  between -29% and +9.0%;  $f_1(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent that the magnitude of  $q_t - q_b$  exceeds -29%, the  $\Delta T$  Trip Setpoint shall be automatically reduced by 3.151% of its value at RATED THERMAL POWER; and
- (iii) for each percent that the magnitude of  $q_t - q_b$  exceeds +9.0%, the  $\Delta T$  Trip Setpoint shall be automatically reduced by 1.50% of its value at RATED THERMAL POWER.

## LIMITING SAFETY SYSTEM SETTINGS

### BASES (With Bypass System Removed; RTDs in Thermowells)

#### Overtemperature $\Delta T$

The Overtemperature Delta T trip provides core protection to prevent DNB for all combinations of pressure, power, coolant temperature, and axial power distribution, provided that the transient is slow with respect to thermal delays associated with the RTDs mounted in thermowells (about 5 seconds), and pressure is within the range between the Pressurizer High and Low Pressure trips. The Setpoint is automatically varied with: (1) coolant temperature to correct for temperature induced changes in density and heat capacity of water and includes dynamic compensation for piping delays from the core to the loop temperature detectors, (2) pressurizer pressure, and (3) axial power distribution. With normal axial power distribution, this Reactor trip limit is always below the core Safety Limit as shown in Figure 2.1-1. If axial peaks are greater than design, as indicated by the difference between top and bottom power range nuclear detectors, the Reactor trip is automatically reduced according to the notations in Table 2.2-1.

#### Overpower $\Delta T$

The Overpower Delta T trip provides assurance of fuel integrity (e.g., no fuel pellet melting and less than 1% cladding strain) under all possible overpower conditions, limits the required range for overtemperature delta T protection, and provides a backup to the High Neutron Flux trip. The Setpoint is automatically varied with: (1) coolant temperature to correct for temperature induced changes in density and heat capacity of water, (2) rate of change of temperature for dynamic compensation for instrumentation delays associated with the loop temperature detectors, and (3) axial power distribution, to ensure that the allowable heat generation rate (kW/ft) is not exceeded. The Overpower  $\Delta T$  trip provides protection to mitigate the consequences of various size steam breaks as reported in WCAP 9226, "Reactor Core Response to Excessive Secondary Steam Break."