Docket Nos.: 50-369 and 50-370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: CHANGES TO LICENSE AMENDMENTS (TACS 60178/60179)

My letter dated May 19, 1988, forwarded Amendments 84 and 65 to Facility Operating Licenses NPF-9 and NPF-17 for the McGuire Nuclear Station, Units 1 and 2. Attached to the amendments were revised pages for the Technical Specifications. Please replace pages 2-8, 2-9 and B2-5 which were forwarded with that letter with the enclosed, corrected pages.

Sincerely.

Original signed by:

Darl Hood, Project Manager Project Directorate II-3 Division of Reactor Projects I/II

Enclosures: As stated

cc w/enclosures: See next page

p

DISTRIBUTION: Docket File NRC PDR Local PDR PDII-3 Reading S. Varga G. Lainas D. Matthews M. Rood D. Hood E. Jordan J. Partlow ACRS (10) McGuire Readin	g	14-E-4 14-H-3 14-H-25 14-H-25 14-H-25 MNBB-3302 9-A-2 H-1016	OGC-WF W. Jones T. Barnhart GPA-PA ARM/LFMB E. Butcher D. Hagan	15-B-18 P-130A (8) P1-137 17-F-2 AR-2015 11-F-23 MNBB-3302	
LA:PD:H-3 MR00d <i>5 1,J</i> 7/88	DS/H PM:PDII-3 DHood:pw S /27/88	Þ SN D:PDII DMattho 5 /27/3	fn -3 ews 88		
8806070257 880527 PDR ADUCK 05000369					

PDR

Mr. H. B. Tucker Duke Power Company

cc: Mr. A.V. Carr, Esq. Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

County Manager of Mecklenburg County 720 East Fourth Street Charlotte, North Carolina 28202

Mr. Robert Gill Duke Power Company Nuclear Production Department P. O. Box 33189 Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1200 Seventeenth Street, N.W. Washington, D. C. 20036

Senior Resident Inspector c/o U.S. Nuclear Regulatory Commission Route 4, Box 529 Hunterville, North Carolina 28078

Regional Administrator, Region II U.S. Nuclear Regulatory Commission, 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323

S. S. Kilborn Area Manager, Mid-South Area ESSD Projects Westinghouse Electric Corporation MNC West Tower - Bay 239 P. O. Box 355 Pittsburgh, Pennsylvania 15230 McGuire Nuclear Station

Dr. John M. Barry Department of Environmental Health Mecklenburg County 1200 Blythe Boulevard Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Chief Radiation Protection Branch Division of Facility Services Department of Human Resources 701 Barbour Drive Raleigh, North Carolina 27603-2008

		TABLE 2.2-1 (Continued)	
		REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS	
		NOTATION	
NOTE 1:	OVERTEMPERATURE ∆T		
	$\Delta T \left(\frac{1 + \tau_1 S}{1 + \tau_2 S}\right) \left(\frac{1 + \tau_1 S}{1 + \tau_2 S}\right)$	$\frac{1}{\tau_{3}S}) \leq \Delta T_{0} \{K_{1} - K_{2} (\frac{1 + \tau_{4}S}{1 + \tau_{5}S})[T(\frac{1}{1 + \tau_{6}S}) - T'] + K_{3}(P-P') - f_{1}(\Delta I)\}$	(
	Where: ∆T	= Measured ΔT by RTD Manifold Instrumentation,	
	$\frac{1+\tau_1 S}{1+\tau_2 S}$	= Lead-lag compensator on measured ΔT ,	
	τ ₁ , τ ₂	= Time constants utilized in the lead-lag controller for ΔT , $\tau_1 \ge 8$ sec., $\tau_2 \le 3$ sec.,	
	$\frac{1}{1+\tau_3}$	= Lag compensator on measured ΔT ,	
	τ3	= Time constants utilized in the lag compensator for ΔT , τ_3 \leq 2 sec.	1
	ΔT _o	= Indicated ΔT at RATED THERMAL POWER,	
	K ₁	≤ 1.200,	(
:	К2	= 0.0222	
	$\frac{1 + \tau_4 S}{1 + \tau_5 S}$	= The function generated by the lead-lag controller for T dynamic compensa	tion,
	τ ₄ , τ ₅	= Time constants utilized in the lead-lag controller for $T_{avg},$ $\tau_4 \geq 28$ sec, $\tau_5 \leq 4$ sec.,	
	Т	= Average temperature, °F,	
	$\frac{1}{1+\tau_6S}$	= Lag compensator on measured T _{avg} ,	
	880607020 PDR ADDO P	2 880527 K 05000369 PDR	

. -

.′

.

McGUIRE - UNITS 1 and 2

2-8

Amendment No. 84 (Unit 1) Amendment No. 65 (Unit 2)

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

NOTE 1: (Continued)

- τ_6 = Time constant utilized in the measured T avg lag compensator, $\tau_6 \leq 2$ sec
 - = \leq 588.2°F Reference T_{avg} at RATED THERMAL POWER,
- $K_3 = 0.001095,$

T١

Ρ

S

- = Pressurizer pressure, psig,
- P' = 2235 psig (Nominal RCS operating pressure),
 - = Laplace transform operator, sec $^{-1}$,

and $f_1(\Delta I)$ is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for $q_t q_b$ between -29% and +9.0%; $f_1(\Delta I) = 0$, where q_t and q_b are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and $q_t + q_b$ is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent that the magnitude of $q_t q_b$ exceeds -29%, the ΔT Trip Setpoint shall be automatically reduced by 3.151% of its value at RATED THERMAL POWER; and
- (iii) for each percent that the magnitude of $q_t q_b$ exceeds +9.0%, the ΔT Trip Setpoint shall be automatically reduced by 1.50% of its value at RATED THERMAL POWER.

LIMITING SAFETY SYSTEM SETTINGS

BASES (With Bypass System Removed; RTDs in Thermowells)

Overtemperature ΔT

The Overtemperature Delta T trip provides core protection to prevent DNB for all combinations of pressure, power, coolant temperature, and axial power distribution, provided that the transient is slow with respect to thermal delays associated with the RTDs mounted in thermowells (about 5 seconds), and pressure is within the range between the Pressurizer High and Low Pressure trips. The Setpoint is automatically varied with: (1) coolant temperature to correct for temperature induced changes in density and heat capacity of water and includes dynamic compensation for piping delays from the core to the loop temperature detectors, (2) pressurizer pressure, and (3) axial power distribution. With normal axial power distribution, this Reactor trip limit is always below the core Safety Limit as shown in Figure 2.1-1. If axial peaks are greater than design, as indicated by the difference between top and bottom power range nuclear detectors, the Reactor trip is automatically reduced according to the notations in Table 2.2-1.

Overpower ΔT

The Overpower Delta T trip provides assurance of fuel integrity (e.g., no fuel pellet melting and less than 1% cladding strain) under all possible overpower conditions, limits the required range for overtemperature delta T protection, and provides a backup to the High Neutron Flux trip. The Setpoint is automatically varied with: (1) coolant temperature to correct for temperature induced changes in density and heat capacity of water, (2) rate of change of temperature for dynamic compensation for instrumentation delays associated with the loop temperature detectors, and (3) axial power distribution, to ensure that the allowable heat generation rate (kW/ft) is not exceeded. The Overpower Δ Ttrip provides protection to mitigate the consequences of various size steam breaks as reported in WCAP 9226, "Reactor Core Response to Excessive Secondary Steam Break."

Amendment No. 84(Unit 1) Amendment No. 65(Unit 2)