Docket Nos.: 50-369 and 50-370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

Subject: Issuance of Amendment No. $_{82}$ to Facility Operating License NPF-9 and Amendment No. $_{63}$ to Facility Operating License NPF-17 - McGuire Nuclear Station, Units 1 and 2 (TACS 67496/67497)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 82 to Facility Operating License NPF-9 and Amendment No. 63 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. These amendments consist of changes to the Technical Specifications in response to your application dated March 14, 1988.

The amendments change the Technical Specifications by removing obsolete text regarding the Upper Head Injection system. The amendments are effective as of their date of issuance.

A copy of the related safety evaluation supporting Amendment No. 82 to Facility Operating License NPF-9 and Amendment No. 63 to Facility Operating License NPF-17 is enclosed.

Notice of issuance of amendments will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Original signed by:

Darl Hood, Project Manager Project Directorate II-3 Division of Reactor Projects I/II

Enclosures: 1. Amendment No. 82 to NPF-9 2. Amendment No. 63 to NPF-17 3. Safety Evaluation

cc w/enclosures: See next page

8805180207 880510

ADOCK 05000369

PDR

PD#LI-3/DRP-1/II	₽D#II-3/DRP-I/II
MRood:pw	DHood
3 128/88	3 12 8/88

PDR

PD#II-3/DRP-I/I

Acting PD 나/1 /88 Mr. H. B. Tucker Duke Power Company

cc:

Mr. A.V. Carr, Esq. Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

County Manager of Mecklenburg County 720 East Fourth Street Charlotte, North Carolina 28202

Mr. Robert Gill Duke Power Company Nuclear Production Department P. O. Box 33189 Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1200 Seventeenth Street, N.W. Washington, D. C. 20036

Senior Resident Inspector c/o U.S. Nuclear Regulatory Commission Route 4, Box 529 Hunterville, North Carolina 28078

Regional Administrator, Region II U.S. Nuclear Regulatory Commission, 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323

S. S. Kilborn Area Manager, Mid-South Area ESSD Projects Westinghouse Electric Corporation MNC West Tower - Bay 239 P. O. Box 355 Pittsburgh, Pennsylvania 15230 McGuire Nuclear Station

Dr. John M. Barry Department of Environmental Health Mecklenburg County 1200 Blythe Boulevard Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Chief Radiation Protection Branch Division of Facility Services Department of Human Resources 701 Barbour Drive Raleigh, North Carolina 27603-2008 DATED: May 10, 1988

AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NPF-9 - McGuire Nuclear Station, Unit 1 AMENDMENT NO. ⁶³ TO FACILITY OPERATING LICENSE NPF-17 - McGuire Nuclear Station, Unit 2

DISTRIBUTION: Docket File 50-369/370 NRC PDR Local PDR PRC System NSIC PD#II-3 R/F McGuire R/F M. Rood D. Hood GLainas/SVarga OGC-White Flint J. Partlow E. Jordan W. Jones T. Barnhart (8) ACRS (10) GPA/PA ARM/LFMB E. Butcher D. Hagan

L. Reyes



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 82 License No. NPF-9

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-9 filed by the Duke Power Company (the licensee) dated March 14, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8805180210 880510 PDR ADDCK 05000369 PDR PDR

- Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 8^2 , are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by:

David B. Matthews, Director Project Directorate II-3 Division of Reactor Projects-I/II

Attachment: Technical Specification Changes

Date of Issuance: May 10, 1988

DIt PM:PDII-3 LA:PDIJ-3 OGC-WP ADR2: NRR MRodd: pw DHood WHodaes Acting PD Lánas 3/26/88 3 12 /88 3 /2 8/88 4/1/88 /88



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

DUKE POWER COMPANY

DOCKET NO. 50-370

MCGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 63 License No. NPF-17

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-17 filed by the Duke Power Company (the licensee) dated March 14, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

- 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachments to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:
 - (2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 63 , are hereby incorporated into the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by: David B. Matthews, Director Project Directorate II-3 Division of Reactor Projects-I/II

Attachment: Technical Specification Changes

Date of Issuance: May 10, 1988



FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 63

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Amended Page IX 3/4 5-1 3/4 5-2a 3/4 5-2b 3/4 5-3a 3/4 5-3a 3/4 5-3b 3/4 5-4 B 3/4 5-1 B 3/4 5-2 B 3/4 5-3 INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

.

.

.

SECTION			PAGE	
3/4.4.9 PRESSURE/TEMPERATURE LIMITS				
Reactor Coolant System			3/4 4-30	
FIGURE 3.4-2a	UNIT 1 REACTOR COOLANT S HEATUP LIMITATIONS - APP UP TO 10 EFPY	SYSTEM PLICABLE	3/4 4-31	
FIGURE 3.4-2b	UNIT 2 REACTOR COOLANT S HEATUP LIMITATIONS-APPLI UP TO 10 EFPY	YSTEM CABLE	3/4 4-32	
FIGURE 3.4-3a	UNIT 1 REACTOR COOLANT S COOLDOWN LIMITATIONS - A TO 10 EPFY	YSTEM PPLICABLE UP	3/4 4-33	
FIGURE 3.4-3b	UNIT 2 REACTOR COOLANT S COOLDOWN LIMITATIONS-APP TO 10 EPFY	YSTEM PLICABLE UP	3/4 4-34	
TABLE 4.4-5 REACTOR VESSEL WITHDRAWAL SCH	MATERIAL SURVEILLANCE PR	ROGRAM -	3/4 4-35	
Pressurizer			3/4 4-36	
Overpressure Protec	tion Systems		3/4 4-37	
3/4.4.10 STRUCTURAL INTEGRIT	Ϋ		3/4 4-39	
3/4.4.11 REACTOR VESSEL HEAD	VENT SYSTEM		3/4 4-40	
3/4.5 EMERGENCY CORE COOLING SYSTEMS				
3/4.5.1 ACCUMULATORS				
Cold Leg Injection.			3/4 5-1	
[Deleted]			3/4 5-3	
3/4.5.2 ECCS SUBSYSTEMS - T	vg ≥ 350°F		3/4 5-5	
$3/4.5.3$ ECCS SUBSYSTEMS - T _{avg} $\leq 350^{\circ}$ F			3/4 5-9	
3/4.5.4 [Deleted]	-		3/4.5-11	
3/4.5.5 REFUELING WATER STOP	AGE TANK		3/4 5-12	
McGUIRE - UNITS 1 and 2	IX	Amendment No. 82 Amendment No. 63	(Unit 1) (Unit 2)	

ł

3/4.5 EMERGENCY CORE COOLING SYSTEMS

3/4.5.1 ACCUMULATORS

COLD LEG INJECTION

LIMITING CONDITION FOR OPERATION

3.5.1.1 Each cold leg injection accumulator shall be OPERABLE with:

- a. The isolation valve open,
- b. A contained borated water volume of between 6870 and 7342 gallons,
- c. A boron concentration of between 1900 and 2100 ppm,
- d. A nitrogen cover-pressure of between 585 and 639 psig, and
- e. A water level and pressure channel OPERABLE.

APPLICABILITY: MODES 1, 2, and 3*.

ACTION:

- a. With one accumulator inoperable, except as a result of a closed isolation valve or boron concentration less than 1900 ppm, restore the inoperable accumulator to OPERABLE status within 1 hour or be in at least HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
- b. With one accumulator inoperable due to the isolation value being closed, either immediately open the isolation value or be in at least HOT STANDBY within 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
- c. With one accumulator inoperable due to boron concentration less than 1900 ppm and:
 - The volume weighted average boron concentration of the three limiting accumulators 1900 ppm or greater, restore the inoperable accumulator to OPERABLE status within 24 hours of the low boron determination or be in at least HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.
 - 2) The volume weighted average boron concentration of the three limiting accumulators less than 1900 ppm but greater than 1500 ppm, restore the inoperable accumulator to OPERABLE status or return the volume weighted average boron concentration of the three limiting accumulators to greater than 1900 ppm and enter ACTION c.1 within 6 hours of the low boron determination or be in HOT STANDBY within the next 6 hours and reduce pressurizer pressure to less than 1000 psig within the following 6 hours.

*Pressurizer pressure above 1000 psig.

Pages 3/4 5-2a and 3/4 5-2b intentionally deleted.

McGUIRE - UNITS 1 and 2 3/4 5-2a

Amendment No.82 (Unit 1) Amendment No.63 (Unit 2)

Pages 3/4 5-3, 3/4 5-3a, and 3/4 5-3b intentionally deleted.

McGUIRE - UNITS 1 and 2

Amendment No.82 (Unit 1) Amendment No.63 (Unit 2) This page intentionally deleted.

McGUIRE - UNITS 1 and 2

Amendment No. 82 (Unit 1) Amendment No. 63 (Unit 2)

3/4.5 EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.1 ACCUMULATORS

The OPERABILITY of each Reactor Coolant System (RCS) Cold Leg Accumulator ensures that a sufficient volume of borated water will be immediately forced into the reactor core through each of the cold legs in the event the RCS pressure falls below the pressure of the accumulators. This initial surge of water into the core provides the initial cooling mechanism during large RCS pipe ruptures.

The limits on accumulator volume, boron concentration and pressure ensure that the assumptions used for accumulator injection in the safety analysis are met.

The allowed down time for the accumulators are variable based upon boron concentration to ensure that the reactor is shutdown following a LOCA and that any problems are corrected in a timely manner. Subcriticality is assured when boron concentration is above 1500 ppm, so additional down time is allowed when concentration is above 1500 ppm. A concentration of less than 1900 ppm in any single accumulator or as a volume weighted average may be indicative of a problem, such as valve leakage, but since reactor shutdown is assured, additional time is allowed to restore boron concentration in the accumulators.

The accumulator power operated isolation valves are considered to be "operating bypasses" in the context of IEEE Std. 279-1971, which requires that bypasses of a protective function be removed automatically whenever permissive conditions are not met. In addition, as these accumulator isolation valves fail to meet single failure criteria, removal of power to the valves is required.

The limits for operation with an accumulator inoperable for any reason except an isolation valve closed minimizes the time exposure of the plant to a LOCA event occurring concurrent with failure of an additional accumulator which may result in unacceptable peak cladding temperatures. If a closed isolation valve cannot be immediately opened, the full capability of one accumulator is not available and prompt action is required to place the reactor in a mode where this capability is not required.

The original licensing bases of McGuire assumes both the UHI system and the Cold Leg Accumulators function to mitigate postulated accidents. Subsequent analyses, documented in "McGuire Nuclear Station, Safety Analysis for UHI Elimination" dated September 1985, and docketed by Duke letter dated October 2, 1985, support the determination that UHI is no longer required provided the Cold Leg Accumulator volume is adjusted to be consistent with that assumed in the Safety Analysis.

McGUIRE - UNITS 1 and 2

Amendment No. 82 (Unit 1) Amendment No. 63 (Unit 2)

EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS

The OPERABILITY of two independent ECCS subsystems ensures that sufficient emergency core cooling capability will be available in the event of a LOCA assuming the loss of one subsystem through any single failure consideration. Either subsystem operating in conjunction with the accumulators is capable of supplying sufficient core cooling to limit the peak cladding temperatures within acceptable limits for all postulated break sizes ranging from the double ended break of the largest RCS cold leg pipe downward. In addition, each ECCS subsystem provides long-term core cooling capability in the recirculation mode during the accident recovery period.

With the RCS temperature below 350°F, one OPERABLE ECCS subsystem is acceptable without single failure consideration on the basis of the stable reactivity condition of the reactor and the limited core cooling requirements.

The limitation for a maximum of one centrifugal charging pump and one Safety Injection pump to be OPERABLE and the Surveillance Requirement to verify all charging pumps and Safety Injection pumps except the required OPERABLE charging pump to be inoperable below 300°F provides assurance that a mass addition pressure transient can be relieved by the operation of a single PORV.

The Surveillance Requirements provided to ensure OPERABILITY of each component ensures that at a minimum, the assumptions used in the safety analyses are met and that subsystem OPERABILITY is maintained. Surveillance Requirements for throttle valve position stops and flow balance testing provide assurance that proper ECCS flows will be maintained in the event of a LOCA. Maintenance of proper flow resistance and pressure drop in the piping system to each injection point is necessary to: (1) prevent total pump flow from exceeding runout conditions when the system is in its minimum resistance configuration, (2) provide the proper flow split between injection points in accordance with the assumptions used in the ECCS-LOCA analyses, and (3) provide an acceptable level of total ECCS flow to all injection points equal to or above that assumed in the ECCS-LOCA analyses.

3/4.5.4

[Deleted]

3/4.5.5 REFUELING WATER STORAGE TANK

The OPERABILITY of the refueling water storage tank (RWST) as part of the ECCS ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that: (1) sufficient water is available within containment to permit recirculation cooling flow to the core, and (2) the reactor will remain subcritical in the cold condition following mixing of the RWST and the RCS water volumes with all control rods inserted except

McGUIRE - UNITS 1 and 2

Amendment No.82 (Unit 1) Amendment No.63 (Unit 2)

EMERGENCY CORE COOLING SYSTEMS

BASES

REFUELING WATER STORAGE TANK (Continued)

for the most reactive control assembly. These assumptions are consistent with the LOCA analyses.

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 8.5 and 10.5 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 82 TO FACILITY OPERATING LICENSE NPF-9

AND AMENDMENT NO. 63 TO FACILITY OPERATING LICENSE NPF-17

DUKE POWER COMPANY

DOCKET NOS. 50-369 AND 50-370

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

I. INTRODUCTION

By letter dated March 14, 1988, Duke Power Company (the licensee) proposed amendments to change the McGuire Technical Specifications (TS) by removing obsolete text regarding Upper Head Injection (UHI) system.

II. EVALUATION

By previous Amendments 57 (McGuire Unit 1) and 38 (McGuire Unit 2), dated May 13, 1986, the Commission approved changes to the TS allowing operation with the UHI system (1) functionally disabled by closure of isolation values or (2) physically removed. Because the changes applied to both of two units in the common TS document, each with different refueling outage schedules, and because each unit would operate one fuel cycle with UHI functionally disabled prior to physical removal, the previous changes contained provisions for the plant transition by specifying requirements during which the UHI system was (1) operable, (2) isolated but present, and (3) physically removed. The transition was completed during the 1987 refueling outages at which time the UHI system piping and values were physically removed from each unit. Accordingly, all references in the TS to the UHI system are now obsolete. The licensee has requested that reference to the UHI system in the TS be removed to preclude any possible confusion over applicability of the extraneous specifications.

The staff has reviewed the licensee's request and finds that the requested change to delete obsolete text has no safety implication, and is purely administrative. Therefore, the proposed change is acceptable.

III. ENVIRONMENTAL CONSIDERATION

PDR

These amendments involve changes to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational exposure. The NRC staff has made a determination that the amendments involve no significant hazards consideration, and there has been no public comment on such finding. Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of these amendments. B8051B0215 B80510 PDR ADBCK 05000369

IV. CONCLUSION

The Commission made a proposed determination that the amendments involve no significant hazards consideration which was published in the Federal Register (53 FR11369) on April 6, 1988. The Commission consulted with the state of North Carolina. No public comments were received, and the state of North Carolina did not have any comments.

We have concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: D. Hood, PD#II-3/DRP-I/II

Dated: May 10, 1988

- , ,	May 10, 1988		
Docket Nos. 50-369/37	DISTRIBUTION:		
MEMORANDUM FOR:	Sholly Coordinator PDII-3 R/F		
FROM:	Darl S. Hood, Project Manager DHood Project Directorate II-3 McGuire R/F Division of Reactor Projects-I/II OGC-WF Sholly Coon (orig. + 1)		
SUBJECT:	REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE (TACS 67496/67497)		
Duke Power Compa	y, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station,		
Units 1 and 2, M	cklenburg County, North Carolina		
Date of applicat	on for amendments: March 14, 1988		
Brief description	Brief description of amendments: The amendments change the Technical		
Specifications by	Specifications by removing obsolete text regarding the Upper Head		
Injection System			
Date of issuance	May 10, 1988		
Effective date: N	ay 10, 1988		
Amendment Nos.: 8	2 and 63		
Facility Operation	g License Nos. NPF-9 and NPF-17: Amendments revised the		
Technical Specif	cations.		
Date of initial	otice in FEDERAL REGISTER: April 6, 1988 (53 FR 11369)		
The Commission's related evaluation of the amendments is contained in a Safety			
Evaluation dated May 10,1988.			
No significant hazards consideration comments received: No.			
Local Public Document Room locations: Atkins Library, University of North			
Carolina, Charlotte (UNCC Station), North Carolina 28223			
8805180218 880510 ADUCK 0500036 PDR ADUCK 0500036	Original signed by: Darl S. Hood, Project Manager Project Directorate II-3 Division of Reactor Projects-I/II		
LA:PDII-3 PM:P MRood:pw DHoo /%/88 3/2	$ \begin{array}{cccccccccccccccccccccccccccccccccccc$		

May 10, 1988

Decket Nee EO 260/2	20				
MEMORANDUM FOR:	Sholly Coordinator	Docket File PDII-3 R/F			
FROM:	Darl S. Hood, Project Manager Project Directorate II-3 Division of Reactor Projects-I/II	MRood DHood McGuire R/F OGC-WF			
SUBJECT:	REQUEST FOR PUBLICATION IN BIWEEK OF ISSUANCE OF AMENDMENT TO FACIL (TACS 67496/67497)	Sholly Coor. (orig. + 1) Y FR NOTICE - NOTICE ITY OPERATING LICENSE			
Duke Power Comp	any, Docket Nos. 50-369 and 50-370,	McGuire Nuclear Station,			
Units 1 and 2, I	Mecklenburg County, North Carolina				
Date of applica	tion for amendments: March 14, 1988	3			
Brief description	Brief description of amendments: The amendments change the Technical				
Specifications	by removing obsolete text regarding	the Upper Head			
Injection System	n.				
Date of issuance	2: May 10, 1988				
Effective date:	May 10, 1988				
Amendment Nos.:	82 and 63				
Facility Operat	ing License Nos. NPF-9 and NPF-17:	Amendments revised the			
Technical Speci	fications.				
Date of initial	notice in FEDERAL REGISTER: April	6, 1988 (53 FR ₁₁₃₆₉)			
The Commission's related evaluation of the amendments is contained in a Safety					
Evaluation date	1 May 10,1988.				
No significant	nazards consideration comments rece	ived: No.			
Local Public Document Room locations: Atkins Library, University of North					
Carolina, Charlotte (UNCC Station), North Carolina 28223					
	Original Darl S. Hood, Project Direc Division of Re	signed by: Project Manager torate II-3 eactor Projects-I/II			

LA:PDII-3 MRood:pw 子 亿人/88 DH PM:PDII-3 DHood 3 /24/88

D3/1 PDII-3 Acting PD 4/1/88