Docket Nos.: 50-369 50-370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: LICENSE AMENDMENT CORRECTIONS

My letter dated March 2, 1989, forwarded Amendments 93 and 74 to Facility Operating Licenses NPF-9 and NPF-17 for the McGuire Nuclear Station, Units 1 and 2, respectively. Enclosed with the amendments were Technical Specifications page changes. Two of those pages contained typographical errors and page 3/4 7-46 should have been omitted. Please remove page 3/4 7-46 of the March 2 transmittal and replace pages 3/4 7-45 and B 3/4 7-8 of the March 2 transmittal with the enclosed revised pages.

Sincerely,

Darl Hood, Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/encl: See next page

DISTRIBTUION: Docket File NRC PDR Local PDR PDII-3 R/f MRood DHood		Wanda Jones EButcher ACRS (10) GPA/PA ARM/LFMB McGuire Plant	P-130A 11-F-23 P-135 17-F-2 AR-2015 File	
GLainas GLainas EAdensam OGC DHagan EJordan BGrimes TMeeks(8)	14-E-4 14-H-3 15-B-18 MNBB-3302 MNBB-3302 9-A-2 P1-137 DS(Y	NG	0	OP-1
PDJ 15-3 MROOD 03 <i>110</i> /89	PDII-3 DHood:1s 03/g /89	PDII-3 DMatthews 03//0/89	DFO1	C
8903210059 89 PDR ADOCK 05 P	20310 3000369 PDC		۱. ۱	



UNITED STATES WUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

March 10, 1989

Docket Nos.: 50-369 50 - 370

> Mr. H. B. Tucker, Vice President Nuclear Production Department Duke Power Company 422 South Church Street Charlotte, North Carolina 28242

Dear Mr. Tucker:

SUBJECT: LICENSE AMENDMENT CORRECTIONS

My letter dated March 2, 1989, forwarded Amendments 93 and 74 to Facility Operating Licenses NPF-9 and NPF-17 for the McGuire Nuclear Station, Units 1 and 2, respectively. Enclosed with the amendments were Technical Specifications page changes. Two of those pages contained typographical errors and page 3/4 7-46 should have been omitted. Please remove page 3/4 7-46 of the March 2 transmittal and replace pages 3/4 7-45 and B 3/4 7-8 of the March 2 transmittal with the enclosed revised pages.

Sincerely,

Vool

Darl Hood, Project Manager Project Directorate II-3 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

1.13

cc w/encl: See next page

- t

Mr. H. B. Tucker Duke Power Company

cc:

Mr. A.V. Carr, Esq. Duke Power Company P. O. Box 33189 422 South Church Street Charlotte, North Carolina 28242

County Manager of Mecklenburg County 720 East Fourth Street Charlotte, North Carolina 28202

Mr. J. S. Warren Duke Power Company Nuclear Production Department P. O. Box 33189 Charlotte, North Carolina 28242

J. Michael McGarry, III, Esq. Bishop, Liberman, Cook, Purcell and Reynolds 1400 L Street, N.W. Washington, D. C. 20005

Senior Resident Inspector c/o U.S. Nuclear Regulatory Commission Route 4, Box 529 Hunterville, North Carolina 28078

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323

S. S. Kilborn Area Manager, Mid-South Area ESSD Projects Westinghouse Electric Corporation MNC West Tower - Bay 239 P. O. Box 355 Pittsburgh, Pennsylvania 15230 McGuire Nuclear Station

Dr. John M. Barry Department of Environmental Health Mecklenburg County 1200 Blythe Boulevard Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Chief Radiation Protection Branch Division of Facility Services Department of Human Resources 701 Barbour Drive Raleigh, North Carolina 27603-2008

Mr. Alan R. Herdt, Chief Project Branch #3 U.S. Nuclear Regulatory Commission 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323 TABLE 3.7-7

AUXILIARY BUILDING GROUNDWATER LEVEL MONITORS

LOCATION	INTERIOR/ EXTERIOR ELEVATION UNIT
н. Н	(Feet - Mean Sea Level)
PP51	Interior 731' - 0" 1
QQ56	Interior 731' - 0" 1 & 2
PP-61	Interior 731' - 0" 2
West Wall	Exterior 731' - 0" 1
East Wall	Exterior 731' - 0" 2
•	

McGUIRE - UNITS 1 and 2

8903210064 890310 PDR ADUCK 05000369 PDC

Bernard Barran Martin Martin

•

. . .

· · · ·

Amendment No. 93 (Unit 1) Amendment No. 74 (Unit 2)

PLANT SYSTEMS

BASES

3/4.7/13 GROUNDWATER LEVEL

This Technical Specification is provided to ensure that groundwater levels will be monitored and prevented from rising to the potential failure limit for the McGuire Units 1 and 2 Auxiliary Buildings. This motential failure limit is based on engineering calculations that have determined that the Auxiliary Buildings are susceptible to overturning due to buoyancy at elevation 737 feet Mean Sea Level(MSL). Under the requirements of this Technical Specification, if groundwater level exceeds elevation 731 feet MSL, (3 out of 5 Tech Spec groundwater monitor alarms), and cannot be reduced in one (1) hour, McGuire must begin reducing Units 1 and 2 to Mode 5, Cold Shutdown.

Aller -

Analysis performed by Design Engineering determined that the Reactor and Diesel Generator Buildings are designed to withstand hydrostatic loadings due to groundwater levels up to elevation 760 feet MSL; therefore, no Technical Specification requirements are specified for these structures.

Elevation 731 feet MSL is the Technical Specification action level of the five Technical Specification groundwater monitors listed in Table 3.7-7. The East Wall exterior monitor alarm at elevation 731 feet MSL is the Alert alarm due to the groundwater well being bored to a depth of 730 feet MSL because of underground rock formation below the well. The other four (4) monitors are Hi-Hi alarms at elevation 731 feet (MSL).

The East Wall exterior monitor was originally on the exterior of the Unit 2 Auxiliary Building and subsequently was enclosed by the construction of the Equipment Staging Building.

As required by Operations procedures, any alarms on non-Technical Specification groundwater monitors will also be investigated. Additionally, if three (3) out of the five (5) Technical Specification Groundwater monitors alarm at levels below the Technical Specification action levels, Operations will contact Duke Design Engineering (Civil) for investigation and resolution of the increased groundwater level.

If one or more of the 5 Technical Specification groundwater monitors is determined to be inoperable, the monitor(s) will be considered to be indicating above the 731'-O" level until repaired and returned to an operable status.

McGUIRE - UNITS I and 2

Amendment No. 93 (Unit 1) Amendment No. 74 (Unit 2) !