

December 10, 2001

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RE: RISK-INFORMED
INSERVICE INSPECTION APPLICATION FOR SOUTH TEXAS PROJECT,
UNITS 1 AND 2 (TAC NOS. MB1277 AND MB1278)

Dear Mr. Cottle:

By letter dated February 27, 2001 (NOC-AE-01001034), you submitted a request for relief from Section XI examination requirements of the American Society of Mechanical Engineers Code for inservice inspections (ISI) of Class 1 and 2 piping welds. The proposed alternative of a risk-informed ISI program is to provide an acceptable level of quality and safety in accordance with 10 CFR 50.55a(a)(3)(i).

The enclosed information is needed for the NRC staff to complete its review of your application. To expedite the NRC staff's review to meet the agreed upon schedule, the request for additional information was provided to your staff by e-mail on November 19, 2001. Any difference between the enclosed questions and the e-mail is editorial. In a call on the questions with your staff, they agreed to submit the responses to the questions by January 11, 2002. If the responses are submitted by that date, the NRC staff expects to issue its evaluation on schedule. If you have any questions, contact me, lead project manager, at 301-415-1307, or at jnd@nrc.gov through the internet.

Sincerely,

/RA/

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Request for Additional Information

cc w/encl: See next page

December 10, 2001

Mr. William T. Cottle
President and Chief Executive Officer
STP Nuclear Operating Company
South Texas Project Electric
Generating Station
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION RE: RISK-INFORMED
INSERVICE INSPECTION APPLICATION FOR SOUTH TEXAS PROJECT,
UNITS 1 AND 2 (TAC NOS. MB1277 AND MB1278)

Dear Mr. Cottle:

By letter dated February 27, 2001 (NOC-AE-01001034), you submitted a request for relief from Section XI examination requirements of the American Society of Mechanical Engineers Code for inservice inspections (ISI) of Class 1 and 2 piping welds. The proposed alternative of a risk-informed ISI program is to provide an acceptable level of quality and safety in accordance with 10 CFR 50.55a(a)(3)(i).

The enclosed information is needed for the NRC staff to complete its review of your application. To expedite the NRC staff's review to meet the agreed upon schedule, the request for additional information was provided to your staff by e-mail on November 19, 2001. Any difference between the enclosed questions and the e-mail is editorial. In a call on the questions with your staff, they agreed to submit the responses to the questions by January 11, 2002. If the responses are submitted by that date, the NRC staff expects to issue its evaluation on schedule. If you have any questions, contact me, lead project manager, at 301-415-1307, or at jnd@nrc.gov through the internet.

Sincerely,
/RA/

Jack Donohew, Senior Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-498 and 50-499

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PUBLIC
PDIV-1 Reading
RidsNrrDlpmPdiv(SRichards)
RidsNrrDlpmLpdiv-1 (RGramm)
RidsNrrPMJDonohew
RidsNrrLAMMcAllister
RidsOgcRp
RidsAcrsAcnwMailCenter
WJohnson, RIV
SAli
SDinsmore
RHernan

ACCESSION NO.: ML013200045

* RAI received by e-mail dated 11/19/2001

OFFICE	PDIV-2/PM	PDIV-1/LA	EMCB/NRR	PDIV-1/SC
NAME	JDonohew:lf	MMcAllister	SAli*	RGramm
DATE	12/10/2001	12/10/2001	11/19/2001	12/10/2001

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION

SOUTH TEXAS PROJECT, UNITS 1 AND 2

RISK-INFORMED INSERVICE INSPECTION

DOCKET NOS. 50-498 AND 50-499

The following are questions on the risk-informed inservice inspection (RI-ISI) submittal dated February 27, 2001, for relief from Section XI examination requirements of the American Society of Mechanical Engineers (ASME) Code for Class 1 and 2 piping welds at South Texas Project, Units 1 And 2 (STP):

1. Will the RI-ISI program be updated every 10 years and submitted to the NRC consistent with the current ASME Code, Section XI requirements?
2. Under what conditions will the RI-ISI program be resubmitted to the NRC before the end of any 10-year interval?
3. Page 8 of the submittal presents the criteria for engineering evaluation and additional examinations if unacceptable flaws or relevant conditions are found during examinations. The submittal states that the evaluation will include whether other elements in the segment or segments are subject to the same root cause conditions. The submittal further states that additional examinations will be performed on these elements up to a number equivalent to the number of elements required to be inspected on the segment or segments initially. Please address the following:
 - (a) Please clarify the term "initially". Specifically, does it refer to inspections planned for the current outage or the current interval?
 - (b) Please clarify how will the elements be selected for additional examinations. Specifically, please verify that the elements will be selected based on the root cause or damage mechanism, and include high risk significant as well as medium risk significant elements (if needed) to reach the required number of additional elements.
4. Page 5 of the submittal states that a deviation to EPRI [Electric Power Research Institute] RI-ISI methodology has been implemented in the failure potential assessment for thermal stratification, cycling and striping (TASCS). Please state if the revised methodology for assessing TASCS potential is in conformance with the updated criteria described in EPRI letter to NRC dated March 28, 2001. Also, please confirm that as stated in the subject letter, once the final Materials Reliability Program guidance has been developed, the RI-ISI program will be updated for the evaluation of susceptibility to TASCS, as appropriate.

5. The submittal states that the scope includes Category B-J socket welds. Please state what examination method will be utilized for the inspection of socket welds.
6. Section 3.6.1 of the submittal states that, for medium consequence category segments, boundary estimates of $1E-4$ and $1E-5$ were used for the conditional core damage and large early release frequency respectively. What was used for the high consequence category segments?
7. Section 1.2 of your submittal states that the Level 2 probabilistic safety assessment (PSA) and individual plant examination (IPE) submittal dated August 28, 1992, supplemented by the current probabilistic risk assessment (PRA) model, STP_1997, were used to support the RI-ISI submittal. The October 14, 1999 letter transmitting procedures and diagrams for the proposed Risk Informed Exemption included a copy of the Probabilistic Risk Assessment Program, OPGP04-ZA-0604, Rev. 3. The procedure includes the following two steps.

6.3.8 The overall PRA model results are updated every refueling cycle of Unit 1, not to exceed two years, or when the Risk & Reliability Analysis Administrator determines (using guidance supplied by OPGP01-ZA-0305) an update is required.

6.3.20 Each update cycle, the Updated PRA (including the Updated PRA Computer Model) is documented as "complete" via a signed letter from the Risk & Reliability Analysis Administrator to RMS. Computer codes are maintained in accordance with OPGP05-ZA-0014, "Software Quality Assurance Program."

It appears that the 1997 model (i.e., STP_1997) referenced in the February 27, 2001, submittal would have been more than two years old when the RI-ISI submittal was being prepared; however, the update procedure indicates that the models should normally be no more than two years old. Please explain the apparent discrepancy of using a "current PRA model, STP_1997" in the February 27, 2001 submittal.

South Texas, Units 1 & 2

cc:

Mr. Cornelius F. O'Keefe
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Mr. M. T. Hardt
Mr. W. C. Gunst
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Mr. C. A. Johnson/R. P. Powers
AEP - Central Power and Light Company
P. O. Box 289
Mail Code: N5022
Wadsworth, TX 77483

INPO
Records Center
700 Galleria Parkway
Atlanta, GA 30339-3064

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Judge, Matagorda County
Matagorda County Courthouse
1700 Seventh Street
Bay City, TX 77414

A. H. Gutterman, Esq.
Morgan, Lewis & Bockius
1800 M Street, N.W.
Washington, DC 20036-5869

Mr. J. J. Sheppard, Vice President
Engineering & Technical Services
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

S. M. Head, Manager, Licensing
Nuclear Quality & Licensing Department
STP Nuclear Operating Company
P. O. Box 289, Mail Code: N5014
Wadsworth, TX 77483

Office of the Governor
ATTN: John Howard, Director
Environmental and Natural
Resources Policy
P. O. Box 12428
Austin, TX 78711

Jon C. Wood
Matthews & Branscomb
112 East Pecan, Suite 1100
San Antonio, TX 78205

Arthur C. Tate, Director
Division of Compliance & Inspection
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756

Jim Calloway
Public Utility Commission of Texas
Electric Industry Analysis
P. O. Box 13326
Austin, TX 78711-3326