

July 17, 1991

Docket Nos. 50-369  
and 50-370

Mr. M. S. Tuckman  
Vice President -  
Nuclear Operations  
Duke Power Company  
P. O. Box 1007  
Charlotte, North Carolina 28201-1007

Dear Mr. Tuckman:

SUBJECT: CORRECTION TO AMENDMENT NOS. 122 AND 104 DATED JULY 15, 1991,  
TO FACILITY OPERATING LICENSE NOS. NPF-9 AND NPF-17 FOR THE  
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TACS 80129/80130)

On July 15, 1991, the Nuclear Regulatory Commission issued Amendment Nos.  
122 and 104 to Facility Operating Licenses NPF-9 and NPF-17 for the  
McGuire Nuclear Station, Units 1 and 2.

In discussions with your staff, we found an incorrect reference under  
Technical Specification (TS) Section 3/4.7.6, "Control Area Ventilation System."  
In Section 3.7.6, a., for MODES 1, 2, 3 and 4; and a. and b., for MODES 5  
and 6, the reference "4.7.6.a" should be changed to "4.7.6.b."

The TS page has been corrected and is enclosed for your convenience.

Sincerely,

/s/

Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects I/II

Enclosure:  
As stated

DISTRIBUTION  
See next page

cc w/enclosure:  
See next page

NRC FILE CENTER 021

OFC	: NRR:PDII-3	: NRR:PDII-3	:	:	:
NAME	: LBerry:lb	: TReed	:	:	:
DATE	: 07/17/91	: 07/17/91	:	:	:

OFFICIAL RECORD COPY  
Document Name: MCGUIRE AMDT CORRECTION

9108010004 910717  
PDR ADDCK 05000369  
P PDR

200022

DFOL 11/11  
CP 11/11



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555  
July 17, 1991

Docket Nos. 50-369  
and 50-370

Mr. M. S. Tuckman  
Vice President -  
Nuclear Operations  
Duke Power Company  
P. O. Box 1007  
Charlotte, North Carolina 28201-1007

Dear Mr. Tuckman:

SUBJECT: CORRECTION TO AMENDMENT NOS. 122 AND 104 DATED JULY 15, 1991,  
TO FACILITY OPERATING LICENSE NOS. NPF-9 AND NPF-17 FOR THE  
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TACS 80129/80130)

On July 15, 1991, the Nuclear Regulatory Commission issued Amendment Nos. 122 and 104 to Facility Operating Licenses NPF-9 and NPF- 17 for the McGuire Nuclear Station, Units 1 and 2.

In discussions with your staff, we found an incorrect reference under Technical Specification (TS) Section 3/4.7.6, "Control Area Ventilation System." In Section 3.7.6, a., for MODES 1, 2, 3 and 4; and a. and b., for MODES 5 and 6, the reference "4.7.6.a" should be changed to "4.7.6.b."

The TS page has been corrected and is enclosed for your convenience.

Sincerely,

A handwritten signature in black ink, appearing to read "Timothy A. Reed", is written over a horizontal line.

Timothy A. Reed, Project Manager  
Project Directorate II-3  
Division of Reactor Projects I/II

Enclosure:  
As stated

cc w/enclosure:  
See next page

DATED: July 17, 1991

AMENDMENT NO. 122 TO FACILITY OPERATING LICENSE NPF-9 - McGuire Nuclear Station, Unit 1  
AMENDMENT NO. 104 TO FACILITY OPERATING LICENSE NPF-17 - McGuire Nuclear Station, Unit 2

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PD II-3 R/F

McGuire R/F

S. Varga 14-E-4

G. Lainas 14-H-3

D. Matthews 14-H-25

R. Ingram 14-H-25

T. Reed 14-H-25

OGC-WF 15-B-18

D. Hagan MNBB 4702

G. Hill (8) P1-37

W. Jones MNBB 7103

J. Calvo 11-F-22

ACRS (10) P-135

GPA/PA 17-F-2

OC/LFMB MNBB 4702

Mr. M.S. Tuckman  
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. Paul Guill  
Duke Power Company  
Nuclear Production Department  
P.O. Box 1007  
Charlotte, North Carolina 28201-1007

J. Michael McGarry, III, Esq.  
Winston and Strawn  
1400 L Street, N.W.  
Washington, DC 20005

Senior Resident Inspector  
c/o U.S. Nuclear Regulatory Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, Georgia 30323

Mr. Frank Modrak  
Project Manager, Mid-South Area  
ESSD Projects  
Westinghouse Electric Corporation  
MNC West Tower - Bay 241  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Dr. John M. Barry  
Department of Environmental Health  
Mecklenburg County  
1200 Blythe Boulevard  
Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Director  
Department of Environmental,  
Health and Natural Resources  
Division of Radiation Protection  
P.O. Box 27687  
Raleigh, North Carolina 27611-7687

Mr. Alan R. Herdt, Chief  
Project Branch #3  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Ms. Karen E. Long  
Assistant Attorney General  
N. C. Department of Justice  
P.O. Box 629  
Raleigh, North Carolina 27602

Mr. R.L. Gill, Jr.  
Nuclear Production Department  
Duke Power Company  
P.O. Box 1007  
Charlotte, North Carolina 28201-1007

## PLANT SYSTEMS

### 3/4.7.6 CONTROL AREA VENTILATION SYSTEM

#### LIMITING CONDITION FOR OPERATION

---

3.7.6 Two independent Control Area Ventilation Systems shall be OPERABLE.

APPLICABILITY: ALL MODES

ACTION: (Units 1 and 2)

MODES 1, 2, 3 and 4:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

MODES 5 and 6:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE Control Area Ventilation System in the recirculation mode; and
- b. With both Control Area Ventilation Systems inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, or with the OPERABLE Control Area Ventilation System, required to be in the recirculation mode by ACTION a., not capable of being powered by an OPERABLE emergency power source, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.4 are not applicable.
- d. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

9108010314 910717  
PDR ADDCK 05000369  
P PDR