

July 17, 1991

Docket Nos. 50-369
and 50-370

Mr. M. S. Tuckman
Vice President -
Nuclear Operations
Duke Power Company
P. O. Box 1007
Charlotte, North Carolina 28201-1007

Dear Mr. Tuckman:

SUBJECT: CORRECTION TO AMENDMENT NOS. 122 AND 104 DATED JULY 15, 1991,
TO FACILITY OPERATING LICENSE NOS. NPF-9 AND NPF-17 FOR THE
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TACS 80129/80130)

On July 15, 1991, the Nuclear Regulatory Commission issued Amendment Nos.
122 and 104 to Facility Operating Licenses NPF-9 and NPF-17 for the
McGuire Nuclear Station, Units 1 and 2.

In discussions with your staff, we found an incorrect reference under
Technical Specification (TS) Section 3/4.7.6, "Control Area Ventilation System."
In Section 3.7.6, a., for MODES 1, 2, 3 and 4; and a. and b., for MODES 5
and 6, the reference "4.7.6.a" should be changed to "4.7.6.b."

The TS page has been corrected and is enclosed for your convenience.

Sincerely,

/s/

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II

Enclosure:
As stated

DISTRIBUTION
See next page

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFC	: NRR:PDII-3	: NRR:PDII-3	:	:	:
NAME	: LBerry:lb	: TReed	:	:	:
DATE	: 07/17/91	: 07/17/91	:	:	:

OFFICIAL RECORD COPY
Document Name: MCGUIRE AMDT CORRECTION

9108010004 910717
PDR ADDCK 05000369
P PDR

200022

DFOL
1/11
CP
[Handwritten signatures]



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

July 17, 1991

Docket Nos. 50-369
and 50-370

Mr. M. S. Tuckman
Vice President -
Nuclear Operations
Duke Power Company
P. O. Box 1007
Charlotte, North Carolina 28201-1007

Dear Mr. Tuckman:

SUBJECT: CORRECTION TO AMENDMENT NOS. 122 AND 104 DATED JULY 15, 1991,
TO FACILITY OPERATING LICENSE NOS. NPF-9 AND NPF-17 FOR THE
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TACS 80129/80130)

On July 15, 1991, the Nuclear Regulatory Commission issued Amendment Nos. 122 and 104 to Facility Operating Licenses NPF-9 and NPF-17 for the McGuire Nuclear Station, Units 1 and 2.

In discussions with your staff, we found an incorrect reference under Technical Specification (TS) Section 3/4.7.6, "Control Area Ventilation System." In Section 3.7.6, a., for MODES 1, 2, 3 and 4; and a. and b., for MODES 5 and 6, the reference "4.7.6.a" should be changed to "4.7.6.b."

The TS page has been corrected and is enclosed for your convenience.

Sincerely,

A handwritten signature in black ink, appearing to read "Timothy A. Reed".

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II

Enclosure:
As stated

cc w/enclosure:
See next page

DATED: July 17, 1991

AMENDMENT NO. 122 TO FACILITY OPERATING LICENSE NPF-9 - McGuire Nuclear Station, Unit 1
AMENDMENT NO. 104 TO FACILITY OPERATING LICENSE NPF-17 - McGuire Nuclear Station, Unit 2

DISTRIBUTION:

Docket File

NRC PDR

Local PDR

PD II-3 R/F

McGuire R/F

S. Varga 14-E-4

G. Lainas 14-H-3

D. Matthews 14-H-25

R. Ingram 14-H-25

T. Reed 14-H-25

OGC-WF 15-B-18

D. Hagan MNBB 4702

G. Hill (8) P1-37

W. Jones MNBB 7103

J. Calvo 11-F-22

ACRS (10) P-135

GPA/PA 17-F-2

OC/LFMB MNBB 4702

Mr. M.S. Tuckman
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Paul Guill
Duke Power Company
Nuclear Production Department
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, N.W.
Washington, DC 20005

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. R.L. Gill, Jr.
Nuclear Production Department
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

PLANT SYSTEMS

3/4.7.6 CONTROL AREA VENTILATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.6 Two independent Control Area Ventilation Systems shall be OPERABLE.

APPLICABILITY: ALL MODES

ACTION: (Units 1 and 2)

MODES 1, 2, 3 and 4:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

MODES 5 and 6:

- a. With one Control Area Ventilation System inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, restore the inoperable system to OPERABLE status within 7 days or initiate and maintain operation of the remaining OPERABLE Control Area Ventilation System in the recirculation mode; and
- b. With both Control Area Ventilation Systems inoperable for reasons other than the heaters specified in 4.7.6.b and 4.7.6.e.4, or with the OPERABLE Control Area Ventilation System, required to be in the recirculation mode by ACTION a., not capable of being powered by an OPERABLE emergency power source, suspend all operations involving CORE ALTERATIONS or positive reactivity changes.
- c. The provisions of Specification 3.0.4 are not applicable.
- d. With the heaters tested in 4.7.6.b and 4.7.6.e.4 inoperable, restore the inoperable heaters to OPERABLE status within 7 days, or file a Special Report in accordance with Specification 6.9.2 within 30 days, specifying the reason for inoperability and the planned actions to return the heaters to OPERABLE status.

9108010314 910717
PDR ADDOCK 05000369
P PDR