

6.0 ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

- 6.1.1 The Plant General Manager shall be responsible for overall unit operation and shall delegate in writing the succession to this responsibility during his absence.
- 6.1.2 The Shift Supervisor, or during his absence from the control room, a designated individual, shall be responsible for the control room command function. A management directive to this effect, signed by the Site Vice President, shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

ONSITE AND OFFSITE ORGANIZATION

- 6.2.1 An onsite and an offsite organization shall be established for unit operation and corporate management. This onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.
- a. Lines of authority, responsibility and communication shall be established and defined from the highest management levels through intermediate levels to and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organizational charts. These organizational charts will be documented in the Topical Quality Assurance Report and updated in accordance with 10 CFR 50.54(a)(3).
 - b. The Chief Nuclear Officer shall be responsible for overall plant nuclear safety. This individual shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support in the plant so that continued nuclear safety is assured.
 - c. The Plant General Manager shall be responsible for overall unit safe operation and shall have control over those onsite resources necessary for safe operation and maintenance of the plant.
 - d. Although the individuals who train the operating staff and those who carry out the quality assurance functions may report to the appropriate manager onsite, they shall have sufficient organizational freedom to be independent from operating pressures.
 - e. Although health physics individuals may report to any appropriate manager onsite, for matters relating to radiological health and safety of employees and the public, the Health Physics Supervisor shall have direct access to that onsite individual having responsibility for overall unit management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

6.0 ADMINISTRATIVE CONTROLS

MEETING FREQUENCY

6.5.1.4 The FRG shall meet at least once per calendar month and as convened by the FRG Chairman or his designated alternate.

QUORUM

6.5.1.5 The quorum of the FRG necessary for the performance of the FRG responsibility and authority provisions of these Technical Specifications shall consist of the Chairman or his designated alternate and four members including alternates.

RESPONSIBILITIES

6.5.1.6 The Facility Review Group shall be responsible for:

- a. Review of (1) all new procedures required by Specification 6.8 and all procedure changes that require a written 50.59 evaluation, (2) all programs required by Specification 6.8 and changes thereto, and (3) any other proposed procedures or changes thereto as determined by the Plant General Manager to affect nuclear safety.
- b. Review of all proposed tests and experiments that affect nuclear safety.
- c. Review of all proposed changes to Appendix A Technical Specifications.
- d. Review of all proposed changes or modifications to unit systems or equipment that affect nuclear safety.
- e. Investigation of all violations of the Technical Specifications, including the preparation and forwarding of reports covering evaluation and recommendations to prevent recurrence to the Chief Nuclear Officer and to the Chairman of the Company Nuclear Review Board.
- f. Review of all REPORTABLE EVENTS.
- g. Review of unit operations to detect potential nuclear safety hazards.
- h. Performance of special reviews, investigations or analyses and reports thereon as requested by the Plant General Manager or the Company Nuclear Review Board.
- i. Not Used.
- j. Not Used.

6.0 ADMINISTRATIVE CONTROLS

RESPONSIBILITIES (Continued)

- k. Review of every unplanned on-site release of radioactive material to the environs including the preparation of reports covering evaluation, recommendations and disposition of the corrective action to prevent recurrence and the forwarding of these reports to the Chief Nuclear Officer and to the Company Nuclear Review Board.
- l. Review of changes to the PROCESS CONTROL PROGRAM and the OFFSITE DOSE CALCULATION MANUAL and RADWASTE TREATMENT SYSTEMS.
- m. Review and documentation of judgment concerning prolonged operation in bypass, channel trip, and/or repair of defective protection channels of process variables placed in bypass since the last FRG meeting.
- n. Review of the Fire Protection Program and implementing procedures and submittal of recommended changes to the Company Nuclear Review Board.

AUTHORITY

6.5.1.7 The Facility Review Group shall:

- a. Recommend in writing to the Plant General Manager approval or disapproval of items considered under Specifications 6.5.1.6a. through d. and m. above.
- b. Render determinations in writing with regard to whether or not each item considered under Specifications 6.5.1.6a, b, d, and e above requires NRC approval pursuant to 10 CFR 50.59.
- c. Provide written notification within 24 hours to the Chief Nuclear Officer and the Company Nuclear Review Board of disagreement between the FRG and the Plant General Manager; however, the Plant General Manager shall have responsibility for resolution of such disagreements pursuant to Specification 6.1.1 above.

RECORDS

6.5.1.8 The Facility Review Group shall maintain written minutes of each FRG meeting that, at a minimum, document the results of all FRG activities performed under the responsibility and authority provisions of these technical specifications. Copies shall be provided to the Plant General Manager, Chief Nuclear Officer and the Chairman of the Company Nuclear Review Board.

6.5.2 COMPANY NUCLEAR REVIEW BOARD (CNRB)

FUNCTION

- 6.5.2.1 The Company Nuclear Review Board shall function to provide independent review and audit of designated activities in the areas of:
- a. nuclear power plant operations
 - b. nuclear engineering
 - c. chemistry and radiochemistry
 - d. metallurgy

ADMINISTRATIVE CONTROLS

FUNCTION (Continued)

- e. instrument and control
- f. radiological safety
- g. mechanical and electrical engineering
- h. quality assurance practices

COMPOSITION

6.5.2.2 The Chief Nuclear Officer shall appoint, in writing, a minimum of five members to the CNRB and shall designate from this membership, in writing, a Chairman. The membership shall function to provide independent review and audit in the areas listed in Specification 6.5.2.1. The Chairman shall meet the requirements of ANSI/ANS-3.1-1987, Section 4.7.1. The members of the CNRB shall meet the educational requirements of the ANSI/ANS-3.1-1987, Section 4.7.2, and have at least 5 years of professional level experience in one or more of the fields listed in Specification 6.5.2.1. CNRB members who do not possess the educational requirements of ANSI/ANS-3.1-1987, Section 4.7.2 (up to a maximum of 2 members) shall be evaluated, and have their membership approved and documented, in writing, on a case-by-base basis by the Chief Nuclear Officer, considering the alternatives to educational requirements of ANSI/ANS-3.1-1987, Sections 4.1.1 and 4.1.2.

ALTERNATES

6.5.2.3 All alternate members shall be appointed in writing by the CNRB Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in CNRB activities at any one time.

CONSULTANTS

6.5.2.4 Consultants shall be utilized as determined by the CNRB Chairman to provide expert advice to the CNRB.

MEETING FREQUENCY

6.5.2.5 The CNRB shall meet at least once per calendar quarter during the initial year of unit operation following fuel loading and at least once per 6 months thereafter and as convened by the CNRB Chairman or his designated alternate.

QUORUM

6.5.2.6 The quorum of the CNRB necessary for the performance of the CNRB review and audit functions of these Technical Specifications shall consist of the Chairman or his designated alternate and at least a majority of CNRB members including alternates. No more than a minority of the quorum shall have line responsibility for operation of the unit.

ADMINISTRATIVE CONTROLS

AUDITS (continued)

- d. The performance of activities required by the Quality Assurance Program to meet the criteria of Appendix B, 10 CFR Part 50.
- e. Any other area of unit operation considered appropriate by the CNRB or the Chief Nuclear Officer.
- f. The fire protection programmatic controls including the implementing procedures at least once per 24 months by qualified licensee QA personnel.
- g. The fire protection equipment and program implementation at least once per 12 months utilizing either a qualified offsite licensee fire protection engineer or an outside independent fire protection consultant. An outside independent fire protection consultant shall be used at least every third year.
- h. The radiological environmental monitoring program and the results thereof.
- i. The OFFSITE DOSE CALCULATION MANUAL and implementing procedures.
- j. The PROCESS CONTROL PROGRAM and implementing procedures for dewatering of radioactive bead resin.

TECHNICAL REVIEW RESPONSIBILITIES

6.5.2.9 The technical review responsibilities under the cognizance of the CNRB shall encompass:

- a. Plant operating characteristics, NRC issuances, industry advisories, Licensee Event Reports and other sources that may indicate areas for improving plant safety;
- b. Plant operations, modifications, maintenance, and surveillance to verify independently that these activities are performed safely and correctly and that human errors are reduced as much as practical;
- c. Internal and external operational experience information that may indicate areas for improving plant safety; and
- d. Making detailed recommendations to the Chairman – CNRB and plant management for revising procedures, equipment modifications or other means of improving nuclear safety and plant reliability.

AUTHORITY

6.5.2.10 The CNRB shall report to and advise the Chief Nuclear Officer on those areas of responsibility specified in Specifications 6.5.2.7, 6.5.2.8, and 6.5.2.9.

ADMINISTRATIVE CONTROLS

RECORDS

6.5.2.11 Records of CNRB activities shall be prepared, approved, and distributed as indicated below:

- a. Minutes of each CNRB meeting shall be prepared, approved, and forwarded to the Chief Nuclear Officer within 14 days following each meeting.
- b. Reports of reviews encompassed by Specification 6.5.2.7 above shall be prepared, approved, and forwarded to the Chief Nuclear Officer within 14 days following completion of the review.
- c. Audit reports encompassed by Specification 6.5.2.8 above shall be forwarded to the Chief Nuclear Officer and to the management positions responsible for the areas audited within 30 days after completion of the audit by the auditing organization.
- d. Technical reviews encompassed by Specification 6.5.2.9 above shall be prepared, maintained and a report of the activities forwarded each calendar month to the Chairman, CNRB.

ADMINISTRATIVE CONTROLS

6.6 REPORTABLE EVENTS ACTION

- 6.6.1 The following actions shall be taken for REPORTABLE EVENTS:
- a. The Commission shall be notified and a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
 - b. Each REPORTABLE EVENT shall be reviewed by the FRG, and the results of this review shall be submitted to the CNRB, and the Chief Nuclear Officer.

6.7 SAFETY LIMIT VIOLATION

- 6.7.1 The following actions shall be taken in the event a Safety Limit is violated:
- a. The NRC Operations Center shall be notified by telephone as soon as possible and in all cases within 1 hour. The Chief Nuclear Officer and the CNRB shall be notified within 24 hours.
 - b. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the FRG. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems or structures, and (3) corrective action taken to prevent recurrence.
 - c. The Safety Limit Violation Report shall be submitted to the Commission, the CNRB, and the Chief Nuclear Officer within 14 days of the violation.
 - d. Critical operation of the unit shall not be resumed until authorized by the Commission.

6.8 PROCEDURES AND PROGRAMS

- 6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:
- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Revision 2, February 1978, and those required for implementing the requirements of NUREG 0737.
 - b. Refueling operations.
 - c. Surveillance and test activities of safety-related equipment.
 - d. Not Used.
 - e. Not Used.