



**Entergy Nuclear Southwest**  
Entergy Operations, Inc.  
17265 River Road  
Killona, LA 70066  
Tel 504 739 6660  
Fax 504 739 6678

**John T. Herron**  
Vice President, Operations  
Waterford 3  
jherron@entergy.com

W3F1-2001-0104  
A4.05  
PR

November 8, 2001

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

**SUBJECT:** Waterford Steam Electric Station, Unit 3  
Docket No. 50-382  
Supplement to 30 Day Response To NRC Bulletin 2001-01 For  
Waterford 3; Circumferential Cracking of VHP Nozzles

**REFERENCES:** W3F1-2001-0081, 30 Day Response To NRC Bulletin 2001-01 For  
Waterford 3; Circumferential Cracking of VHP Nozzles, September  
4, 2001

Dear Sir or Madam:

In the referenced letter, Entergy Operations, Inc. (Entergy) committed to "...perform an effective visual examination of essentially 100% of the outer bare metal surface of the vessel head penetrations for evidence of leakage during the next scheduled refueling outage" at Waterford Steam Electric Station, Unit 3. During a conference call held between the NRC staff and Entergy personnel on October 22, 2001, the staff requested that the phrase "essentially 100%" be clarified and provided their interpretation of the phrase.

Entergy concurs with the staff's interpretation that "essentially 100%" as used in the referenced letter means "essentially 360 degrees around 100% of the vessel head penetrations."

This letter contains no new commitments.

If you have any questions or require additional information, please contact D. Bryan Miller at 504-739-6692.


A088

Supplement to 30 Day Response To NRC Bulletin 2001-01 For  
Waterford 3; Circumferential Cracking of VHP Nozzles  
W3F1-2001-0104  
Page 2  
November 8, 2001

This letter is submitted pursuant to 10 CFR 50.54(f) and contains information responding to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles," for Waterford 3.

I declare under penalty of perjury that the foregoing is true and correct. Executed on November 8, 2001.

Sincerely,



J. T. Herron  
Vice President, Operations  
Waterford 3

JTH/DBM/cbh

cc: E.W. Merschoff, NRC Region IV  
N. Kalyanam, NRC-NRR  
NRC Resident Inspectors Office

---

*copies - unable  
to locate the  
originals  
Judy M*