

April 15, 1993

Docket Nos. 50-369
and 50-370

DISTRIBUTION

Docket File	OGC
NRC/Local PDRs	D. Hagan
PDII-3 Reading	G. Hill(4)
S. Varga	W. Jones
G. Lainas	C. Grimes
D. Matthews	D. Shum
T. Reed	ACRS (10)
L. Berry	PA
	OC/LFMB
	E. Merschoff, RII

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENTS 136 AND 118, MCGUIRE NUCLEAR STATION,
UNITS 1 AND 2 (TAC NOS. M79018 AND M79019)

The Nuclear Regulatory Commission issued Amendments 136 and 118 to McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS) revising the Standby Nuclear Service Water Pond water temperature on April 5, 1993.

Due to an administrative oversight, TS page 3/4 7-12, Section 3.7.5b. should have been revised to read:

- b. An average water temperature of less than or equal to 82°F at elevation 722 feet.

A corrected page 3/4 7-12 is enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

/s/

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 7-12

NRC FILE SERVICE COPY

cc w/enclosure:
See next page

OFFICE	PDII-3/LA	PDII-3/PM	PDII-3/D		
NAME	L. BERRY	T. REED	D. MATTHEWS		
DATE	4/13/93	4/13/93	4/15/93		

OFFICIAL RECORD COPY
FILE NAME: G:\MCGUIRE\AMDCOR.LTR

CP-1

9304230100 930415
PDR ADOCK 05000369
P PDR

DF01
41



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

April 15, 1993

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENTS 136 AND 118, MCGUIRE NUCLEAR STATION,
UNITS 1 AND 2 (TAC NOS. M79018 AND M79019)

The Nuclear Regulatory Commission issued Amendments 136 and 118 to McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS) revising the Standby Nuclear Service Water Pond water temperature and elevation on April 5, 1993.

Due to an administrative oversight, TS page 3/4 7-12, Section 3.7.5b. should have been revised to read:

- b. An average water temperature of less than or equal to 82°F at elevation 722 feet.

A corrected page 3/4 7-12 is enclosed. We apologize for any inconvenience this may have caused.

Sincerely,

A handwritten signature in black ink, appearing to read "Timothy A. Reed".

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
TS page 3/4 7-12

cc w/enclosure:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

County Manager of Mecklenberg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. R. O. Sharpe
Compliance
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Carolinas District
Westinghouse Electric Corporation
P. O. Box 32817
Charlotte, North Carolina 28232

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Alan R. Herdt, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
P. O. Box 1006
Charlotte, North Carolina 28201-1006

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

PLANT SYSTEMS

3/4.7.5 STANDBY NUCLEAR SERVICE WATER POND

LIMITING CONDITION FOR OPERATION

3.7.5 The standby nuclear service water pond shall be OPERABLE with:

- a. A minimum water level at or above elevation 739.5 feet Mean Sea Level, USGS datum, and
- b. An average water temperature of less than or equal to 82°F at elevation 722 feet.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION: (Units 1 and 2)

With the requirements of the above specification not satisfied, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.5 The standby nuclear service water pond shall be determined OPERABLE:

- a. At least once per 24 hours by verifying the water level to be within its limit,
- b. At least once per 24 hours during the months of July, August and September by verifying the water temperature to be within its limit, and
- c. At least once per 12 months by visually inspecting the dam and verifying no abnormal degradation, erosion, or excessive seepage.

9304230105 930415
PDR ADOCK 05000369
P PDR