

November 27, 1991

Docket Nos. 50-369
and 50-370

Distribution
See next page

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: ISSUANCE OF AMENDMENT NO. 128 TO FACILITY OPERATING LICENSE NPF-9
AND AMENDMENT NO. 110 TO FACILITY OPERATING LICENSE NPF-17 -
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TACS M80694)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 128 to Facility Operating License NPF-9 and Amendment No. 110 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated June 26, 1991, as supplemented September 16, 1991 and November 7, 1991, with the following exception. We have not completed our review of the proposed increases in tolerances for the pressurizer safety valve and main steamline safety valve lift setpoints. Accordingly, those proposed changes are not included in this amendment. They will be addressed separately as we continue our review of them.

The amendments revise the TS to reflect the reloading of McGuire Unit 1 Cycle 8 with B&W fuel. In addition, there are a substantial number of TS changes that stem from the use of a new Duke Power Company reload analysis methodology, as well as from revised safety analysis input assumptions.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance of the amendments will be included in the Commission's biweekly Federal Register notice.

Sincerely,
ORIGINAL SIGNED BY T. REED

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 128 to NPF-9
2. Amendment No. 110 to NPF-17
3. Safety Evaluation

cc w/enclosures:
See next page

*SEE PREVIOUS CONCURRENCES

OFC	: PDII-3/LA	: PDII-3/PM	: OGC *	: PDII-3/D	:
NAME	: LBerry	: TReed	: STurk	: DMatthews	:
DATE	: 11/25/91	: 11/26/91	: 11/21/91	: 11/27/91	:

OFFICIAL RECORD COPY
Document Name: MCGUIRE RELOAD AMDT

DFOL
11

NRC FILE CENTER COPY

CP
[Signature]

2112090212 911127
PDR ADDCK 050009369
PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 27, 1991

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: ISSUANCE OF AMENDMENT NO. 128 TO FACILITY OPERATING LICENSE NPF-9
AND AMENDMENT NO. 110 TO FACILITY OPERATING LICENSE NPF-17 -
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TAC NO. 80694)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 128 to Facility Operating License NPF-9 and Amendment No. 110 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated June 26, 1991, as supplemented September 16, 1991 and November 7, 1991, with the following exception. We have not completed our review of the proposed increases in tolerances for the pressurizer safety valve and main steamline safety valve lift setpoints. Accordingly, those proposed changes are not included in this amendment. They will be addressed separately as we continue our review of them.

The amendments revise the TS to reflect the reloading of McGuire Unit 1 Cycle 8 with B&W fuel. In addition, there are a substantial number of TS changes that stem from the use of a new Duke Power Company reload analysis methodology, as well as from revised safety analysis input assumptions.

A copy of the related Safety Evaluation is also enclosed. Notice of Issuance of the amendments will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 128 to NPF-9
2. Amendment No. 110 to NPF-17
3. Safety Evaluation

cc w/enclosures:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

CC:

Mr. A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. R. O. Sharpe
Compliance
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, N.W.
Washington, DC 20005

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

DATED: NOVEMBER 27, 1991

AMENDMENT NO. 128 TO FACILITY OPERATING LICENSE NPF-9 - McGuire, Unit 1
AMENDMENT NO. 110 TO FACILITY OPERATING LICENSE NPF-17 - McGuire, Unit 2

DISTRIBUTION:

Docket File	
NRC PDR	
Local PDR	
PD II-3 R/F	
McGuire R/F	
S. Varga	14-E-4
G. Lainas	14-H-3
D. Matthews	14-H-25
L. Berry	14-H-25
T. Reed	14-H-25
OGC-WF	15-B-18
D. Hagan	MNBB 4702
G. Hill (8)	P1-37
W. Jones	MNBB 7103
C. Grimes	11-F-23
ACRS (10)	P-135
GPA/PA	17-F-2
OC/LFMB	MNBB 4702

000000