

January 7, 1992

Docket Nos. 50-369
and 50-370

DISTRIBUTION
~~Docket File~~
NRC/LOCAL PRDs
OGC
ACRS (10)
LReyes,II
DHagan
GHill(8)
WJones
CGrimes
GPC/PA
OC/LFMB

McGuire R/F
PDII-3 R/F

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO REVISED TECHNICAL SPECIFICATION BASES CHANGES

The Nuclear Regulatory Commission issued a revision to the Technical Specification Bases for McGuire Station, Units 1 and 2, involving a change to the functional description of the P-7 and P-8 reactor trip system interlocks contained in Bases Section B.2.2, dated December 30, 1991.

The date of revision was inadvertently omitted from the bottom of the Bases page. Please replace the old page with the enclosed revised page.

Sincerely,

ORIGINAL SIGNED BY:

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

OFC	: LA:PDII-3	: PM:PDII-3	:	:	:
NAME	: LBerry:1b	: TReed	:	:	:
DATE	: 01/ /92	: 01/ /92	:	:	:

OFFICIAL RECORD COPY
Document Name: CORRECTION BASES PAGE

CP
DF01
10

9201100290 920107
PDR ADOCK 05000349
F PDR

THIS FILE CONTAINS COPY
THIS FILE CONTAINS COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

January 7, 1992

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO REVISED TECHNICAL SPECIFICATION BASES CHANGES

The Nuclear Regulatory Commission issued a revision to the Technical Specification Bases for McGuire Station, Units 1 and 2, involving a change to the functional description of the P-7 and P-8 reactor trip system interlocks contained in Bases Section B.2.2, dated December 30, 1991.

The date of revision was inadvertently omitted from the bottom of the Bases page. Please replace the old page with the enclosed revised page.

Sincerely,

A handwritten signature in black ink, appearing to read "T. A. Reed", written over a large, stylized circular flourish.

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

Dr. John M. Barry
Mecklenburg County
Dept. of Environmental Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. R. O. Sharpe
Compliance
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, N.W.
Washington, DC 20005

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

LIMITING SAFETY SYSTEM SETTINGS

BASES

Reactor Trip System Interlocks

The Reactor Trip System Interlocks perform the following functions:

- P-6 On increasing power P-6 allows the manual block of the Source Range Reactor trip and de-energizing of the high voltage to the detectors. On decreasing power, Source Range Level trips are automatically reactivated and high voltage restored.
- P-7 On increasing power P-7 automatically enables Reactor trips on low flow in more than one reactor coolant loop, reactor coolant pump bus undervoltage and underfrequency, pressurizer low pressure and pressurizer high level. On decreasing power the above listed trips are automatically blocked.
- P-8 On increasing power P-8 automatically enables Reactor trips on low flow in one or more reactor coolant loops and on Turbine Trip. On decreasing power the P-8 automatically blocks the above listed trips.
- P-10 On increasing power P-10 allows the manual block of the Intermediate Range Reactor trip and the Flow Setpoint Power Range Reactor trip; and automatically blocks the Source Range Reactor trip and de-energizes the Source Range high voltage power. On decreasing power the Intermediate Range Reactor trip and the Low Setpoint Power Range Reactor trip are automatically reactivated. Provides input to P-7.
- P-13 Provides input to P-7.