

November 25, 1991

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENT NOS. 126 AND 108
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

The Nuclear Regulatory Commission issued Amendment No. 126 to Facility Operating License NPF-9 and Amendment No. 108 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2, on October 29, 1991.

A typographical error was found on page 3/4 7-18b of the Technical Specifications (TS) in Note 5 which should have read, "If the number of unacceptable snubbers ..." instead of, "If the snubber of unacceptable snubbers..."

Please replace the existing TS page with the enclosed revised TS page 3/4 7-18b.

We regret any inconvenience this may have caused you.

Sincerely,

/s/

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

NRC FILE CENTER COPY

OFC	: PDII-3/LA	: PDII-3/PM	:	:	:
NAME	: LBerry:lb	: TReed	:	:	:
DATE	: 11/20/91	: 11/25/91	:	:	:

OFFICIAL RECORD COPY
Document Name: CORRECTION MCGUIRE

9112020268 911125
PDR ADDCK 05000369
P PDR

CP
edw
JE01
11

DATE: November 25, 1991

DISTRIBUTION

Docket File

NRC DPR

LOCAL PDR

PDII-3 Reading

McGuire Reading

SVarga 14E4

GLainas 14H3

DMatthews

LBerry

TReed

OGC 15B18

DHagan NMBB 4702

GHill (8) Pi-37

WJones MNBB 4702

CGrimes 11F23

ACRS (10) P-135

GPA/PA 17F2

OC/LFMB MNBB 4702



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
November 25, 1991

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENT NOS. 126 AND 108
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

The Nuclear Regulatory Commission issued Amendment No. 126 to Facility Operating License NPF-9 and Amendment No. 108 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2, on October 29, 1991.

A typographical error was found on page 3/4 7-18b of the Technical Specifications (TS) in Note 5 which should have read, "If the number of unacceptable snubbers ..." instead of, "If the snubber of unacceptable snubbers..."

Please replace the existing TS page with the enclosed revised TS page 3/4 7-18b.

We regret any inconvenience this may have caused you.

Sincerely,

A handwritten signature in dark ink, appearing to read "Timothy A. Reed", is written over a circular stamp or seal.

Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. M.S. Tuckman
Duke Power Company

McGuire Nuclear Station

cc:

Mr. A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Paul Guill
Duke Power Company
Nuclear Production Department
P.O. Box 1007
Charlotte, North Carolina 28201-1007

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, N.W.
Washington, DC 20005

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Mr. R.L. Gill, Jr.
Nuclear Production Department
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Table 4.7-2 (continued)
SNUBBER VISUAL INSPECTION INTERVAL

- Note 4: If the number of unacceptable snubbers is equal to or less than the Column B but greater than the number in Column A, the next inspection shall be the same as the previous interval.
- Note 5: If the number of unacceptable snubbers is equal to or greater than the number in Column C, the next inspection interval shall be two-thirds of the previous interval. However, if the number of unacceptable snubbers is less than the number in Column C but greater than the number in Column B, the next interval shall be reduced proportionally by interpolation, that is, the previous interval shall be reduced by a factor that is one third of the ratio of the difference between the number of unacceptable snubbers found during the previous interval and the number in Column B to the difference in the numbers in Columns B and C.
- Note 6: The provisions of Specification 4.0.2 are applicable for all inspection intervals up to and including 48 months.