

September 28, 1994

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

DISTRIBUTION:

Docket File
PUBLIC
~~Public~~
GLainas
HBerkow
BBoger (A), RII
MSinkule, RII
EJordan, T-4 D18
ACRS (10), TWF
OPA, O-2 G5

Dear Mr. McMeekin:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT FOR AN EXEMPTION FROM 10 CFR 50.60, "ACCEPTANCE CRITERIA FOR FRACTURE PREVENTION MEASURES FOR LIGHT-WATER NUCLEAR POWER REACTORS FOR NORMAL OPERATION" - MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. M89807 AND M89808)

Enclosed is the "Environmental Assessment and Finding of No Significant Impact" related to your request for an exemption from certain requirements of 10 CFR 50.60, "Acceptance Criteria for Fracture Prevention Measures for Light-Water Nuclear Power Reactors for Normal Operation," for the McGuire Nuclear Station Units 1 and 2. The request was submitted by letter dated June 28, 1994, and requests an exemption from Appendices G and H to 10 CFR Part 50 so that the American Society of Mechanical Engineers Code Case N-514, "Low Temperature Overpressure Protection," may be used as an acceptable alternative method to determine the acceptable low temperature overpressure protection setpoints.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by:
Victor Nerses for:
Herbert N. Berkow, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9410040075 940928
PDR ADOCK 05000369
P PDR

Docket Nos. 50-369
and 50-370

Enclosure:
Environmental Assessment

cc w/enclosure:
See next page

DOCUMENT NAME: G:\McGuire\MCG89807.EA

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	LA:PD23:DRPE	E	PM:PD23:DRPE	BC:EMCB:DE	OGC	D:PD23:DRPE
NAME	CNORSWORTHY		VNERSES	JSTROSNIDER	DDORRICK	HBERKOW
DATE	9/9/94		9/9/94	9/13/94	9/20/94	9/28/94

OFFICE: BC: SILK/B/D/DRSS

NAME: R. JONES

DATE: 9/13/94

030098

NRG FILE CENTER COPY

DFU



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 28, 1994

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT
IMPACT FOR AN EXEMPTION FROM 10 CFR 50.60, "ACCEPTANCE CRITERIA
FOR FRACTURE PREVENTION MEASURES FOR LIGHT-WATER NUCLEAR POWER
REACTORS FOR NORMAL OPERATION" - MCGUIRE NUCLEAR STATION,
UNITS 1 AND 2 (TAC NOS. M89807 AND M89808)

Enclosed is the "Environmental Assessment and Finding of No Significant Impact" related to your request for an exemption from certain requirements of 10 CFR 50.60, "Acceptance Criteria for Fracture Prevention Measures for Light-Water Nuclear Power Reactors for Normal Operation," for the McGuire Nuclear Station Units 1 and 2. The request was submitted by letter dated June 28, 1994, and requests an exemption from Appendices G and H to 10 CFR Part 50 so that the American Society of Mechanical Engineers Code Case N-514, "Low Temperature Overpressure Protection," may be used as an acceptable alternative method to determine the acceptable low temperature overpressure protection setpoints.

This assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "Herbert N. Berkow".

Herbert N. Berkow, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-369
and 50-370

Enclosure:
Environmental Assessment

cc w/enclosure:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

cc:

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611-7687

County Manager of Mecklenberg County
720 East Fourth Street
Charlotte, North Carolina 28202

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. J. E. Snyder
Regulatory Compliance Manager
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-
0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

Dr. John M. Barry
Mecklenberg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

UNITED STATES NUCLEAR REGULATORY COMMISSIONDUKE POWER COMPANYDOCKET NOS. 50-369 AND 50-370ENVIRONMENTAL ASSESSMENT ANDFINDING OF NO SIGNIFICANT IMPACT

The U. S. Nuclear Regulatory Commission (the Commission) is considering issuance of an exemption from certain requirements of its regulations to Facility Operating License Nos. NPF-9 and NPF-17, issued to the Duke Power Company, licensee for the McGuire Nuclear Station Units 1 and 2. The plants are located at the licensee's site in Mecklenburg, County, North Carolina. The exemption was requested by the licensee by letter dated June 28, 1994, and supplemented by letters dated August 18, 1994 and September 7, 1994.

ENVIRONMENTAL ASSESSMENTIdentification of Proposed Action:

The proposed action requests an exemption from certain requirements of 10 CFR 50.60, "Acceptance Criteria for Fracture Prevention Measures for Light-Water Nuclear Power Reactors for Normal Operation," to allow application of an alternate methodology to determine the low temperature overpressure protection (LTOP) setpoint for the McGuire Nuclear Station Units 1 and 2. The proposed alternate methodology is consistent with guidelines developed by the American Society of Mechanical Engineers (ASME) Working Group on Operating Plant Criteria (WGPC) to define pressure limits during LTOP events that avoid certain unnecessary operational restrictions, provide adequate margins against failure of the reactor pressure vessel, and reduce the potential for unnecessary activation of pressure-relieving devices used for LTOP. These

guidelines have been incorporated into Code Case N-514, "Low Temperature Overpressure Protection," which has been approved by the ASME Code Committee. The content of this code case has been incorporated into Appendix G of Section XI of the ASME Code and published in the 1993 Addenda to Section XI. The NRC staff is revising 10 CFR 50.55a, which will endorse the 1993 Addenda and Appendix G of Section XI into the regulations.

The philosophy used to develop Code Case N-514 guidelines is to ensure that the LTOP limits are still below the pressure/temperature (P/T) limits for normal operation, but allow the pressure that may occur with activation of pressure-relieving devices to exceed the P/T limits, provided acceptable margins are maintained during these events. This philosophy protects the pressure vessel from LTOP events, and still maintains the Technical Specification P/T limits applicable for normal heatup and cooldown in accordance with Appendix G to 10 CFR Part 50 and Sections III and XI of the ASME Code.

The Need for the Proposed Action:

10 CFR 50.60 states that all light-water nuclear power reactors must meet the fracture toughness and material surveillance program requirements for the reactor coolant pressure boundary as set forth in Appendices G and H to 10 CFR Part 50. Appendix G to 10 CFR 50 defines P/T limits during any condition of normal operation, including anticipated operational occurrences and system hydrostatic tests, to which the pressure boundary may be subjected over its service lifetime. 10 CFR 50.60(b) specifies that alternatives to the described requirements in Appendices G and H to 10 CFR Part 50 may be used when an exemption is granted by the Commission under 10 CFR 50.12.

To prevent transients that would produce pressure excursions exceeding the Appendix G P/T limits while the reactor is operating at low temperatures, the licensee installed an LTOP system. The LTOP system includes pressure relieving devices in the form of Power-Operated Relief Valves (PORVs) that are set at a pressure low enough that if a transient occurred while the coolant temperature is below the LTOP enabling temperature, they would prevent the pressure in the reactor vessel from exceeding the Appendix G P/T limits. To prevent these valves from lifting as a result of normal operating pressure surges (e.g., reactor coolant pump starting, and shifting operating charging pumps) with the reactor coolant system in a water solid condition, the operating pressure must be maintained below the PORV setpoint.

In addition, in order to prevent cavitation of a reactor coolant pump, the operator must maintain a differential pressure across the reactor coolant pump seals. Hence, the licensee must operate the plant in a pressure window that is defined as the difference between the minimum required pressure to start a reactor coolant pump and the operating margin to prevent lifting of the PORVs due to normal operating pressure surges. The licensee LTOP analysis indicates that using the Appendix G safety margins to determine the PORV setpoint would result in a pressure setpoint within its operating window, but there would be no margin for normal operating pressure surges. Therefore, operating with these limits could result in the lifting of the PORVs and cavitation of the reactor coolant pumps during normal operation.

Therefore, the licensee proposed that in determining the PORV setpoint for LTOP events for McGuire, the allowable pressure be determined using the safety

margins developed in an alternate methodology in lieu of the safety margins required by Appendix G to 10 CFR Part 50. The alternate methodology is consistent with ASME Code Case N-514. The content of this code case has been incorporated into Appendix G of Section XI of the ASME Code and published in the 1993 Addenda to Section XI.

An exemption from 10 CFR 50.60 is required to use the alternate methodology for calculating the maximum allowable pressure for LTOP considerations. By application dated June 28, as supplemented August 18, 1994 (and further clarified by letter dated September 7, 1994), the licensee requested an exemption from 10 CFR 50.60.

Environmental Impacts of the Proposed Action:

The Commission has completed its evaluation of the licensee's application.

Appendix G of the ASME Code requires that the P/T limits be calculated: (a) using a safety factor of 2 on the principal membrane (pressure) stresses, (b) assuming a flaw at the surface with a depth of one-quarter (1/4) of the vessel wall thickness and a length of six (6) times its depth, and (c) using a conservative fracture toughness curve that is based on the lower bound of static, dynamic, and crack arrest fracture toughness tests on material similar to the McGuire reactor vessel material.

In determining the PORV setpoint for LTOP events, the licensee proposed to use safety margins based on an alternate methodology consistent with the proposed ASME Code Case N-514 guidelines. The ASME Code Case N-514 allows determination of the setpoint for LTOP events such that the maximum pressure in the vessel would not exceed 110% of the P/T limits of the existing ASME

Appendix G. This results in a safety factor of 1.8 on the principal membrane stresses. All other factors, including assumed flaw size and fracture toughness, remain the same. Although this methodology would reduce the safety factor on the principal membrane stresses, use of the proposed criteria will provide adequate margins of safety to the reactor vessel during LTOP transients.

Accordingly, the Commission concludes that this proposed action would result in no significant radiological environmental impact.

With regard to potential non-radiological impacts, the proposed change involves use of more realistic safety margins for determining the PORV setpoint during LTOP events. It does not affect non-radiological plant effluents and has no other environmental impact. Therefore, the Commission concludes that there are no significant non-radiological environmental impacts associated with the proposed exemption.

Alternative to the Proposed Action:

As an alternative to the proposed action, the staff considered denial of the proposed action. Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

Alternative Use of Resources:

This action did not involve the use of any resources not previously considered in the Final Environmental Statements related to operation of the McGuire Nuclear Station, dated April 1976, and its addendum dated January 1981.

Agencies and Persons Consulted:

The NRC staff consulted with the state of Tennessee regarding the environmental impact of the proposed action. The state official had no comments.

FINDING OF NO SIGNIFICANT IMPACT:

The Commission has determined not to prepare an environmental impact statement for the proposed exemption.

Based upon the foregoing environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment.

For further details with respect to this action, see the request for exemption dated June 28, as supplemented August 18, 1994 (and further clarified by letter dated September 7, 1994), which is available for public inspection at the Commission's Public Document Room, 2120 L Street, NW., Washington, DC and at the local public document room located at the Atkins Library, University of North Carolina, Charlotte (UNCC Station), North Carolina 28223.

Dated at Rockville, Maryland, this 28th day of September, 1994.

FOR THE NUCLEAR REGULATORY COMMISSION



Victor Nerses, Acting Project Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation