

March 22, 1994

Docket Nos. 50-369  
and 50-370

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

Distribution

~~Docket File~~  
NRC/Local PDRs  
PDII-3 Reading  
S.Varga  
~~XXXXXXXXXX~~  
V.Nerses  
L.Berry  
OGC 15B18

D.Hagan MNB4702  
G.Hill(4) P1-37  
C.Grimes 11F23  
ACRS(10) P-135  
PA 17F2  
OC/LFMB MNB4702  
E.Merschhoff, RII  
D. Matthews

SUBJECT: ISSUANCE OF AMENDMENTS - McGUIRE NUCLEAR STATION, UNITS 1 AND 2  
(TAC NOS. M88120 AND M88121)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 141 to Facility Operating License NPF-9 and Amendment No. 123 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994.

The amendments reduce the required minimum measured reactor coolant system flow from 385,000 gallons per minute (gpm) to 382,000 gpm.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Victor Nerses, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 141 to NPF-9
2. Amendment No. 123 to NPF-17
3. Safety Evaluation

cc w/enclosures:  
See next page

OFFICE	PDII-3/LA	PDII-3/PM	OGC <i>by rick</i>	PDII-3/D <i>DM</i>	
NAME	L. BERRY <i>LB</i>	V. NERSES:dt <i>VN</i>	<i>Uy</i>	D. MATTHEWS <del>XXXXXXXXXX</del>	
DATE	<i>2/12/94</i>	<i>2/23/94</i>	<i>3/12/94</i>	<i>3/24/94</i>	

OFFICIAL RECORD COPY  
FILE NAME:G:\MCGUIRE/MCG88120.AMD

9403300010 940322  
PDR ADOCK 05000369  
P PDR

280030

FORM 575 OFFICIAL COPY

CP-1  
DFOI



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 22, 1994

Docket Nos. 50-369  
and 50-370

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: ISSUANCE OF AMENDMENTS - McGUIRE NUCLEAR STATION, UNITS 1 AND 2  
(TAC NOS. M88120 AND M88121)

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 141 to Facility Operating License NPF-9 and Amendment No. 123 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TSs) in response to your application dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994.

The amendments reduce the required minimum measured reactor coolant system flow from 385,000 gallons per minute (gpm) to 382,000 gpm.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script that reads "Victor Nerses".

Victor Nerses, Project Manager  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 141 to NPF-9
2. Amendment No. 123 to NPF-17
3. Safety Evaluation

cc w/enclosures:  
See next page

Mr. T. C. McMeekin  
Duke Power Company

McGuire Nuclear Station

cc:

A. V. Carr, Esquire  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

County Manager of Mecklenberg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. R. O. Sharpe  
Compliance  
Duke Power Company  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, NC 28078-8985

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW.  
Washington, DC 20005

Senior Resident Inspector  
c/o U. S. Nuclear Regulatory  
Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Mr. T. Richard Puryear  
Nuclear Technical Services Manager  
Westinghouse Electric Corporation  
Carolinas District  
2709 Water Ridge Parkway, Suite 430  
Charlotte, North Carolina 28217

Dr. John M. Barry  
Mecklenberg County  
Department of Environmental  
Protection  
700 N. Tryon Street  
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director  
Department of Environmental,  
Health and Natural Resources  
Division of Radiation Protection  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Mr. Mark Lesser, Section Chief  
Project Branch #3  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of  
Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242-0001

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 141  
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 141, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification  
Changes

Date of Issuance: **March 22, 1994**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123  
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated October 25, 1993, as supplemented December 3, 1993, and February 14, 1994, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director  
Project Directorate II-3  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification  
Changes

Date of Issuance:     **March 22, 1994**

ATTACHMENT TO LICENSE AMENDMENT NO. 141

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 123

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove  
Pages

2-2  
2-3  
2-5  
2-8  
2-9  
2-10  
2-11  
3/4 2-24

Insert  
Pages

2-2  
2-3  
2-5  
2-8  
2-9  
2-10  
2-11  
3/4 2-24






Figure 2.1-1  
REACTOR CORE SAFETY LIMITS - FOUR LOOPS IN OPERATION

This page intentionally left blank

1

TABLE 2.2-1

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABL VALUES</u>
1. Manual Reactor Trip	N.A.	N.A.
2. Power Range, Neutron Flux	Low Setpoint - $\leq 25\%$ of RATED THERMAL POWER  High Setpoint - $\leq 109\%$ of RATED THERMAL POWER	Low Setpoint - $\leq 26\%$ of RATED THERMA POWER  HighSetpoint - $\leq 110\%$ of RATED THERMA POWER
3. Power Range, Neutron Flux, High Positive Rate	$\leq 5\%$ of RATED THERMAL POWER with a time constant $\geq 2$ seconds	$\leq 5.5\%$ of RATED THERMAL POWER with a time constant $\geq 2$ seconds
4. Intermediate Range, Neutron Flux	$\leq 25\%$ of RATED THERMAL POWER	$\leq 30\%$ of RATED THERMAL POWER
5. Source Range, Neutron Flux	$\leq 10^5$ counts per second	$\leq 1.3 \times 10^5$ counts per second
6. Overtemperature $\Delta T$	See Note 1	See Note 3
7. Overpower $\Delta T$	See Note 2	See Note 4
8. Pressurizer Pressure--Low	$\geq 1945$ psig	$\geq 1935$ psig
9. Pressurizer Pressure--High	$\leq 2385$ psig	$\leq 2395$ psig
10. Pressurizer Water Level--High	$\leq 92\%$ of instrument span	$\leq 93\%$ of instrument span
11. Low Reactor Coolant Flow	$\geq 90\%$ of minimum measured flow per loop*	$\geq 88.8\%$ of minimum measured flow per loop*

\*Minimum measured flow is 95,500 gpm per loop.

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION

NOTE 1: OVERTEMPERATURE  $\Delta T$

$$(\Delta T / \Delta T_0) \left( \frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left( \frac{1}{1 + \tau_3 S} \right) \leq K_1 - K_2 \left( \frac{1 + \tau_4 S}{1 + \tau_5 S} \right) [T \left( \frac{1}{1 + \tau_6 S} \right) - T_1] + K_3 (P - P^1) - f_1(\Delta I)$$

Where:  $\Delta T$  = Measured  $\Delta T$  by Loop Narrow Range RTD,

$\Delta T_0$  = Indicated  $\Delta T$  at RATED THERMAL POWER,

$\frac{1 + \tau_1 S}{1 + \tau_2 S}$  = Lead-lag compensator on measured  $\Delta T$ ,

$\tau_1, \tau_2$  = Time constants utilized in the lead-lag controller for  $\Delta T$ ,  $\tau_1 \geq 8$  sec.,  $\tau_2 \leq 3$  sec.,

$\frac{1}{1 + \tau_3}$  = Lag compensator on measured  $\Delta T$ ,

$\tau_3$  = Time constants utilized in the lag compensator for  $\Delta T$ ,  $\tau_3 \leq 2$  sec.\*

$K_1$   $\leq 1.1988$ ,

$K_2$  = 0.03354,

$\frac{1 + \tau_4 S}{1 + \tau_5 S}$  = The function generated by the lead-lag controller for  $T_{avg}$  dynamic compensation,

$\tau_4, \tau_5$  = Time constants utilized in the lead-lag controller for  $T_{avg}$ ,  
 $\tau_4 \geq 28$  sec.,  $\tau_5 \leq 4$  sec.,

$T$  = Average temperature, °F,

$\frac{1}{1 + \tau_6 S}$  = Lag compensator on measured  $T_{avg}$ ,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

NOTE 1: (Continued)

- $\tau_6$  = Time constant utilized in the measured  $T_{avg}$  lag compensator,  $\tau_6 \leq 2$  sec.
- $T^1$  =  $\leq 588.2$  °F Reference  $T_{avg}$  at RATED THERMAL POWER,
- $K_3$  = 0.001522,
- $P$  = Pressurizer pressure, psig,
- $p^1$  = 2235 psig (Nominal RCS operating pressure),
- $S$  = Laplace transform operator,  $\text{sec}^{-1}$ ,

and  $f_1(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:

- (i) for  $q_t - q_b$  between  $-44.0\%$  and  $+12.0\%\Delta I$ ;  $f_1(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent imbalance that the magnitude of  $q_t - q_b$  is more negative than  $-44.0\%\Delta I$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 3.436% of  $\Delta T_o$ ; and
- (iii) for each percent imbalance that the magnitude of  $q_t - q_b$  is more positive than  $+12.0\%\Delta I$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 1.619% of  $\Delta T_o$ .

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

NOTE 2: OVERPOWER  $\Delta T$

$$(\Delta T / \Delta T_0) \left( \frac{1 + \tau_1 S}{1 + \tau_2 S} \right) \left( \frac{1}{1 + \tau_3 S} \right) \leq K_4 - K_5 \left( \frac{\tau_7 S}{1 + \tau_7 S} \right) \left( \frac{1}{1 + \tau_6 S} \right) T - K_6 \left[ T \left( \frac{1}{1 + \tau_6 S} - T'' \right) - f_2 (\Delta I) \right]$$

Where:  $\Delta T$  = As defined in Note 1,

$\Delta T_0$  = As defined in Note 1,

$\frac{1 + \tau_1 S}{1 + \tau_2 S}$  = As defined in Note 1

$\tau_1, \tau_2$  = As defined in Note 1

$\frac{1}{1 + \tau_3 S}$  = As defined in Note 1,

$K_4$   $\leq$  1.0851,

$K_5$  = 0.02/°F for increasing average temperature and 0 for decreasing average temperature,

$\frac{\tau_7 S}{1 + \tau_7 S}$  = The function generated by the rate-lag controller for  $T_{avg}$  dynamic compensation,

$\tau_7$  = Time constant utilized in the rate-lag controller for  $T_{avg}$ ,  $\tau_7 \geq 5$  sec,

$\frac{1}{1 + \tau_6 S}$  = As defined in Note 1,

$\tau_6$  = As defined in Note 1,

$K_6$  = 0.001207/°F for  $T > T''$  and  $K_6 = 0$  for  $T \leq T''$ ,

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

NOTATION (Continued)

$T_{ref}$  = As defined in Note 1,  
 $T''$  =  $\leq 588.2$  °F Reference  $T_{avg}$  at RATED THERMAL POWER,  
 $S$  = As defined in Note 1, and

$f_2(\Delta I)$  is a function of the indicated difference between top and bottom detectors of the power-range nuclear ion chambers; with gains to be selected based on measured instrument response during plant startup tests such that:


- (i) for  $q_t - q_b$  between  $-35\%$  and  $+35\% \Delta I$ ;  $f_2(\Delta I) = 0$ , where  $q_t$  and  $q_b$  are percent RATED THERMAL POWER in the top and bottom halves of the core respectively, and  $q_t + q_b$  is total THERMAL POWER in percent of RATED THERMAL POWER;
- (ii) for each percent imbalance that the magnitude of  $q_t - q_b$  is more negative than  $-35\% \Delta I$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 7.0% of  $\Delta T_o$ ; and
- (iii) for each percent imbalance that the magnitude of  $q_t - q_b$  is more positive than  $+35\% \Delta I$ , the  $\Delta T$  Trip Setpoint shall be automatically reduced by 7.0% of  $\Delta T_o$ .

Note 3: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 4.4% of Rated Thermal Power.

Note 4: The channel's maximum Trip Setpoint shall not exceed its computed Trip Setpoint by more than 3.0% of Rated Thermal Power.

## POWER DISTRIBUTION LIMITS

Figure 3.2-1 Reactor Coolant System Total Flow Rate Versus  
Rated Thermal Power - Four Loops in Operation







UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 141 TO FACILITY OPERATING LICENSE NPF-9  
AND AMENDMENT NO. 123 TO FACILITY OPERATING LICENSE NPF-17

DUKE POWER COMPANY

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-369 AND 50-370

1.0 INTRODUCTION

By letter dated October 25, 1993 (Reference 1), as supplemented December 3, 1993 (Reference 2), and February 14, 1994 (Reference 3), Duke Power Company (the licensee) submitted a request for changes to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS). The requested changes would reduce the required minimum measured reactor coolant system flow from 385,000 gallons per minute (gpm) to 382,000 gpm. The December 3, 1993, letter provided information in response to the staff's November 19, 1993, request for additional information. The February 14, 1994, letter requested NRC staff approval that the flow-reduction portion of the requested TS change be separated from the approval of the safety limit portion of the requested TS change. Therefore, the remaining changes to TS Figures 2.1-1 and 3.2-1, and TS Table 2.2-1, to reflect a reduction in the reactor coolant system minimum required flow rate, are approved as discussed below. The licensee's February 14, 1994, requested change reduced the scope of the October 25, 1993, application and reduced the scope of the initial proposed no significant hazards consideration determination, but otherwise did not change the NRC staff's initial determination that the three standards of 10 CFR 50.92(c) are satisfied.

The reasons for the licensee's request in the October 25, 1993, application, as supplemented December 3, 1993, and February 14, 1994, are that the degrading of the steam generator tubes in McGuire, Units 1 and 2, have necessitated that tubes be plugged or sleeved, which reduces the available flow area in the steam generators and consequently reduces flow through the core. In addition, a hot leg temperature streaming phenomenon has affected the ability to accurately measure flow. As a result of these effects, it was difficult to ensure meeting the TS minimum flow requirements to maintain 100% power operation.

The following TS were modified to reflect the reduction in reactor coolant system (RCS) flow:

- 1) Figure 2.1-1, Reactor Core Protection Limits - Four Loops in Operation,

9403300020 940322  
PDR ADOCK 05000369  
P PDR

- 2) Figure 3.2-1, Reactor Coolant System Total Flow Rate Versus Rated Thermal Power - Four Loops in Operation, and
- 3) The overtemperature delta T ( $\text{OT}\Delta\text{T}$ ) and overpower delta T ( $\text{OP}\Delta\text{T}$ ) setpoint equation constants in Table 2.2-1, Reactor Trip System Instrumentation Trip Setpoints.

These revisions are applicable to McGuire, Units 1 and 2.

## 2.0 EVALUATION

### 2.1 Revision of $\text{OT}\Delta\text{T}$ and $\text{OTAP}$ Parameters in Table 2.2-1

To support the reduction in measured minimum RCS flow (MMF), changes were required for the  $\text{OP}\Delta\text{T}$  setpoints for McGuire, Units 1 and 2. These changes involved recalculation of the TS allowable values of the trip functions. The revised core thermal limits were generated to reflect the reduced MMF of 382,000 gpm. Based on these new protection limits, the  $\text{OT}\Delta\text{T}$  setpoint constants (Note 1 of Table 2.2-1), and the  $\text{OP}\Delta\text{T}$  setpoint equation constants (Notes 2 and 3 of Table 2.2-1) were revised to reflect the necessary changes. The impact of the reduced flow on the coefficients was partially offset by a reduction in the margin assumed in the calculation of the coefficients.

The revised  $\text{OP}\Delta\text{T}$  allowable values are more restrictive than the existing values. In the course of these calculations, a minor error was discovered by the licensee that affected the existing allowable values. This resulted in a recalculation of the allowable value affected by the flow reduction.

The revision required for the McGuire  $\text{OT}\Delta\text{T}$  allowable value is less restrictive than the existing value. To improve clarity, the maximum trip setpoint limit in Notes 2 and 4 of TS Table 2.2-1 will be expressed in percent of rated thermal power (RTP) instead of percent instrument span.

In response to a request for additional information, the licensee responded (Reference 2) with information which provided the approved methodology (Reference 4) for the changes made relating to  $\text{OP}\Delta\text{T}$  and  $\text{OT}\Delta\text{T}$ . The staff, therefore, finds these changes to be acceptable.

### 2.2 The Effect of Reduced Flow on the Final Safety Analysis Report Analyses

The licensee performed analyses to justify reduction in the minimum RCS flow to 382,000 gpm. These analyses were to show that the reduced flow rate will not have a significant impact on any accident analyses presented in the Final Safety Analysis Report (FSAR) Chapters 4, 6, or 15.

#### 2.2.1 Thermal Hydraulic Design, FSAR Section 4.4

The thermal hydraulic design for the McGuire units was analyzed by the licensee with the reduction in RCS MMF to 382,000 gpm. The reduced flow rate resulted in a slight reduction of the margin in the core DNB limits. TS Figure 3.2-1, Reactor Coolant System Total Flow Rate Versus Rated Thermal Power - Four Loops in Operation, was revised to reflect the lower allowable

flow rate. For the changes made in RCS flow at reduced power, the licensee stated (Reference 2) that the RCS flow values were determined using the same 2% power per 1% flow reduction factor used in the existing TS figure. The axial Flux Difference Limits, TS Section 3.2.1, are unchanged and all the current thermal hydraulic design criteria are satisfied at the reduced flow conditions.

#### 2.2.2 Mass and Energy Releases for Containment Analyses, FSAR Chapter 6

Duke Power stated that the reduction in MMF flow affects the mass and energy releases for containment analysis only through a change in the RCS temperature input assumption. As the RCS average temperature will remain unchanged with the change in MMF, the RCS initial fluid and metal stored energy will remain unchanged. Also, a constant RCS average temperature implies that the driving temperature difference for primary-to-secondary heat transfer will remain unchanged. These two parameters, initial energy content and rate of energy transfer, are the means by which mass and energy releases influence containment response for the transients analyzed in Chapter 6 of the FSAR. Since the reduction in MMF is being made with a negligible change in RCS temperature, the licensee stated that the mass and energy releases calculated in FSAR Chapter 6 will not be affected.

#### 2.2.3 Accident Analyses, FSAR Chapter 15

All of the FSAR Chapter 15 accident analyses which are applicable to the McGuire units were explicitly analyzed by the licensee with an initial RCS flow assumption that corresponds to an MMF of 382,000 gpm, or have been evaluated to determine the impact of a reduction in MMF of 3,000 gpm.

The following analyses were reanalyzed by DPC with an initial RCS flow assumption which is less than or equal to an MMF flow of 382,000 gpm.

- 15.1.5 Steam System Piping Failure
- 15.2.3b Turbine Trip - Peak Primary Pressure
- 15.2.6 Loss of Non-emergency AC Power
- 15.2.7 Loss of Normal Feedwater Flow
- 15.2.8 Feedwater System Pipe Break
- 15.3.1 Partial Loss of Reactor Coolant System Flow
- 15.3.2 Complete Loss of Reactor Coolant System Flow
- 15.3.3 Locked Rotor
- 15.4.1 Uncontrolled Bank Withdrawal from Subcritical
- 15.4.2 Uncontrolled Bank Withdrawal at Power
- 15.4.3 Rod Assembly Misoperation
- 15.4.8 Rod Ejection
- 15.6.3 Steam Generator Tube Rupture
- 15.6.5 Loss of Coolant Accident

Events that were not reanalyzed included those that are bounded by other more limiting events as stated in the licensee's Topical Report DPC-NE-3002-A and events which are analyzed with the acceptance criteria of no departure from nucleate boiling.

As noted above, the licensee has performed reanalyses or has made evaluations that determine that the reduction in MMF will not adversely affect the steady state or transient analyses documented in Chapters 4, 6, and 15 of the McGuire FSAR. Duke Power stated (Reference 2) that the reanalyses used approved codes (References 5 to 9). Therefore, the staff finds the decrease in the MMF from 385,000 gpm to 382,000 gpm in the McGuire, Units 1 and 2, TS to be acceptable.

The staff has reviewed the licensee's submittal to support the reduction in the required minimum measured reactor coolant system flow and finds the TS changes to be acceptable.

### 3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the North Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

### 4.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluent that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (58 FR 67842 dated December 22, 1993). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

### 5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: H. Balukjian  
R. Martin

Date: March 22, 1994

#### REFERENCES

1. Letter from M. S. Tuckman, DPC, to USNRC, dated October 25, 1993.
2. Letter from M. S. Tuckman, DPC, to USNRC, dated December 3, 1993.
3. Letter from M. S. Tuckman, DPC, to USNRC, dated February 14, 1994.
4. Letter from T. C. McMeekin, DPC, to USNRC, dated April 26, 1993.
5. Kabadi, J. N., et al., "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code," WCAP-10266P-A, Rev. 2, March 1987.
6. N. Lee, et al., "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," WCAP-10054P-A, August 1985.
7. DPC-NE-3000P-A, Rev. 1, "Thermal-Hydraulic Transient Analysis Methodology," November 1991.
8. DPC-NE-3001P-A, "Multidimensional Reactor Transients and Safety Analysis Physics Parameter Methodology," November 1991.
9. DPC-NE-3002-A, "FSAR Chapter 15 System Transient Analysis Methodology," November 1991.