

August 2, 1994

Docket Nos. 50-369
and 50-370

DISTRIBUTION

Docket File	D.Hagan
NRC/Local PDRs	G.Hill(4)
PDII-3 Reading	C.Grimes
S.Varga	ACRS (10)
G.Lainas	PA
H.Berkow	OC/LFDCB
V.Nerses	OGC
L.Berry	E.Merschhoff,RII

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENTS 144 AND 126

The Nuclear Regulatory Commission issued Amendments 144 and 126 to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS) on July 18, 1994.

Please replace TS pages 3/4 3-56 and 3/4 3-57 with the enclosed corrected pages that revised minor editorial errors.

Sincerely,

Original signed by:

Robert E. Martin, Acting Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Corrected TS pages

cc w/enclosure:
See next page

OFFICE	PDII-3/LA	PDII-3/PM	PDII-3/D		
NAME	L. BERRY	R. MARTIN	H. BERKOW		
DATE	8/2/94	8/2/94	8/2/94		

OFFICIAL RECORD COPY
FILE NAME: G:\MCGUIRE\AMD144.COR

9408080080 940802
PDR ADOCK 05000369
P PDR

NRC FILE CENTER COPY

DF01



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 2, 1994

Docket Nos. 50-369
and 50-370

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

Dear Mr. McMeekin:

SUBJECT: CORRECTION TO AMENDMENTS 144 AND 126

The Nuclear Regulatory Commission issued Amendments 144 and 126 to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS) on July 18, 1994.

Please replace TS pages 3/4 3-56 and 3/4 3-57 with the enclosed corrected pages that revised minor editorial errors.

Sincerely,

A handwritten signature in cursive script that reads "Robert E. Martin".

Robert E. Martin, Acting Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
Corrected TS pages

cc w/enclosure:
See next page

Mr. T. C. McMeekin
Duke Power Company

McGuire Nuclear Station

cc:

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

County Manager of Mecklenberg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. J. E. Snyder
Regulatory Compliance Manager
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

Dr. John M. Barry
Mecklenberg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Marvin Sinkule, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-
0001

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

TABLE 3.3-10

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NO. OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>
1. Containment Pressure	2	1
2. Reactor Coolant Temperature - T _{HOT} and T _{COLD} (Wide Range)	2/T _{HOT} 2/T _{COLD}	1/T _{HOT} 1/T _{COLD}
3. Reactor Coolant Pressure - Wide Range	2	1
4. Pressurizer Water Level	2	1
5. Steam Line Pressure	2/steam generator	1/steam generator
6. Steam Generator Water Level - Narrow Range	2/steam generator	1/steam generator
7. Refueling Water Storage Tank Water Level	2	1
8. Auxiliary Feeder Flow Rate	2/steam generator	1/steam generator
9. Reactor Coolant System Subcooling Margin Monitor	2	1
10. Containment Water Level (Wide Range)	2	1
11. In Core Thermocouples	4/core quadrant	2/core quadrant
12. Containment Atmosphere - High Range Monitor (EMF-51a or 51b)	1	1
13. Reactor Vessel Level Instrumentation		
a. Dynamic Head (D/P) Range	2	1
b. Lower Range	2	1
14. Neutron Flux - Wide Range	2	1
15. Containment Hydrogen Concentration	2	1
16. Diesel Generator Cooling Water Heat Exchanger RN Flow*	1/diesel generator	1/diesel generator
17. Containment Spray Heat Exchanger RN Flow*	1/train	1/train

*Not applicable if the associated outlet valve is set to its flow balance position with power removed or if the associated outlet valve's flow balance position is fully open.

McGUIRE - UNITS 1 & 2
 9408080083 940802
 PDR ADDCK 05000369
 PDR

3/4 3-57

Amendment No. 144 (Unit 1)
 Amendment No. 126 (Unit 2)

TABLE 4.3-7
ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Containment Pressure	M	R
2. Reactor Coolant Temperature - T _{HOT} and T _{COLD} (Wide Range)	M	R
3. Reactor Coolant Pressure - Wide Range	M	R
4. Pressurizer Water Level	M	R
5. Steam Line Pressure	M	R
6. Steam Generator Water Level - Narrow Range	M	R
7. Refueling Water Storage Tank Water Level	M	R
8. Auxiliary Feedwater Flow Rate	M	R
9. Reactor Coolant System Subcooling Margin Monitor	M	R
10. Containment Water Level (Wide Range)	M	R
11. In Core Thermocouples	M	R
12. Containment Atmosphere - High Range Monitor (EMF-51a or 51b)	M	R
13. Reactor Vessel Level Instrumentation		
a. Dynamic Head (D/P) Range	M	R
b. Lower Range	M	R
14. Neutron Flux - Wide Range	M	R
15. Containment Hydrogen Concentration	M	R
16. Diesel Generator Cooling Water Heat Exchanger RN Flow	M	R
17. Containment Spray Heat Exchanger RN Flow	M	R

McGUIRE - UNITS 1 & 2

3/4 3-57

Amendment No. 144 (Unit 1)
Amendment No. 126 (Unit 2)