





UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

August 2, 1995

Mr. T. C. McMeekin  
Vice President, McGuire Site  
Duke Power Company  
12700 Hagers Ferry Road  
Huntersville, NC 28078-8985

SUBJECT: ISSUANCE OF AMENDMENTS - McGUIRE NUCLEAR STATION, UNITS 1 AND 2  
RELOCATION OF SEISMIC INSTRUMENTATION, METEOROLOGICAL  
INSTRUMENTATION, AND LOOSE-PART DETECTION SYSTEM  
(TAC NOS. M91426 AND M91426)

Dear Mr. McMeekin:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 158 to Facility Operating License NPF-9 and Amendment No. 140 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated January 18, 1995.

The amendments delete selected TS requirements related to instrumentation from the TS, and relocate them to the Selected Licensee Commitment (SLC) Manual, with their associated Bases and surveillance requirements. No changes are being made to the technical content of the affected TS pages. Future changes to the SLC Manual (Chapter 16 of the Final Safety Analysis Report) will be controlled by the provisions of 10 CFR 50.59. The relocated requirements include the following:

- TS 3/4.3.3.3, Seismic Instrumentation
- TS 3/4.3.3.4, Meteorological Instrumentation
- TS 3/4.10, Loose-Part Detection System

A copy of the related Safety Evaluation is enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Victor Nerses".

Victor Nerses, Senior Project Manager  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Enclosures:

1. Amendment No. 158 to NPF-9
2. Amendment No. 140 to NPF-17
3. Safety Evaluation

cc w/encl: See next page

Mr. T. C. McMeekin  
Duke Power Company

McGuire Nuclear Station

cc:

A. V. Carr, Esquire  
Duke Power Company  
422 South Church Street  
Charlotte, North Carolina 28242-0001

County Manager of Mecklenberg County  
720 East Fourth Street  
Charlotte, North Carolina 28202

Mr. J. E. Snyder  
Regulatory Compliance Manager  
Duke Power Company  
McGuire Nuclear Site  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078-  
8985

J. Michael McGarry, III, Esquire  
Winston and Strawn  
1400 L Street, NW.  
Washington, DC 20005

Senior Resident Inspector  
c/o U. S. Nuclear Regulatory  
Commission  
12700 Hagers Ferry Road  
Huntersville, North Carolina 28078

Mr. T. Richard Puryear  
Nuclear Technical Services Manager  
Westinghouse Electric Corporation  
Carolinas District  
2709 Water Ridge Parkway, Suite 430  
Charlotte, North Carolina 28217

Dr. John M. Barry  
Mecklenberg County  
Department of Environmental  
Protection  
700 N. Tryon Street  
Charlotte, North Carolina 28202

Mr. Dayne H. Brown, Director  
Department of Environmental,  
Health and Natural Resources  
Division of Radiation Protection  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Ms. Karen E. Long  
Assistant Attorney General  
North Carolina Department of  
Justice  
P. O. Box 629  
Raleigh, North Carolina 27602

Mr. G. A. Copp  
Licensing - EC050  
Duke Power Company  
526 South Church Street  
Charlotte, North Carolina 28242-  
0001

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street, NW. Suite 2900  
Atlanta, Georgia 30323

Elaine Wathen, Lead REP Planner  
Division of Emergency Management  
116 West Jones Street  
Raleigh, North Carolina 27603-1335



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 158  
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated January 18, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9508070356 950802  
PDR ADOCK 05000369  
P PDR


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 158, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification  
Changes

Date of Issuance: August 2, 1995



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 140  
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated January 18, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 140, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director  
Project Directorate II-2  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Technical Specification  
Changes

Date of Issuance: August 2, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 158

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

AND

TO LICENSE AMENDMENT NO. 140

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

VII  
VIII  
3/4 3-46  
3/4 3-47  
3/4 3-48  
3/4 3-49  
3/4 3-50  
3/4 3-51  
3/4 3-78  
B 3/4 3-3  
B 3/4 3-5

Insert Pages

VII  
VIII  
3/4 3-46  
3/4 3-47  
3/4 3-48  
3/4 3-49  
3/4 3-50  
3/4 3-51  
3/4 3-78  
B 3/4 3-3  
B 3/4 3-5



INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

---

| <u>SECTION</u>  | <u>PAGE</u> |
|---|-------------|
| Movable Incore Detectors.....                               | 3/4 3-45    |
| [DELETED] .....   | 3/4 3-46    |
| TABLE 3.3-7 [DELETED] .....                                 | 3/4 3-47    |
| TABLE 4.3-4 [DELETED] .....                                 | 3/4 3-48    |
| [DELETED] .....   | 3/4 3-49    |
| TABLE 3.3-8 [DELETED] .....                                 | 3/4 3-50    |
| TABLE 4.3-5 [DELETED] .....                                 | 3/4 3-51    |
| Remote Shutdown Instrumentation.....                        | 3/4 3-52    |
| TABLE 3.3-9 REMOTE SHUTDOWN MONITORING INSTRUMENTATION..... | 3/4 3-53    |

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

| <u>SECTION</u>   | <u>PAGE</u> |
|--|-------------|
| TABLE 4.3-6    REMOTE SHUTDOWN MONITORING INSTRUMENTATION<br>SURVEILLANCE REQUIREMENTS . . . . . | 3/4 3-54    |
| Accident Monitoring Instrumentation . . . . .  | 3/4 3-55    |
| TABLE 3.3-10    ACCIDENT MONITORING INSTRUMENTATION . . . . .                                    | 3/4 3-56    |
| TABLE 4.3-7    ACCIDENT MONITORING INSTRUMENTATION<br>SURVEILLANCE REQUIREMENTS . . . . .        | 3/4 3-57    |
| Explosive Gas Monitoring Instrumentation . . . . .   | 3/4 3-71    |
| TABLE 3.3-13    EXPLOSIVE GAS MONITORING INSTRUMENTATION . . . . .                               | 3/4 3-72    |
| TABLE 4.3-9    EXPLOSIVE GAS MONITORING INSTRUMENTATION<br>SURVEILLANCE REQUIREMENTS . . . . .   | 3/4 3-75    |
| [DELETED] . . . . .  | 3/4 3-78    |
| 3/4.3.4    [DELETED] . . . . .   | 3/4 3-79    |
| <u>3/4.4 REACTOR COOLANT SYSTEM</u>  |             |
| 3/4.4.1    REACTOR COOLANT LOOPS AND COOLANT CIRCULATION   |             |
| Startup and Power Operation . . . . .  | 3/4 4-1     |
| Hot Standby . . . . .  | 3/4 4-2     |
| Hot Shutdown . . . . .   | 3/4 4-3     |
| Cold Shutdown - Loops Filled . . . . .   | 3/4 4-5     |

This Page Deleted

This Page Deleted

This Page Deleted

This Page Deleted

This Page Deleted

This Page Deleted



This Page Deleted

## INSTRUMENTATION

### BASES

---

#### MOVABLE INCORE DETECTORS (Continued)

of the core. The OPERABILITY of this system is demonstrated by irradiating each detector used and determining the acceptability of its voltage curve.

For the purpose of measuring  $F_Q(Z)$  or  $F_{\Delta H}^N$ , a full incore flux map is used. Quarter-core flux maps, as defined in WCAP-8648, June 1976, may be used in recalibration of the Excore Neutron Flux Detection System, and full incore flux maps or symmetric incore thimbles may be used for monitoring the QUADRANT POWER TILT RATIO when one Power Range channel is inoperable.

#### 3/4.3.3.3 Deleted

#### 3/4.3.3.4 Deleted

#### 3/4.3.3.5 REMOTE SHUTDOWN INSTRUMENTATION

The OPERABILITY of the remote shutdown instrumentation ensures that sufficient capability is available to permit shutdown and maintenance of HOT STANDBY of the facility from locations outside of the control room. This capability is required in the event control room habitability is lost and is consistent with General Design Criterion 19 of 10 CFR 50.

#### 3/4.3.3.6 ACCIDENT MONITORING INSTRUMENTATION

The OPERABILITY of the accident monitoring instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables following an accident. This capability is consistent with the recommendations of Regulatory Guide 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant Conditions During and Following an Accident," December 1975 and NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations "

BASES

---

3/4.3.3.10 Deleted

3/4.3.4 Deleted



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
RELATED TO AMENDMENT NO. 158 TO FACILITY OPERATING LICENSE NPF-9  
AND AMENDMENT NO. 140 TO FACILITY OPERATING LICENSE NPF-17  
DUKE POWER COMPANY  
MCGUIRE NUCLEAR STATION, UNITS 1 AND 2  
DOCKET NOS. 50-369 AND 50-370

1.0 INTRODUCTION

By letter dated January 18, 1995, Duke Power Company (the licensee) submitted a request for changes to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS). The requested changes would delete selected TS requirements related to instrumentation, with their associated Bases and surveillance requirements, from the TS and relocate them to the Selected License Commitment (SLC) Manual, Chapter 16 of the Final Safety Analysis Report. The relocated requirements include TS 3/4.3.3.3, "Seismic Instrumentation", TS 3/4.3.3.4, "Meteorological Instrumentation", and TS 3/4.3.3.10, "Loose-Part Detection System". No changes are being made to the technical content of the relocated requirements. Future changes will be controlled by the provisions of 10 CFR 50.59.

Section 182a of the Atomic Energy Act, as amended (the "Act"), requires that applicants for nuclear power plant operating licenses to incorporate TS as a part of the license. The Commission's regulatory requirements related to the content of the TS are set forth in 10 CFR 50.36. That regulation requires that the TS include items in five specific categories, including (1) safety limits, limiting safety system settings and limiting control settings; (2) limiting conditions for operation; (3) surveillance requirements; (4) design features; and (5) administrative controls and states also that the Commission may include such additional TS as it finds to be appropriate. However, the regulation does not specify the particular TS to be included in a plant's license.

The Commission has provided guidance for the contents of the TS in its "Final Policy Statement on Technical Specifications Improvements for Nuclear Power Reactors" ("Final Policy Statement"), 58 FR 39132 (July 22, 1993), in which the Commission indicated that compliance with the Final Policy Statement satisfies Section 182a of the Act. In particular, the Commission indicated that certain items could be relocated from the TS to licensee-controlled documents, consistent with the standard enunciated in *Portland General Electric Co.* (Trojan Nuclear Plant), ALAB-531, 9 NRC 263, 273 (1979). In that case, the Atomic Safety and Licensing Appeal Board indicated that "technical specifications are to be reserved for those matters as to which the imposition

of rigid conditions or limitations upon reactor operation is deemed necessary to obviate the possibility of an abnormal situation or event giving rise to an immediate threat to the public health and safety."

Consistent with this approach, the Final Policy Statement identified four criteria to be used in determining whether a particular matter is required to be included in the TS, as follows: (1) Installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary; (2) A process variable, design feature, or operating restriction that is an initial condition of a Design Basis Accident or Transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (3) A structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a Design Basis Accident or Transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier; (4) A structure, system, or component which operating experience or probabilistic safety assessment has shown to be significant to public health and safety.<sup>1</sup> As a result, existing Limiting Condition for Operation (LCO) requirements which fall within or satisfy any of the criteria in the Final Policy Statement must be retained in the TS, while those LCO requirements which do not fall within or satisfy these criteria may be relocated to other, licensee-controlled documents.

## 2.0 EVALUATION

### 3/4.3.3.3 Seismic Monitoring Instrumentation

Section VI(a)(3) of Appendix A to 10 CFR Part 100 requires that seismic monitoring instrumentation be provided to promptly determine the response of those nuclear power plant features important to safety in the event of an earthquake. This capability is required to allow for a comparison of the measured response to that used in the design basis for the unit. Comparison of such data is needed to (1) determine whether the plant can continue to be operated safely, and (2) permit such timely action as may be appropriate. However, seismic instrumentation does not actuate any protective equipment or serve any direct role in the mitigation of an accident.

The capability of the plant to withstand a seismic event or other design-basis accident is determined by the initial design and construction of systems, structures, and components. The instrumentation is used to alert operators to the seismic event and evaluate the plant response. The Final Policy Statement explained that instrumentation to detect precursors to reactor coolant pressure boundary leakage, such as seismic instrumentation, is not included in the first criterion. As discussed above, the seismic instrumentation does not serve as a protective design feature or part of a primary success path for events which challenge fission product barriers. The staff has concluded that the seismic monitoring instrumentation does not satisfy the Final Policy Statement criteria and need not be included in the TS. Therefore, it is acceptable for the licensee to relocate the seismic monitoring instrumentation

<sup>1</sup>

The Commission recently promulgated a proposed change to 10 CFR 50.36, pursuant to which the rule would be amended to codify and incorporate these criteria (59 FR 48180, September 20, 1994). The Commission's Final Policy Statement specified that the Reactor Core Isolation Cooling, Isolation Condenser, Residual Heat Removal, Standby Liquid Control, and Recirculation Pump Trip are included in the TS under Criterion 4 (58 FR 39132, July 22, 1993).

requirements to the SLC Manual and control changes to those provisions in accordance with 10 CFR 50.59.

#### 3/4.3.3.4 Meteorological Instrumentation

The meteorological monitoring instrumentation is used to measure environmental parameters (wind direction, speed, and air temperature differences) which may affect the distribution of radioactive effluents following a release of radioactive material. In 10 CFR 50.47, "Emergency Plans," and 10 CFR Part 50, Appendix E, "Emergency Planning and Preparedness for Production and Utilization Facilities," the Commission requires power plant licensees to provide reasonable assurance that adequate protective measures can and will be taken in the event of a radiological emergency. Timely access to accurate local meteorological data is important for estimating potential radiation doses to the public and for determining appropriate protective measures. In 10 CFR 50.36a(a)(2), the Commission requires nuclear power plant licensees to submit annual reports specifying the quantity of each of the principal radionuclides released to unrestricted areas in liquid and airborne effluents and such other information as may be required by the NRC to estimate maximum potential annual radiation doses to the public. A knowledge of meteorological conditions in the vicinity of the reactor is important in providing a basis for estimating annual radiation doses resulting from radioactive materials released in airborne effluents. Accordingly, the meteorological monitoring instrumentation serves a useful function in estimating radiation doses to the public from either routine or accidental releases of radioactive materials to the atmosphere. The licensee has proposed to relocate these provisions to the SLC such that future changes to the operation and surveillance of the meteorological monitoring instrumentation could be changed under 10 CFR 50.59.

The meteorological monitoring instrumentation does not serve a primary protective function so as to warrant inclusion in the TS in accordance with the criteria of the Final Policy Statement. The instrumentation does not serve to ensure that the plant is operated within the bounds of initial conditions assumed in design basis accident and transient analyses or that the plant will be operated to preclude transients or accidents. Likewise, the meteorological instrumentation does not serve as part of the primary success path of a safety sequence analysis used to demonstrate that the consequences of these events are within the appropriate acceptance criteria.

Accordingly, the staff has concluded that the meteorological instrumentation does not satisfy the Final Policy Statement criteria and need not be included in TS. The staff has determined that requirements related to the meteorological monitoring instrumentation can be moved from the TS to the SLC Manual, and that any subsequent changes to the provisions would be controlled pursuant to 10 CFR 50.59. Accordingly, the relocation of the meteorological instrumentation requirements from the TS to the SLC Manual is acceptable.

#### 3/4.3.3.10 Loose-Part Detection System

The loose-part detection system identifies the existence of possible loose parts in the reactor coolant system. Early detection can provide operators time to take corrective actions and avoid or mitigate damage to or malfunctions of primary system components. However, as discussed in the Final Policy Statement, the loose-part detection system does not function to detect significant abnormal degradation of the reactor coolant pressure boundary. The loose-part detection system does not serve as an active design feature for

establishing initial conditions or mitigation of design basis accidents or transients. The staff has concluded that requirements for this system do not satisfy the Final Policy Statement criteria and need not be included in TS. Therefore, it is acceptable for the Licensee to relocate the requirements related to the loose-part detection system from the TS to the SLC Manual and to control changes to those provisions in accordance with 10 CFR 50.59.

### 3.0 STAFF CONCLUSION

On the basis of the evaluations above, the staff concludes that these requirements related to instrumentation are not required to be in the TS under 10 CFR 50.36 or Section 182a of the Act, and are not required in order to provide adequate protection to the health and safety of the public. Further, they do not fall within any of the four criteria set forth in the Commission's Final Policy Statement, discussed above. In addition, the NRC staff finds that sufficient regulatory controls exist under the provisions of 10 CFR 50.59 to ensure that future changes to these requirements will be acceptable. Accordingly, the staff has concluded that these requirements related to instrumentation may be relocated to the SLC Manual.

The NRC staff has no objection to the deletion of the Bases associated with the relocated requirements.

### 4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the South Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

### 5.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (60 FR 11132 dated March 1, 1995). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

## 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

### Principal Contributors:

William Reckley

Carl Schulten

S. S. Kirslis

Date: August 2, 1995