

Ex. 6

From: [redacted] <Doddv...>  
To: [redacted] <WLS@nrc.gov> W Schmidt  
Date: Mon, Jul 17, 2000 3:23 PM  
Subject: Re: IP2 tubes with signals in 1997

Ian:  
This filtering was not required by the guidelines, but perhaps should have been required. When an inspection has as much noise as these tubes, the designer of these tests should have used everything possible. The filter only improves the detection of the defect using the C-scan. Anything suspicious should prompt the analyst to look at the Lissajous of the scan.

I agree that these are not easy calls, but the data is there for the analysts to find these defects.  
Caius

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 6  
FOIA-2001-0256

6/21