

November 26, 2001

LICENSEE: FirstEnergy Nuclear Operating Company  
FACILITY: Davis-Besse Nuclear Power Station, Unit 1  
SUBJECT: MEETING SUMMARY OF NOVEMBER 8, 2001, TO DISCUSS THE  
LICENSEE'S RESPONSE TO BULLETIN 2001-01

On November 8, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with a representative of the FirstEnergy Nuclear Operating Company. The meeting, which was closed to the public due to the presentation of proprietary materials, was requested by the licensee in order to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin to their 13th refueling outage which is scheduled to begin in March 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included in the enclosure. There were no meeting handouts.

The licensee's justification to defer inspections recommended by the bulletin relied, in part, on the as-found condition of the reactor vessel head penetrations during the refueling outages of 1996, 1998, and 2000. The licensee's submittal of October 30, 2001, included proprietary photographs of the reactor vessel head taken during these outages. However, due to the poor quality of the photographs, the staff concluded that an independent assessment of the reactor vessel head penetrations could not be made. In an effort to demonstrate the structural integrity of the reactor vessel head, the licensee brought videotapes made during the refueling outages noted above. Thus, the meeting consisted of viewing videotapes and determining whether an independent assessment of the reactor vessel penetrations could be made. The staff made various comments concerning the quality of the inspections and their results.

*/RA/*

Stephen P. Sands, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Projects Management  
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: List of Meeting Participants

cc w/encl: See next page

November 26, 2001

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Davis-Besse Nuclear Power Station, Unit 1

SUBJECT: MEETING SUMMARY OF NOVEMBER 8, 2001, TO DISCUSS THE LICENSEE'S RESPONSE TO BULLETIN 2001-01

On November 8, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with a representative of the FirstEnergy Nuclear Operating Company. The meeting, which was closed to the public due to the presentation of proprietary materials, was requested by the licensee in order to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin to their 13th refueling outage which is scheduled to begin in March 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included in the enclosure. There were no meeting handouts.

The licensee's justification to defer inspections recommended by the bulletin relied, in part, on the as-found condition of the reactor vessel head penetrations during the refueling outages of 1996, 1998, and 2000. The licensee's submittal of October 30, 2001, included proprietary photographs of the reactor vessel head taken during these outages. However, due to the poor quality of the photographs, the staff concluded that an independent assessment of the reactor vessel head penetrations could not be made. In an effort to demonstrate the structural integrity of the reactor vessel head, the licensee brought videotapes made during the refueling outages noted above. Thus, the meeting consisted of viewing videotapes and determining whether an independent assessment of the reactor vessel penetrations could be made. The staff made various comments concerning the quality of the inspections and their results.

*/RA/*

Stephen P. Sands, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Projects Management  
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure: List of Meeting Participants

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	PD3-2 r/f	SSands
OGC	ACRS	SBajwa
JZwolinski/TMarsh		AMendiola
THarris	TBergman	GGrant, RIII
WBateman	KWichman	AHiser
SLong	SRosenberg	JZimmerman
ALee	DPickett	

**ADAMS ACCESSION NO. ML013240016**

**\*See previous concurrence**

OFFICE	PM:LPD3	LA:LPD3	SC:EMCB	SC:LPD3
NAME	*S Sands/ <i>DVP for/</i>	*T Harris	*K Wichman	A Mendiola
DATE	11/19/01	11/19/01	11/19/01	11/26/01

**OFFICIAL RECORD COPY**

Mr. Guy G. Campbell  
FirstEnergy Nuclear Operating Company

Davis-Besse Nuclear Power Station, Unit 1

cc:

Mary E. O'Reilly  
FirstEnergy  
76 South Main Street  
Akron, OH 44308

Manager - Regulatory Affairs  
FirstEnergy Nuclear Operating Company  
Davis-Besse Nuclear Power Station  
5501 North State - Route 2  
Oak Harbor, OH 43449-9760

Jay E. Silberg, Esq.  
Shaw, Pittman, Potts  
and Trowbridge  
2300 N Street, NW.  
Washington, DC 20037

Regional Administrator  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, IL 60523-4351

Michael A. Schoppman  
Framatome ANP  
1700 Rockville Pike, Suite 525  
Rockville, MD 20852

Resident Inspector  
U.S. Nuclear Regulatory Commission  
5503 North State Route 2  
Oak Harbor, OH 43449-9760

Plant Manager  
FirstEnergy Nuclear Operating Company  
Davis-Besse Nuclear Power Station  
5501 North State - Route 2  
Oak Harbor, OH 43449-9760

Dennis Clum  
Radiological Assistance Section Supervisor  
Bureau of Radiation Protection  
Ohio Department of Health  
P.O. Box 118  
Columbus, OH 43266-0118

Carol O'Claire, Chief, Radiological Branch  
Ohio Emergency Management Agency  
2855 West Dublin Granville Road  
Columbus, OH 43235-2206

Director  
Ohio Department of Commerce  
Division of Industrial Compliance  
Bureau of Operations & Maintenance  
6606 Tussing Road  
P.O. Box 4009  
Reynoldsburg, OH 43068-9009

Ohio Environmental Protection Agency  
DERR--Compliance Unit  
ATTN: Zack A. Clayton  
P.O. Box 1049  
Columbus, OH 43266-0149

State of Ohio  
Public Utilities Commission  
180 East Broad Street  
Columbus, OH 43266-0573

Attorney General  
Department of Attorney  
30 East Broad Street  
Columbus, OH 43216

President, Board of County  
Commissioners of Ottawa County  
Port Clinton, OH 43252

LIST OF MEETING PARTICIPANTS

NOVEMBER 8, 2001

NRC

John Zwolinski  
Bill Bateman  
Singh Bajwa  
Keith Wichman  
Allen Hiser  
Steve Long  
Stacey Rosenberg  
Jake Zimmerman  
Andrea Lee  
Doug Pickett

FirstEnergy Nuclear Operating Company

Dave Geisen

ENCLOSURE