

September 17, 1998

Mr. H. B. Barron
Vice President, McGuire Site
Duke Energy Corporation
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

SUBJECT: ISSUANCE OF AMENDMENTS - MCGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. MA2017 AND MA2018)

Dear Mr. Barron:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 181 to Facility Operating License NPF-9 and Amendment No. 163 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated May 8, 1997.

The amendments revise the Power Range Neutron Flux Trip setpoints in the event of inoperable main steam safety valves. Also, the amendments delete the reference to three-loop operation. These changes are consistent with your proposed Improved Standard Technical Specifications submitted on May 27, 1997.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

ORIGINAL SIGNED BY:

Frank Rinaldi, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

1/1

Docket Nos. 50-369 and 50-370

DISTRIBUTION

Docket File
PUBLIC
PDII-2 RF
LRPlisco, RII
COgle, RII
THarris (e-mail SE only)
ACRS
OGC
GHill(4)
WBeckner, TSB
JZwolinski

DFo)

Enclosures:

1. Amendment No. 181 to NPF-9
2. Amendment No. 163 to NPF-17
3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\MCGUIRE\MA2017.AMD *See previous concurrence

OFFICE	PDII-2/PM	PDII-2/LA	OGC*	PDII-2/D
NAME	F.RINALDI:cn	L.BERRY	MYOUNG	H.BERKOW
DATE	9/16/98	9/16/98	9/8/98	9/17/98
COPY	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

9809210205 980917
PDR ADOCK 05000369
P PDR

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 17, 1998

Mr. H. B. Barron
Vice President, McGuire Site
Duke Energy Corporation
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

SUBJECT: ISSUANCE OF AMENDMENTS - MCGUIRE NUCLEAR STATION, UNITS 1
AND 2 (TAC NOS. MA2017 AND MA2018)

Dear Mr. Barron:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 181 to Facility Operating License NPF-9 and Amendment No. 163 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated May 8, 1998.

The amendments revise the Power Range Neutron Flux Trip setpoints in the event of inoperable main steam safety valves. Also, the amendments delete the reference to three-loop operation. These changes are consistent with your proposed Improved Standard Technical Specifications submitted on May 27, 1997.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in cursive script, appearing to read "Frank Rinaldi".

Frank Rinaldi, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Enclosures:

1. Amendment No. 181 to NPF-9
2. Amendment No. 163 to NPF-17
3. Safety Evaluation

cc w/encl: See next page

McGuire Nuclear Station

cc:

Mr. Paul R. Newton
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28242

County Manager of
Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Michael T. Cash
Regulatory Compliance Manager
Duke Energy Corporation
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Senior Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N. Tryon Street
Charlotte, North Carolina 28202

Peter R. Harden, IV
Account Manager
Energy Systems Sales
Westinshouse Electric Corporation
P. O. Box 7288
Charlotte, North Carolina 28241-7288

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-0006

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, S.W., Suite 23T85
Atlanta, Georgia 30303

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health and Natural
Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. T. Richard Puryear
Owners Group (NCEMC)
Duke Energy Corporation
4800 Concord Road
York, South Carolina 29745



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY CORPORATION

DOCKET NO. 50-369

McGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 181
License No. NPF-9

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Energy Corporation (licensee) dated May 8, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9809210209 980917
PDR ADOCK 05000369
P PDR


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 181, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: September 17, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 181

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 7-1
3/4 7-2
B 3/4 7-1
B 3/4 7-2

Insert

3/4 7-1
3/4 7-2
B 3/4 7-1
B 3/4 7-2

3/4.7 PLANT SYSTEMS

3/4.7.1 TURBINE CYCLE

SAFETY VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.1 All main steam line Code safety valves associated with each steam generator shall be OPERABLE with lift settings as specified in Table 3.7-2.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With four reactor coolant loops and associated steam generators in operation and with one or more main steam line code safety valves inoperable, operation in MODES 1, 2, and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or the Power Range Neutron Flux High Trip Setpoint is reduced per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.7.1.1 No additional requirements other than those required by Specification 4.0.5. Following testing, lift settings shall be within $\pm 1\%$.

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT WITH
INOPERABLE STEAM LINE SAFETY VALVES DURING FOUR LOOP OPERATION

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Power Range Neutron Flux High Setpoint (Percent of RATED THERMAL POWER)</u>
1	58
2	39
3	19

TABLE 3.7-2

STEAM LINE SAFETY VALVES PER LOOP

<u>VALVE NUMBER</u>					<u>LIFT SETTING(± 3%)*</u>	<u>ORIFICE SIZE</u>
	<u>Loop A</u>	<u>Loop B</u>	<u>Loop C</u>	<u>Loop D</u>		
1. SV 20	SV 14	SV 8	SV 2		1170 psig	12.174 in ²
2. SV 21	SV 15	SV 9	SV 3		1190 psig	12.174 in ²
3. SV 22	SV 16	SV 10	SV 4		1205 psig	16.00 in ²
4. SV 23	SV 17	SV 11	SV 5		1220 psig	16.00 in ²
5. SV 24	SV 18	SV 12	SV 6		1225 psig	16.00 in ²

* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

3/4.7 PLANT SYSTEMS

BASES

3/4.7.1 TURBINE CYCLE

3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam line Code safety valves ensures that the Secondary Coolant System pressure will be limited to within 110% of its design pressure of 1185 psig during the most severe anticipated system operational transient. The maximum relieving capacity is associated with a Turbine trip from 100% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink (i.e., no steam bypass to the condenser).

The specified valve lift settings and relieving capacities are in accordance with the requirements of Section III of the ASME Boiler and Pressure Code, 1971 Edition. Table 3.7-2 allows a $\pm 3\%$ setpoint tolerance for OPERABILITY; however, the valves are reset to $\pm 1\%$ during surveillance testing to allow for drift. The total relieving capacity for all valves on all of the steam lines is 15.9×10^6 lbs/hr which is 105% of the total secondary steam flow of 15.14×10^6 lbs/hr at 100% RATED THERMAL POWER. A minimum of two OPERABLE safety valves per steam generator ensures that sufficient relieving capacity is available for the allowable THERMAL POWER restriction in Table 3.7-1.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in Secondary Coolant System steam flow and THERMAL POWER required by the reduced Reactor Trip Settings of the Power Range Neutron Flux channels. The Reactor Trip Setpoint reductions are derived based on the algorithm contained in Westinghouse's Nuclear Safety Advisory Letter (NSAL) 94-001.

PLANT SYSTEMS

BASES

3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the Auxiliary Feedwater System ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss-of-offsite power.

Each electric motor-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 450 gpm at a pressure of 1210 psig to the entrance of the steam generators. The steam-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 900 gpm at a pressure of 1210 psig to the entrance of the steam generators. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the RHR System may be placed into operation.

Verification of the steam turbine-driven pump discharge pressure should be deferred until suitable test conditions are established (i.e., greater than or equal to 900 psig in the secondary side of the steam generator). This deferral is required because until 900 psig is reached, there is insufficient steam pressure to perform the test.

3/4.7.1.3 SPECIFIC ACTIVITY

The limitations on Secondary Coolant System specific activity ensure that the resultant offsite radiation dose will be limited to a small fraction of 10 CFR Part 100 dose guideline values in the event of a steam line rupture. This dose also includes the effects of a coincident 1.0 gpm reactor to secondary tube leak in the steam generator of the affected steam line. These values are consistent with the assumptions used in the accident analyses.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

DUKE ENERGY CORPORATION

DOCKET NO. 50-370

McGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 163
License No. NPF-17

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility), Facility Operating License No. NPF-17 filed by the Duke Energy Corporation (licensee) dated May 8, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 163 , are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: September 17, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 163

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove

3/4 7-1
3/4 7-2
B 3/4 7-1
B 3/4 7-2

Insert

3/4 7-1
3/4 7-2
B 3/4 7-1
B 3/4 7-2

3/4.7 PLANT SYSTEMS

3/4.7.1 TURBINE CYCLE

SAFETY VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.1 All main steam line Code safety valves associated with each steam generator shall be OPERABLE with lift settings as specified in Table 3.7-2.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With four reactor coolant loops and associated steam generators in operation and with one or more main steam line code safety valves inoperable, operation in MODES 1, 2, and 3 may proceed provided, that within 4 hours, either the inoperable valve is restored to OPERABLE status or the Power Range Neutron Flux High Trip Setpoint is reduced per Table 3.7-1; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.7.1.1 No additional requirements other than those required by Specification 4.0.5. Following testing, lift settings shall be within $\pm 1\%$.

TABLE 3.7-1

MAXIMUM ALLOWABLE POWER RANGE NEUTRON FLUX HIGH SETPOINT WITH
INOPERABLE STEAM LINE SAFETY VALVES DURING FOUR LOOP OPERATION

<u>Maximum Number of Inoperable Safety Valves on Any Operating Steam Generator</u>	<u>Maximum Allowable Power Range Neutron Flux High Setpoint (Percent of RATED THERMAL POWER)</u>
1	58
2	39
3	19

TABLE 3.7-2

STEAM LINE SAFETY VALVES PER LOOP

<u>VALVE NUMBER</u>					<u>LIFT SETTING(± 3%)*</u>	<u>ORIFICE SIZE</u>
	<u>Loop A</u>	<u>Loop B</u>	<u>Loop C</u>	<u>Loop D</u>		
1. SV 20	SV 14	SV 8	SV 2		1170 psig	12.174 in ²
2. SV 21	SV 15	SV 9	SV 3		1190 psig	12.174 in ²
3. SV 22	SV 16	SV 10	SV 4		1205 psig	16.00 in ²
4. SV 23	SV 17	SV 11	SV 5		1220 psig	16.00 in ²
5. SV 24	SV 18	SV 12	SV 6		1225 psig	16.00 in ²

* The lift setting pressure shall correspond to ambient conditions for the valve at nominal operating temperature and pressure.

3/4.7 PLANT SYSTEMS

BASES

3/4.7.1 TURBINE CYCLE

3/4.7.1.1 SAFETY VALVES

The OPERABILITY of the main steam line Code safety valves ensures that the Secondary Coolant System pressure will be limited to within 110% of its design pressure of 1185 psig during the most severe anticipated system operational transient. The maximum relieving capacity is associated with a Turbine trip from 100% RATED THERMAL POWER coincident with an assumed loss of condenser heat sink (i.e., no steam bypass to the condenser).

The specified valve lift settings and relieving capacities are in accordance with the requirements of Section III of the ASME Boiler and Pressure Code, 1971 Edition. Table 3.7-2 allows a $\pm 3\%$ setpoint tolerance for OPERABILITY; however, the valves are reset to $\pm 1\%$ during surveillance testing to allow for drift. The total relieving capacity for all valves on all of the steam lines is 15.9×10^6 lbs/hr which is 105% of the total secondary steam flow of 15.14×10^6 lbs/hr at 100% RATED THERMAL POWER. A minimum of two OPERABLE safety valves per steam generator ensures that sufficient relieving capacity is available for the allowable THERMAL POWER restriction in Table 3.7-1.

STARTUP and/or POWER OPERATION is allowable with safety valves inoperable within the limitations of the ACTION requirements on the basis of the reduction in Secondary Coolant System steam flow and THERMAL POWER required by the reduced Reactor Trip Settings of the Power Range Neutron Flux channels. The Reactor Trip Setpoint reductions are derived based on the algorithm contained in Westinghouse's Nuclear Safety Advisory Letter (NSAL) 94-001.

PLANT SYSTEMS

BASES

3/4.7.1.2 AUXILIARY FEEDWATER SYSTEM

The OPERABILITY of the Auxiliary Feedwater System ensures that the Reactor Coolant System can be cooled down to less than 350°F from normal operating conditions in the event of a total loss-of-offsite power.

Each electric motor-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 450 gpm at a pressure of 1210 psig to the entrance of the steam generators. The steam-driven auxiliary feedwater pump is capable of delivering a total feedwater flow of 900 gpm at a pressure of 1210 psig to the entrance of the steam generators. This capacity is sufficient to ensure that adequate feedwater flow is available to remove decay heat and reduce the Reactor Coolant System temperature to less than 350°F when the RHR System may be placed into operation.

Verification of the steam turbine-driven pump discharge pressure should be deferred until suitable test conditions are established (i.e., greater than or equal to 900 psig in the secondary side of the steam generator). This deferral is required because until 900 psig is reached, there is insufficient steam pressure to perform the test.

3/4.7.1.3 SPECIFIC ACTIVITY

The limitations on Secondary Coolant System specific activity ensure that the resultant offsite radiation dose will be limited to a small fraction of 10 CFR Part 100 dose guideline values in the event of a steam line rupture. This dose also includes the effects of a coincident 1.0 gpm reactor to secondary tube leak in the steam generator of the affected steam line. These values are consistent with the assumptions used in the accident analyses.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO AMENDMENT NO. 181 TO FACILITY OPERATING LICENSE NPF-9
AND AMENDMENT NO. 163 TO FACILITY OPERATING LICENSE NPF-17

DUKE ENERGY CORPORATION

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-369 AND 50-370

1.0 INTRODUCTION

By letter dated May 8, 1998, Duke Energy Corporation (the licensee) submitted a request for changes to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TSs). The requested changes revise TS Table 3.7-1 by lowering the maximum allowable power range neutron flux high setpoint when one or more main steam safety valves (MSSVs) are inoperable. The proposed changes also revise the Bases for TS 3/4.7.1.1 to include the algorithm used for determining the new setpoint values. The proposed changes also delete the references to three-loop operation in current TS 3.7.1.1(b) and Table 3.7-2. These changes are consistent with the proposed Improved Standard Technical Specifications submitted by the licensee on May 27, 1997.

2.0 EVALUATION

Westinghouse has determined that the maximum allowable power range neutron flux high setpoints given in TS Table 3.7-1 may not be low enough to prevent a secondary side overpressurization during a loss of load/turbine trip. In its Nuclear Safety Advisory Letter (NSAL) 94-001 dated January 20, 1994, Westinghouse reported its determination that the maximum allowable initial power level is not a linear function of available MSSV relief capacity. It was further determined that the current TS provisions for reduced reactor power levels with inoperable MSSVs may not preclude the secondary side pressure from exceeding 110 percent of its design value during a loss of main feedwater transient, particularly at lower power levels. NSAL 94-001 also provided the licensee with an algorithm for determining revised neutron flux high setpoints.

The licensee has calculated new neutron flux high setpoint values based on the algorithm contained in Westinghouse's NSAL 94-001. The new values were lower than the values in the current TS. This process resulted in high neutron flux reactor trip setpoint values of 58 percent, 39 percent, and 19 percent of rated thermal power for a maximum of one, two, and three inoperable MSSVs, respectively, on any operating steam generator. Current TS values are 87 percent, 65 percent, and 43 percent for those same conditions.

The staff has found that the licensee's revised algorithm ensures that the maximum power level allowed for operation with inoperable MSSVs is below the heat-removing capability of the operable MSSVs. This ensures that the secondary system pressure will not exceed 110 percent of its design value. In addition, the new setpoints are more conservative than the previous setpoints. Therefore, the staff finds that the proposed changes to TS Table 3.7-1 and Bases Section 3/4.7.1.1 are acceptable.

The licensee also proposes to delete the references to three-loop operation in its proposed TS 3.7.1.1(b), delete Table 3.7-2 (setpoints for three-loop operation), and renumber Table 3.7-3 as Table 3.7-2. These changes are necessary to bring the TSs consistent with the plant operation, which does not allow three-loop operation during Modes 1 and 2 at McGuire. The staff finds that these proposed changes are acceptable.

3.0 STATE CONSULTATION

In accordance with the Commission's regulations, the North Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (63 FR 40554 dated July 29, 1998). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: C. Liang

Date: September 17, 1998