

November 29, 2001

Mr. Mark Reddemann
Site Vice President
Kewaunee and Point Beach Nuclear Plants
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REVIEW OF POTENTIAL FOR A
REQUEST FOR APPROVAL OF ALTERNATIVE TO ASME CODE
REQUIREMENTS (TAC NO. MB3414)

Dear Mr. Reddemann:

By letter dated November 14, 2001, the Nuclear Management Company, LLC (NMC) submitted a potential relief request for the Nuclear Regulatory Commission (NRC) to review and approve an alternative to American Society of Mechanical Engineers (ASME) Code requirements associated with a potential repair to the part-length control rod drive mechanism (CRDM) housing at the Kewaunee Nuclear Power Plant (KNPP).

Mr. Tom Webb of the NMC staff informed the NRC staff via telephone on November 19, 2001, that the NMC staff completed its visual inspection testing (VT) of the part-length CRDMs. Mr. Webb stated that the VT of the part-length CRDMs indicated no active leaks; therefore, NMC will not be removing any part-length CRDMs and will not require a relief request for an alternative to the ASME code requirements. Based on this information, this completes the NRC staff's review of your submittal dated November 14, 2001.

This completes TAC number MB3414.

Sincerely,

/RA/

John G. Lamb, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-305

cc: See next page

Mr. Mark Reddemann
Site Vice President
Kewaunee and Point Beach Nuclear Plants
Nuclear Management Company, LLC
6610 Nuclear Road
Two Rivers, WI 54241

November 29, 2001

SUBJECT: KEWAUNEE NUCLEAR POWER PLANT - REVIEW OF POTENTIAL FOR A
REQUEST FOR APPROVAL OF ALTERNATIVE TO ASME CODE
REQUIREMENTS (TAC NO. MB3414)

Dear Mr. Reddemann:

By letter dated November 14, 2001, the Nuclear Management Company, LLC (NMC) submitted a potential relief request for the Nuclear Regulatory Commission (NRC) to review and approve an alternative to American Society of Mechanical Engineers (ASME) Code requirements associated with a potential repair to the part-length control rod drive mechanism (CRDM) housing at the Kewaunee Nuclear Power Plant (KNPP).

Mr. Tom Webb of the NMC staff informed the NRC staff via telephone on November 19, 2001, that the NMC staff completed its visual inspection testing (VT) of the part-length CRDMs. Mr. Webb stated that the VT of the part-length CRDMs indicated no active leaks; therefore, NMC will not be removing any part-length CRDMs and will not require a relief request for an alternative to the ASME code requirements. Based on this information, this completes the NRC staff's review of your submittal dated November 14, 2001.

This completes TAC number MB3414.

Sincerely,

/RA/

John G. Lamb, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-305

cc: See next page

DISTRIBUTION:

PUBLIC	PDIII-1 Reading	THarris	OGC
ACRS	RLanksbury,RIII	WReckley	TBergman
GHill(2)	JLamb		

ADAMS ACCESSION NO. **ML013240062**

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/SC(A)
NAME	JLamb	THarris	WReckley
DATE	11/27/01	11/26/01	11/26/01

OFFICIAL RECORD COPY

Kewaunee Nuclear Power Plant

cc:

Foley & Lardner
ATTN: Bradley D. Jackson
One South Pinckney Street
P.O. Box 1497
Madison, WI 53701-1497

Chairman
Town of Carlton
Route 1
Kewaunee, WI 54216

Mr. Gerald Novickis, Chairman
Kewaunee County Board
Kewaunee County Courthouse
613 Dodge Street
Kewaunee, WI 54216

Attorney General
114 East, State Capitol
Madison, WI 53702

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
Route #1, Box 999
Kewaunee, WI 54216

Regional Administrator - Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4531

James D. Looock, Chief Engineer
Public Service Commission
of Wisconsin
610 N. Whitney Way
Madison, WI 53707-7854

Mr. Roy A. Anderson
Executive Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Wisconsin Public Service Corporation
600 N. Adams Street
Green Bay, WI 54307-9002

Plant Manager
Kewaunee Nuclear Power Plant
Nuclear Management Company, LLC
North 490, Highway 42
Kewaunee, WI 54216-9511