

UNITED STATES

WASHINGTON, D.C. 20555-0001

July 29, 1996

Mr. T. C. McMeekin Vice President, McGuire Site Duke Power Company 12700 Hagers Ferry Road Huntersville, NC 28078-8985

SUBJECT: ISSUANCE OF AMENDMENTS - McGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. M94904 AND M94905)

Dear Mr. McMeekin:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 168 to Facility Operating License NPF-9 and Amendment No. 150 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 4, 1996.

The amendments delete Flow Monitoring System from TS 3.4.6.1 and associated surveillance requirements.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly <u>Federal Register</u> notice.

Sincerely.

Victor Nerses, Senior Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Enclosures: 1. Amendment No. 168 to NPF-9

- 2. Amendment No. 150 to NPF-17
- 3. Safety Evaluation

cc w/encl: See next page

9608260077 960729 PDR ADOCK 05000369 P PDR PDR Mr. T. C. McMeekin Vice President, McGuire Site Duke Power Company 12700 Hagers Ferry Road Huntersville, NC 28078-8985 Distribution Docket File R.Crlenjak,RII PUBLIC G.Hill(4) T-5 C3 PDII-2 Reading C.Grimes O-11 F23 S.Varga ACRS T-2 E26 OGC O-15 B18 E.Merschoff,DRP/RII

SUBJECT: ISSUANCE OF AMENDMENTS - McGUIRE NUCLEAR STATION, UNITS 1 AND 2 (TAC NOS. M94904 AND M94905)

Dear Mr. McMeekin:

The Nuclear Regulatory Commission has issued the enclosed Amendment No. 168 to Facility Operating License NPF-9 and Amendment No. 150 to Facility Operating License NPF-17 for the McGuire Nuclear Station, Units 1 and 2. The amendments consist of changes to the Technical Specifications (TS) in response to your application dated March 4, 1996.

The amendments delete Flow Monitoring System from TS 3.4.6.1 and associated surveillance requirements.

A copy of the related Safety Evaluation is also enclosed. A Notice of Issuance will be included in the Commission's biweekly <u>Federal</u> <u>Register</u> notice.

Sincerely,

original signed by Victor Nerses, Senior Project Manager Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket Nos. 50-369 and 50-370

Enclosures:

1. Amendment No. 168 to NPF-9

2. Amendment No. 150 to NPF-17

3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\MCGUIRE\M94904.AMD

OFFICE	PDII-2/LA	PD11-2/PM	SPLB	oge ett	PDII-2/D	
NAME	L.BERRY	V.NERŞES	T.MARSH	CHOLLER	H.BERKOW	4:2
DATE	6/33196	7/3 196	7/16 196	7/24/96	-126 196	ί
COPY	YES	YES NO	VES NO	YES NO	YES NO	

OFFICIAL RECORD COPY

Mr. T. C. McMeekin Duke Power Company

cc: Mr. Paul R. Newton Legal Department, (PB05E) Duke Power Company 422 South Church Street Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County 720 East Fourth Street Charlotte, North Carolina 28202

Mr. J. E. Snyder Regulatory Compliance Manager Duke Power Company McGuire Nuclear Site 12700 Hagers Ferry Road Huntersville, North Carolina 28078

J. Michael McGarry, III, Esquire Winston and Strawn 1400 L Street, NW. Washington, DC 20005

Senior Resident Inspector c/o U. S. Nuclear Regulatory Commission 12700 Hagers Ferry Road Huntersville, North Carolina 28078

Mr. Peter R. Harden, IV Account Sales Manager Westinghouse Electric Corporation Power Systems Field Sales P. O. Box 7288 Charlotte, North Carolina 28241

Dr. John M. Barry Mecklenberg County Department of Environmental Protection 700 N. Tryon Street Charlotte, North Carolina 28202 McGuire Nuclear Station

Ms. Karen E. Long Assistant Attorney General North Carolina Department of Justice P. O. Box 629 Raleigh, North Carolina 27602

Mr. G. A. Copp Licensing - EC050 Duke Power Company 526 South Church Street Charlotte, North Carolina 28242

Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta Street, NW. Suite 2900 Atlanta, Georgia 30323

Elaine Wathen, Lead REP Planner Division of Emergency Management 116 West Jones Street Raleigh, North Carolina 27603-1335

Mr. Dayne H. Brown, Director
Division of Radiation Protection
North Carolina Department of
Environmental Health and Natural
Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-369

MCGUIRE NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 168 License No. NPF-9

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 1 (the facility), Facility Operating License No. NPF-9 filed by the Duke Power Company (licensee) dated March 4, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9608260079 960729 PDR ADOCK 05000369 P PDR 2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-9 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 168, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Herbert N. Berkow, Director Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Technical Specification Changes

Date of Issuance: July 29, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 168

FACILITY OPERATING LICENSE NO. NPF-9

DOCKET NO. 50-369

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

<u>Remove Page</u>	<u>Insert Page</u>
3/4 4-19	3/4 4-19

.

REACTOR COOLANT SYSTEM

3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE

LEAKAGE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

3.4.6.1 The following Reactor Coolant System Leakage Detection Systems shall be OPERABLE:

- a. The Containment Atmosphere Gaseous Radioactivity Monitoring System,
- b. The Containment Floor and Equipment Sump Level System, and
- c. Either the Containment Ventilation Condensate Drain Tank Level Monitoring System or a Containment Atmosphere Particulate Radioactivity Monitoring System.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With only two of the above required Leakage Detection Systems OPERABLE, operation may continue for up to 30 days provided grab samples of the containment atmosphere are obtained and analyzed at least once per 24 hours when the required Gaseous or Particulate Radioactivity Monitoring System is inoperable; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.6.1 The Leakage Detection Systems shall be demonstrated OPERABLE by:

- a. Containment Atmosphere Gaseous and Particulate Radioactivity Monitoring Systems-performance of CHANNEL CHECK, CHANNEL CALIBRATION and ANALOG CHANNEL OPERATIONAL TEST at the frequencies specified in Table 4.3-3.
- b. Containment Floor and Equipment Sump Level System-performance of CHANNEL CALIBRATION at least once per 18 months, and
- c. Containment Ventilation Condensate Drain Tank Level Monitoring System-performance of CHANNEL CALIBRATION at least once per 18 months.



UNITED STATES

WASHINGTON, D.C. 20555-0001

DUKE POWER COMPANY

DOCKET NO. 50-370

MCGUIRE NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 150 License No. NPF-17

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the McGuire Nuclear Station, Unit 2 (the facility), Facility Operating License No. NPF-17 filed by the Duke Power Company (licensee) dated March 4, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-17 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. $_{150}$, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Herbert N. Berkow, Director Project Directorate II-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Technical Specification Changes

Date of Issuance: July 29, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 150

FACILITY OPERATING LICENSE NO. NPF-17

DOCKET NO. 50-370

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains vertical lines indicating the areas of change.

<u>Remove Page</u>	<u>Insert Page</u>
3/4 4-19	3/4 4-19

. •

2

REACTOR COOLANT SYSTEM

3/4.4.6 REACTOR COOLANT SYSTEM LEAKAGE

LEAKAGE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

3.4.6.1 The following Reactor Coolant System Leakage Detection Systems shall be OPERABLE:

- a. The Containment Atmosphere Gaseous Radioactivity Monitoring System,
- b. The Containment Floor and Equipment Sump Level System, and
- c. Either the Containment Ventilation Condensate Drain Tank Level Monitoring System or a Containment Atmosphere Particulate Radioactivity Monitoring System.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With only two of the above required Leakage Detection Systems OPERABLE, operation may continue for up to 30 days provided grab samples of the containment atmosphere are obtained and analyzed at least once per 24 hours when the required Gaseous or Particulate Radioactivity Monitoring System is inoperable; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.6.1 The Leakage Detection Systems shall be demonstrated OPERABLE by:

- a. Containment Atmosphere Gaseous and Particulate Radioactivity Monitoring Systems-performance of CHANNEL CHECK, CHANNEL CALIBRATION and ANALOG CHANNEL OPERATIONAL TEST at the frequencies specified in Table 4.3-3.
- b. Containment Floor and Equipment Sump Level System-performance of CHANNEL CALIBRATION at least once per 18 months, and
- c. Containment Ventilation Condensate Drain Tank Level Monitoring System-performance of CHANNEL CALIBRATION at least once per 18 months.



UNITED STATES UNITED STATES UNITED STATES UNITED STATES

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 168 TO FACILITY OPERATING LICENSE NPF-9

AND AMENDMENT NO. 150 TO FACILITY OPERATING LICENSE NPF-17

DUKE POWER COMPANY

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

DOCKET NOS. 50-369 AND 50-370

1.0 INTRODUCTION

By letter dated March 4, 1996, Duke Power Company (the licensee) submitted a request for changes to the McGuire Nuclear Station, Units 1 and 2, Technical Specifications (TS). The requested changes would delete the reactor coolant system (RCS) flow monitoring system from the TS and Surveillance Requirements. Currently, TS 3/4.4.6 "Reactor Coolant System Leakage" has a Limiting Condition for Operation (LCO) (LCO 3.4.6.1b), that requires either the containment floor and equipment sump level system or the flow monitoring system to be OPERABLE when in Modes 1, 2, 3, and 4. The proposed change would revise LCO 3.4.6.1b to require specifically that the containment floor and equipment sump level system to be OPERABLE and eliminate the flow monitoring system as a viable alternative. The associated Surveillance Requirement 4.4.6.1b would also be revised to delete the surveillance of the flow monitoring system. The stated purpose of the proposed change is that the flow monitoring system cannot be used to monitor unidentified RCS leakage because of known inaccuracies caused by mechanical flaws in the initial design of the system.

2.0 EVALUATION

The current TS requires three RCS leakage detection systems to be operable. One of these systems, the gaseous radioactivity monitoring system, has no alternative system and must be operable in all applicable modes. For each of the other required systems, two alternatives are given in the LCO. The first alternative is a choice between the containment floor and equipment sump level system and the flow monitoring system. The second alternative is a choice between the containment ventilation condensate drain tank level monitoring system and the containment atmosphere particulate radioactivity monitoring The proposed change would only eliminate the first alternative with system. no changes to the rest of the required RCS leakage detection system TS requirements. The proposed change still requires three RCS leakage detection systems to be OPERABLE and is, therefore, more restrictive because one of the alternatives has been removed. The proposed change is also conservative in nature because it will prevent reliance on an inaccurate leakage detection method to satisfy

9608260082 960729 PDR ADDCK 05000369 P PDR PDR an LCO. The staff, therefore, concludes that the proposed change to delete the flow monitoring system from the TS is acceptable.

Based on its evaluation, the staff concludes that the proposed change to eliminate the flow monitoring system and its surveillance requirements from the plant TS is necessary to prevent the potential for reliance on an inaccurate monitoring system and is more restrictive and more conservative than the current specification. The staff, therefore, concludes that the proposed changes to TS 3/4.4.6 are acceptable and should be approved.

3.0 STATE CONSULTATION

. . .

In accordance with the Commission's regulations, the North Carolina State official was notified of the proposed issuance of the amendments. The State official had no comments.

4.0 ENVIRONMENTAL CONSIDERATION

The amendments change requirements with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and change surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant on such finding (61 FR 18166 dated April 24, 1996). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

5.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. LeFave

Date: July 29, 1996