

174
c
Dodd
From: <Doddcv@
To: Ian Barnes
Date: Wed, Jul 19, 2000 7:31 AM
Subject: Ian's Report

Exb

Ian:

Your report was very well written and to the point. I did not review the EPRI Performance Demonstration Data Base's ETSS myself, but was told by Gary Henry that the phase was set to 15 degrees rather than 10 degrees for the 40% TW id notches back in 1997. This is the only possible difference that may be present. If you read the document, I am sure that you have it correct.

We did not ask for their training and testing in 1997 when we were there, but they could not document their training and testing for this outage. I hope that the region will strongly urge them to do this before closing out this test. Good job Ian.

Caius

CC: <WLS@nrc.gov>, <smc1@nrc.gov>

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 6
FOIA- 2001-0256

C/31